

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF **ID:OR4100551 WTP:-WTP-A Month/Year:** Oct 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	0.04	0.03	0.04	----	0.04
2	----	----	0.04	0.02	0.03	----	0.04
3	----	----	0.04	0.02	----	----	0.04
4	----	----	----	----	----	----	----
5	----	----	----	----	----	----	----
6	----	----	----	0.02	0.02	----	0.02
7	----	----	----	0.03	0.06	----	0.06
8	----	----	----	0.02	0.02	----	0.02
9	----	----	----	0.02	0.03	----	0.03
10	----	----	0.03	0.04	0.04	----	0.04
11	----	----	----	----	----	----	----
12	----	----	----	----	----	----	----
13	----	----	----	0.05	0.03	----	0.05
14	----	----	----	0.02	0.02	----	0.02
15	----	----	0.02	0.02	0.03	----	0.03
16	----	----	0.03	----	0.02	----	0.03
17	----	----	----	0.02	----	----	0.02
18	----	----	----	----	----	----	----
19	----	----	----	----	----	----	----
20	----	----	----	0.02	0.02	----	0.02
21	----	----	0.02	0.02	0.02	----	0.02
22	----	----	0.02	0.02	----	----	0.02
23	----	----	0.02	0.02	----	----	0.02
24	----	----	----	0.02	----	----	0.02
25	----	----	----	----	----	----	----
26	----	----	----	----	----	----	----
27	----	----	----	0.02	0.02	----	0.02
28	----	----	0.02	0.02	0.02	----	0.02
29	----	----	0.02	0.02	0.02	----	0.02
30	----	----	----	0.02	0.02	----	0.02
31	----	----	0.02	0.02	0.02	----	0.02

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings $\leq$ 0.3 NTU?	Yes/No <u>Yes</u> /No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All the 4 hour turbidity readings $\leq$ 1 NTU?	Yes/No <u>Yes</u> /No	<u>Yes</u> /No	<u>Yes</u> /No
All turbidity readings < IFE ² triggers?	Yes/No ² <u>Yes</u> /No		
Notes:		PRINTED NAME: <u>Ryan A. Sherman</u>	
		SIGNATURE: <u>[Signature]</u>	DATE: November 6, 2025
		PHONE #: (541) 572-2589	CERT #: <u>9184</u>

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: Oct 2025								Required Log Inactivation: .5
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	0.6	105	65	18.3	8.1	16	Yes	1200
2 / 11 AM	1.2	105	123	17.2	8.3	19	Yes	1200
3 / 11 AM	1.1	105	116	16.7	7.9	17	Yes	1200
4 / 11 AM	----	----	----	----	----	----	----	----
5 / 11 AM	----	----	----	----	----	----	----	----
6 / 11 AM	0.9	105	95	17.2	8.2	18	Yes	1200
7 / 11 AM	1.0	105	106	17.8	8.2	17	Yes	1200
8 / 11 AM	0.6	105	59	18.3	8.1	16	Yes	1200
9 / 11 AM	1.0	105	109	16.1	8.3	20	Yes	1200
10 / 11 AM	1.2	105	126	16.1	8.2	20	Yes	1200
11 / 11 AM	----	----	----	----	----	----	----	----
12 / 11 AM	----	----	----	----	----	----	----	----
13 / 11 AM	1.0	105	108	15.6	8.2	20	Yes	1200
14 / 11 AM	1.1	105	118	15.0	8.3	22	Yes	1200
15 / 11 AM	1.1	105	117	15.0	8.2	21	Yes	1200
16 / 11 AM	0.7	105	69	16.1	8.3	20	Yes	1200
17 / 11 AM	1.1	105	110	14.4	8.2	22	Yes	1200
18 / 11 AM	----	----	----	----	----	----	----	----
19 / 11 AM	----	----	----	----	----	----	----	----
20 / 11 AM	0.9	105	99	13.9	8.2	23	Yes	1200
21 / 11 AM	1.1	105	111	14.4	8.0	21	Yes	1200
22 / 11 AM	1.1	105	110	13.9	8.0	22	Yes	1200
23 / 11 AM	1.0	105	107	15.0	8.3	22	Yes	1200
24 / 11 AM	1.0	105	107	14.4	8.3	23	Yes	1200
25 / 11 AM	----	----	----	----	----	----	----	----
26 / 11 AM	----	----	----	----	----	----	----	----
27 / 11 AM	0.8	105	87	14.4	7.8	19	Yes	1200
28 / 11 AM	0.9	105	95	13.9	8.0	21	Yes	1200
29 / 11 AM	1.0	105	105	13.3	8.2	24	Yes	1200
30 / 11 AM	1.0	105	107	13.3	8.1	23	Yes	1200
31 / 11 AM	1.0	105	106	12.8	8.3	25	Yes	1200

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012