

## OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: January 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	-----	-----	0.05	0.05	-----	-----	0.05
2	-----	-----	-----	-----	-----	-----	-----
3	-----	-----	-----	-----	-----	-----	-----
4	-----	-----	0.05	0.05	0.05	-----	0.05
5	-----	-----	0.05	0.05	0.05	-----	0.05
6	-----	-----	0.05	0.05	0.06	-----	0.06
7	-----	-----	0.06	0.05	0.05	-----	0.06
8	-----	-----	0.05	0.05	-----	-----	0.05
9	-----	-----	-----	-----	-----	-----	-----
10	-----	-----	-----	-----	-----	-----	-----
11	-----	-----	-----	0.05	0.05	-----	0.05
12	-----	-----	0.05	0.05	0.05	-----	0.05
13	-----	-----	-----	0.02	0.02	-----	0.02
14	-----	-----	0.02	0.01	0.01	-----	0.02
15	-----	-----	0.02	0.04	0.05	-----	0.05
16	-----	-----	-----	-----	-----	-----	-----
17	-----	-----	-----	-----	-----	-----	-----
18	-----	-----	-----	0.02	-----	-----	0.02
19	-----	-----	0.01	0.01	0.01	-----	0.01
20	-----	-----	0.02	0.02	0.02	-----	0.02
21	-----	-----	0.04	0.04	0.01	-----	0.04
22	-----	-----	0.01	0.01	0.01	-----	0.01
23	-----	-----	-----	-----	-----	-----	-----
24	-----	-----	-----	-----	-----	-----	-----
25	-----	-----	-----	0.02	0.01	-----	0.02
26	-----	-----	0.01	0.01	0.01	-----	0.01
27	-----	-----	0.02	0.03	0.04	-----	0.04
28	-----	-----	0.02	0.01	0.01	-----	0.02
29	-----	-----	0.01	0.02	0.04	-----	0.04
30	-----	-----	-----	-----	-----	-----	-----
31	-----	-----	-----	-----	-----	-----	-----

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / No <sup>2</sup>		
Notes:	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: February 1, 2021
	PHONE #: ( 541 ) 572-2589	CERT #: <i>9184</i>

<sup>1</sup> Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: January 2021

Required Log Inactivation: 1

Date / Time	Min. Cl <sub>2</sub> Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	105	114	8.9	8.0	60	Yes	850
2 / 11 AM	----	----	----	----	----	----	----	----
3 / 11 AM	----	----	----	----	----	----	----	----
4 / 11 AM	0.9	105	92	9.4	8.0	57	Yes	850
5 / 11 AM	1.0	105	104	10.0	8.1	57	Yes	850
6 / 11 AM	1.2	105	127	10.6	8.1	56	Yes	850
7 / 11 AM	1.2	105	124	9.4	8.0	58	Yes	850
8 / 11 AM	1.3	105	138	10.0	8.0	57	Yes	850
9 / 11 AM	----	----	----	----	----	----	----	----
10 / 11 AM	----	----	----	----	----	----	----	----
11 / 11 AM	1.0	105	104	9.4	8.0	58	Yes	850
12 / 11 AM	1.2	105	123	10.0	8.1	58	Yes	850
13 / 11 AM	1.4	105	146	11.7	8.0	52	Yes	850
14 / 11 AM	1.4	105	149	12.8	8.0	48	Yes	850
15 / 11 AM	1.5	105	159	12.2	8.0	50	Yes	850
16 / 11 AM	----	----	----	----	----	----	----	----
17 / 11 AM	----	----	----	----	----	----	----	----
18 / 11 AM	1.0	105	108	11.7	8.1	51	Yes	850
19 / 11 AM	1.3	105	132	12.2	8.0	49	Yes	850
20 / 11 AM	1.4	105	150	10.6	8.1	58	Yes	850
21 / 11 AM	1.5	105	156	11.1	8.1	56	Yes	850
22 / 11 AM	1.4	105	149	10.6	8.1	57	Yes	850
23 / 11 AM	----	----	----	----	----	----	----	----
24 / 11 AM	----	----	----	----	----	----	----	----
25 / 11 AM	1.3	105	135	7.2	7.9	65	Yes	850
26 / 11 AM	1.4	105	143	5.6	7.9	75	Yes	850
27 / 11 AM	1.2	105	125	5.0	8.0	78	Yes	850
28 / 11 AM	1.2	105	126	5.6	8.0	76	Yes	850
29 / 11 AM	1.2	105	121	6.1	8.0	73	Yes	850
30 / 11 AM	----	----	----	----	----	----	----	----
31 / 11 AM	----	----	----	----	----	----	----	----

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012