

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: March 1

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-----	-----	-----	0.01	0.01	-----	0.01
2	-----	-----	0.01	0.01	0.01	-----	0.01
3	-----	-----	0.02	0.02	0.03	-----	0.03
4	-----	-----	0.02	0.02	-----	-----	0.02
5	-----	-----	0.01	0.01	-----	-----	0.01
6	-----	-----	-----	-----	-----	-----	-----
7	-----	-----	-----	-----	-----	-----	-----
8	-----	-----	0.03	0.02	-----	-----	0.03
9	-----	-----	0.01	0.03	0.01	-----	0.03
10	-----	-----	0.01	0.02	-----	-----	0.02
11	-----	-----	0.02	0.03	0.02	-----	0.03
12	-----	-----	0.02	0.03	-----	-----	0.03
13	-----	-----	-----	-----	-----	-----	-----
14	-----	-----	-----	-----	-----	-----	-----
15	-----	-----	-----	0.02	0.01	-----	0.02
16	-----	-----	0.01	0.01	0.01	-----	0.01
17	-----	-----	0.03	0.04	0.01	-----	0.04
18	-----	-----	0.01	0.01	0.01	-----	0.01
19	-----	-----	0.02	-----	0.01	-----	0.02
20	-----	-----	-----	-----	-----	-----	-----
21	-----	-----	-----	-----	-----	-----	-----
22	-----	-----	0.01	-----	-----	-----	0.01
23	-----	-----	0.01	0.01	0.01	-----	0.01
24	-----	-----	0.02	-----	0.02	-----	0.02
25	-----	-----	-----	0.02	0.02	-----	0.02
26	-----	-----	0.03	0.02	0.01	-----	0.03
27	-----	-----	-----	-----	-----	-----	-----
28	-----	-----	-----	-----	-----	-----	-----
29	-----	-----	0.01	0.01	0.01	-----	0.01
30	-----	-----	0.01	-----	-----	-----	0.01
31	-----	-----	-----	0.01	0.02	-----	0.02

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes/No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All the 4 hour turbidity readings ≤ 1 NTU? Yes/No	Yes/No	Yes/No
All turbidity readings < IFE ² triggers? Yes/No²		
Notes:	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. 92</i>	DATE: April 1, 2021
	PHONE #: (541) 572-2589	CERT #: <i>9184</i>

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: March 1

Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	105	119	11.7	8.1	51	Yes	850
2 / 11 AM	1.1	105	114	11.7	7.9	47	Yes	850
3 / 11 AM	1.1	105	120	11.7	7.9	48	Yes	850
4 / 11 AM	1.1	105	113	11.7	7.9	48	Yes	850
5 / 11 AM	1.1	105	110	11.1	8.0	50	Yes	850
6 / 11 AM	----	----	----	----	----	----	----	----
7 / 11 AM	----	----	----	----	----	----	----	----
8 / 11 AM	1.0	105	102	11.1	8.0	51	Yes	850
9 / 11 AM	1.0	105	108	11.1	8.0	51	Yes	850
10 / 11 AM	1.3	105	138	11.1	8.0	54	Yes	850
11 / 11 AM	1.2	105	127	11.1	8.0	52	Yes	850
12 / 11 AM	1.3	105	132	10.6	8.0	55	Yes	850
13 / 11 AM	----	----	----	----	----	----	----	----
14 / 11 AM	----	----	----	----	----	----	----	----
15 / 11 AM	0.8	105	80	11.7	8.1	49	Yes	850
16 / 11 AM	1.0	105	108	8.9	8.2	63	Yes	850
17 / 11 AM	1.0	105	109	8.3	8.2	67	Yes	850
18 / 11 AM	1.1	105	112	8.9	8.3	67	Yes	850
19 / 11 AM	1.2	105	122	7.2	8.4	77	Yes	850
20 / 11 AM	----	----	----	----	----	----	----	----
21 / 11 AM	----	----	----	----	----	----	----	----
22 / 11 AM	----	----	----	----	----	----	----	850
23 / 11 AM	1.0	105	101	7.2	8.4	75	Yes	850
24 / 11 AM	1.1	105	111	8.3	8.3	69	Yes	850
25 / 11 AM	1.0	105	108	8.9	8.3	65	Yes	850
26 / 11 AM	1.1	105	112	9.4	8.3	64	Yes	850
27 / 11 AM	----	----	----	----	----	----	----	----
28 / 11 AM	----	----	----	----	----	----	----	----
29 / 11 AM	1.0	105	102	10.6	8.2	57	Yes	850
30 / 11 AM	1.0	105	108	10.0	8.3	61	Yes	850
31 / 11 AM	1.1	105	116	10.6	8.2	57	Yes	850

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012