

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP--WTP-A Month/Year: April 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-----	-----	-----	0.01	0.01	-----	0.01
2	-----	-----	0.01	-----	0.01	-----	0.01
3	-----	-----	-----	-----	-----	-----	-----
4	-----	-----	-----	-----	-----	-----	-----
5	-----	-----	0.02	0.01	0.01	-----	0.02
6	-----	-----	0.01	0.01	0.01	-----	0.01
7	-----	-----	0.01	0.01	-----	-----	0.01
8	-----	-----	-----	-----	-----	-----	-----
9	-----	-----	0.02	0.01	0.01	-----	0.02
10	-----	-----	-----	-----	-----	-----	-----
11	-----	-----	-----	-----	-----	-----	-----
12	-----	-----	0.02	0.01	0.01	-----	0.02
13	-----	-----	0.01	0.02	0.01	-----	0.02
14	-----	-----	0.01	0.01	0.01	-----	0.01
15	-----	-----	0.02	0.01	-----	-----	0.02
16	-----	-----	0.01	-----	-----	-----	0.01
17	-----	-----	-----	-----	-----	-----	-----
18	-----	-----	-----	-----	-----	-----	-----
19	-----	-----	0.02	0.01	0.01	-----	0.02
20	-----	-----	0.01	0.01	-----	-----	0.01
21	-----	-----	-----	0.01	-----	-----	0.01
22	-----	-----	0.02	-----	-----	-----	0.02
23	-----	-----	0.02	-----	0.01	-----	0.02
24	-----	-----	-----	-----	-----	-----	-----
25	-----	-----	-----	-----	-----	-----	-----
26	-----	-----	-----	0.02	0.02	-----	0.02
27	-----	-----	0.02	0.01	-----	-----	0.02
28	-----	-----	0.01	0.01	-----	-----	0.01
29	-----	-----	0.01	0.01	-----	-----	0.01
30	-----	-----	0.02	0.01	-----	-----	0.02
31	-----	-----	-----	-----	-----	-----	-----

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
All the 4 hour turbidity readings ≤ 1 NTU? Yes/No		
All turbidity readings < IFE ² triggers? Yes/No²		
Notes:	PRINTED NAME: <i>RYAN A. SHERMAN</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: May 3, 2021
	PHONE #: (541) 572-2589	
	CERT #: <i>9184</i>	

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-; WTP-A Month/Year: April 2021								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1/ 11 AM	1.0	105	103	10.6	8.3	59	Yes	850
2/ 11 AM	1.0	105	108	11.7	8.4	56	Yes	850
3/ 11 AM	----	----	----	----	----	----	----	----
4/ 11 AM	----	----	----	----	----	----	----	----
5/ 11 AM	0.9	105	91	11.1	8.2	54	Yes	850
6/ 11 AM	0.9	105	96	11.1	8.2	54	Yes	850
7/ 11 AM	0.9	105	91	11.7	8.2	52	Yes	850
8/ 11 AM	----	----	----	----	----	----	----	----
9/ 11 AM	0.9	105	90	11.1	8.2	53	Yes	850
10/ 11 AM	----	----	----	----	----	----	----	----
11/ 11 AM	----	----	----	----	----	----	----	----
12/ 11 AM	0.8	105	80	11.7	8.1	50	Yes	850
13/ 11 AM	1.1	105	111	11.7	8.2	52	Yes	850
14/ 11 AM	1.1	105	112	12.2	8.1	50	Yes	850
15/ 11 AM	1.1	105	118	12.2	8.2	51	Yes	850
16/ 11 AM	1.2	105	121	12.2	8.0	49	Yes	850
17/ 11 AM	----	----	----	----	----	----	----	----
18/ 11 AM	----	----	----	----	----	----	----	----
19/ 11 AM	1.0	105	100	12.2	8.1	48	Yes	850
20/ 11 AM	1.1	105	116	12.2	8.1	49	Yes	850
21/ 11 AM	1.1	105	116	12.2	8.0	48	Yes	850
22/ 11 AM	1.2	105	125	12.2	8.1	49	Yes	850
23/ 11 AM	1.2	105	127	12.2	8.0	49	Yes	850
24/ 11 AM	----	----	----	----	----	----	----	----
25/ 11 AM	----	----	----	----	----	----	----	----
26/ 11 AM	1.0	105	108	12.8	8.1	48	Yes	850
27/ 11 AM	1.1	105	114	13.3	8.2	47	Yes	850
28/ 11 AM	1.0	105	100	13.3	8.1	46	Yes	850
29/ 11 AM	1.0	105	104	12.8	8.1	47	Yes	850
30/ 11 AM	1.0	105	103	13.3	8.1	46	Yes	850
31/ 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012