

## OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: November 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	----	----	0.05	0.05	0.05	----	0.05
2	----	----	0.05	0.06	0.05	----	0.06
3	----	----	0.06	0.06	0.06	0.06	0.06
4	----	----	0.05	0.03	0.03	0.03	0.05
5	----	----	0.04	0.04	0.04	----	0.04
6	----	----	----	----	----	----	----
7	----	----	----	----	----	----	----
8	----	----	----	0.03	0.03	----	0.03
9	----	----	0.03	0.05	0.03	0.03	0.05
10	----	----	0.04	0.04	----	----	0.04
11	----	----	0.04	0.04	0.04	----	0.04
12	----	----	0.04	0.04	0.04	0.04	0.04
13	----	----	----	----	----	----	----
14	----	----	----	----	----	----	----
15	----	----	0.04	0.04	0.04	----	0.04
16	----	----	0.04	0.05	----	----	0.05
17	----	----	0.05	0.05	----	----	0.05
18	----	----	0.04	0.04	0.06	----	0.06
19	----	----	0.06	0.03	0.06	0.02	0.06
20	----	----	----	----	----	----	----
21	----	----	----	----	----	----	----
22	----	----	----	0.02	0.03	----	0.03
23	----	----	0.02	0.02	0.05	----	0.05
24	----	----	0.02	0.06	0.02	----	0.06
25	----	----	0.02	0.04	----	----	0.04
26	----	----	0.02	0.02	0.04	----	0.04
27	----	----	----	----	----	----	----
28	----	----	----	----	----	----	----
29	----	----	----	0.02	0.02	----	0.02
30	----	----	0.02	0.02	0.02	----	0.02
31	----	----	----	----	----	----	----

<b>Conventional or Direct Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <span style="float: right;">Yes/No</span>	CT's met everyday? (see back) Yes/No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <span style="float: right;">Yes/No</span>
All the 4 hour turbidity readings ≤ 1 NTU? <span style="float: right;">Yes/No</span>		
All turbidity readings < IFE <sup>2</sup> triggers? <span style="float: right;">Yes/No<sup>2</sup></span>		
<b>Notes:</b>	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: December 1, 2021
	PHONE #: ( 541 ) 572-2589	CERT #: 9184

<sup>1</sup> Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP:-: WTP-A Month/Year: November 2021								Required Log Inactivation: 1
Date / Time	Min. Cl <sub>2</sub> Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	0.9	105	92	13.9	7.9	40	Yes	850
2 / 11 AM	0.9	105	90	13.3	7.9	42	Yes	850
3 / 11 AM	0.9	105	96	13.3	8.0	43	Yes	850
4 / 11 AM	1.0	105	100	12.8	7.9	43	Yes	850
5 / 11 AM	0.9	105	93	13.3	7.8	40	Yes	850
6 / 11 AM	----	----	----	----	----	----	----	----
7 / 11 AM	----	----	----	----	----	----	----	----
8 / 11 AM	0.7	105	68	12.8	7.8	41	Yes	850
9 / 11 AM	0.8	105	82	13.3	7.9	42	Yes	850
10 / 11 AM	0.8	105	84	13.3	7.9	41	Yes	850
11 / 11 AM	0.9	105	91	12.8	7.9	44	Yes	850
12 / 11 AM	0.9	105	96	13.3	8.0	43	Yes	850
13 / 11 AM	----	----	----	----	----	----	----	----
14 / 11 AM	----	----	----	----	----	----	----	----
15 / 11 AM	0.7	105	77	13.3	8.0	43	Yes	850
16 / 11 AM	0.7	105	77	13.9	7.7	37	Yes	850
17 / 11 AM	0.8	105	79	12.8	7.7	40	Yes	850
18 / 11 AM	0.7	105	77	12.8	7.7	40	Yes	850
19 / 11 AM	0.8	105	85	12.8	7.9	42	Yes	850
20 / 11 AM	----	----	----	----	----	----	----	----
21 / 11 AM	----	----	----	----	----	----	----	----
22 / 11 AM	1.0	105	104	12.2	7.9	46	Yes	850
23 / 11 AM	1.1	105	112	11.7	8.4	57	Yes	850
24 / 11 AM	1.0	105	108	10.6	7.9	51	Yes	850
25 / 11 AM	1.1	105	117	10.6	8.0	53	Yes	850
26 / 11 AM	1.2	105	127	10.0	8.0	56	Yes	850
27 / 11 AM	----	----	----	----	----	----	----	----
28 / 11 AM	----	----	----	----	----	----	----	----
29 / 11 AM	1.0	105	104	12.2	7.8	44	Yes	850
30 / 11 AM	1.1	105	116	11.7	7.8	47	Yes	850
31 / 11 AM	----	----	----	----	----	----	----	----

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

*Revised February 2012*