

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: January 2022

| DAY | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 2 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 3 | ---- | ---- | 0.02 | ---- | 0.02 | 0.02 | 0.02 |
| 4 | ---- | ---- | 0.03 | 0.03 | ---- | ---- | 0.03 |
| 5 | ---- | ---- | 0.03 | 0.03 | ---- | ---- | 0.03 |
| 6 | ---- | ---- | 0.03 | 0.02 | ---- | ---- | 0.03 |
| 7 | ---- | ---- | ---- | 0.03 | 0.04 | 0.04 | 0.04 |
| 8 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 9 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 10 | ---- | ---- | ---- | 0.07 | 0.02 | ---- | 0.07 |
| 11 | ---- | ---- | 0.02 | 0.03 | 0.04 | ---- | 0.04 |
| 12 | ---- | ---- | ---- | 0.03 | 0.02 | ---- | 0.03 |
| 13 | ---- | ---- | 0.02 | 0.03 | 0.03 | ---- | 0.03 |
| 14 | ---- | ---- | ---- | 0.02 | 0.02 | 0.02 | 0.02 |
| 15 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 16 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 17 | ---- | ---- | 0.02 | ---- | ---- | ---- | 0.02 |
| 18 | ---- | ---- | ---- | 0.06 | 0.02 | ---- | 0.06 |
| 19 | ---- | ---- | 0.03 | 0.03 | 0.02 | ---- | 0.03 |
| 20 | ---- | ---- | 0.02 | 0.03 | 0.06 | ---- | 0.06 |
| 21 | ---- | ---- | ---- | 0.03 | ---- | ---- | 0.03 |
| 22 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 23 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 24 | ---- | ---- | 0.02 | 0.02 | 0.02 | ---- | 0.02 |
| 25 | ---- | ---- | 0.03 | 0.02 | 0.02 | ---- | 0.03 |
| 26 | ---- | ---- | 0.03 | 0.02 | 0.03 | ---- | 0.03 |
| 27 | ---- | ---- | 0.03 | 0.03 | ---- | ---- | 0.03 |
| 28 | ---- | ---- | 0.02 | 0.04 | 0.02 | 0.03 | 0.04 |
| 29 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 30 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 31 | ---- | ---- | ---- | 0.03 | 0.02 | ---- | 0.03 |

| | | | |
|--|---|---|--|
| Conventional or Direct Filtration | | Monthly Summary (Answer Yes or No) | |
| 95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No | CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No | All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No | |
| All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No | | | |
| All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ² | | | |
| Notes: | PRINTED NAME: <i>Ryan A. Sherman</i> | | |
| | SIGNATURE: <i>Ryan A. Sherman</i> | DATE: February 2, 2022 | |
| | PHONE #: (541) 572-2589 | CERT #: <i>9184</i> | |

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: January 2022 Required Log Inactivation: 1

| Date / Time | Min. Cl ₂ Residual At 1 st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|--|--------------------|--------------|-------|------|-------------|----------------------|-------------------------|
| | [ppm or mg/l] | [minutes] | C x T | [° C] | S.U. | Formula | Yes / No | [GPM] |
| 1 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 2 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 3 / 11 AM | 0.9 | 105 | 96 | 8.3 | 8.1 | 64 | Yes | 850 |
| 4 / 11 AM | 0.8 | 105 | 84 | 8.9 | 8.1 | 59 | Yes | 850 |
| 5 / 11 AM | 1.0 | 105 | 100 | 9.4 | 8.0 | 57 | Yes | 850 |
| 6 / 11 AM | 1.2 | 105 | 124 | 9.4 | 8.1 | 60 | Yes | 850 |
| 7 / 11 AM | 1.3 | 105 | 135 | 9.4 | 8.1 | 60 | Yes | 850 |
| 8 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 9 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 10 / 11 AM | 0.9 | 105 | 92 | 10.6 | 8.0 | 53 | Yes | 850 |
| 11 / 11 AM | 1.0 | 105 | 101 | 10.6 | 8.1 | 54 | Yes | 850 |
| 12 / 11 AM | 1.1 | 105 | 113 | 10.6 | 8.1 | 55 | Yes | 850 |
| 13 / 11 AM | 1.2 | 105 | 125 | 10.6 | 8.1 | 56 | Yes | 850 |
| 14 / 11 AM | 1.2 | 105 | 127 | 11.1 | 8.2 | 55 | Yes | 850 |
| 15 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 16 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 17 / 11 AM | 0.9 | 105 | 89 | 11.1 | 8.1 | 51 | Yes | 850 |
| 18 / 11 AM | 0.9 | 105 | 96 | 11.1 | 8.3 | 56 | Yes | 850 |
| 19 / 11 AM | 1.1 | 105 | 111 | 11.7 | 8.1 | 50 | Yes | 850 |
| 20 / 11 AM | 1.1 | 105 | 117 | 11.7 | 8.0 | 50 | Yes | 850 |
| 21 / 11 AM | 1.3 | 105 | 137 | 11.7 | 8.1 | 52 | Yes | 850 |
| 22 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 23 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 24 / 11 AM | 0.9 | 105 | 91 | 12.2 | 8.1 | 48 | Yes | 850 |
| 25 / 11 AM | 1.0 | 105 | 103 | 12.8 | 8.1 | 47 | Yes | 850 |
| 26 / 11 AM | 1.1 | 105 | 113 | 11.7 | 8.2 | 53 | Yes | 850 |
| 27 / 11 AM | 1.1 | 105 | 119 | 11.1 | 8.1 | 53 | Yes | 850 |
| 28 / 11 AM | 1.1 | 105 | 116 | 10.0 | 8.0 | 55 | Yes | 850 |
| 29 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 30 / 11 AM | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| 31 / 11 AM | 1.1 | 105 | 111 | 8.9 | 8.0 | 60 | Yes | 850 |

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012