

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: June 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	---	---	0.03	0.06	0.03	---	0.06
2	---	---	0.03	0.03	0.03	---	0.03
3	---	---	---	0.03	---	---	0.03
4	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---
6	---	---	0.04	0.03	0.03	---	0.04
7	---	---	---	0.03	0.03	---	0.03
8	---	---	0.03	0.03	---	---	0.03
9	---	---	0.03	---	---	---	0.03
10	---	---	---	0.03	---	---	0.03
11	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---
13	---	---	0.04	0.03	0.03	---	0.04
14	---	---	0.03	0.04	---	---	0.04
15	---	---	---	---	---	---	---
16	---	---	0.04	0.03	0.05	---	0.05
17	---	---	0.06	0.03	0.04	---	0.06
18	---	---	---	---	---	---	---
19	---	---	---	---	---	---	---
20	---	---	0.03	0.03	---	---	0.03
21	---	---	0.03	0.03	---	---	0.03
22	---	---	---	0.04	---	---	0.04
23	---	---	0.04	0.03	---	---	0.04
24	---	---	0.04	0.04	0.04	---	0.04
25	---	---	---	---	---	---	---
26	---	---	---	---	---	---	---
27	---	---	0.05	0.04	0.04	---	0.05
28	---	---	0.04	0.04	0.04	---	0.04
29	---	---	0.04	0.03	---	---	0.04
30	---	---	0.04	0.04	---	---	0.04
31	---	---	---	---	---	---	---

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4 hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ²		
Notes:	PRINTED NAME: <u>Ryan A. Sherman</u>	
	SIGNATURE: <u>Ryan A. Sherman</u>	DATE: July 4, 2022
	PHONE #: (541) 572-2589	CERT #: <u>9184</u>

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: June 2022								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	105	117	16.1	7.9	36	Yes	1200
2 / 11 AM	0.7	105	68	16.7	7.8	31	Yes	1200
3 / 11 AM	0.7	105	68	15.0	7.8	35	Yes	1200
4 / 11 AM	----	----	----	----	----	----	----	----
5 / 11 AM	----	----	----	----	----	----	----	----
6 / 11 AM	1.1	105	118	16.1	7.6	32	Yes	1200
7 / 11 AM	1.2	105	125	16.1	7.7	33	Yes	1200
8 / 11 AM	1.2	105	126	16.7	7.8	33	Yes	1200
9 / 11 AM	1.2	105	127	17.2	7.9	33	Yes	1200
10 / 11 AM	1.1	105	116	17.8	7.9	32	Yes	1200
11 / 11 AM	----	----	----	----	----	----	----	----
12 / 11 AM	----	----	----	----	----	----	----	----
13 / 11 AM	1.2	105	123	15.0	8.0	40	Yes	1200
14 / 11 AM	1.1	105	116	15.6	8.0	38	Yes	1200
15 / 11 AM	----	----	----	----	----	----	----	----
16 / 11 AM	1.1	105	111	18.9	8.1	32	Yes	1200
17 / 11 AM	1.1	105	119	19.4	8.1	31	Yes	1200
18 / 11 AM	----	----	----	----	----	----	----	----
19 / 11 AM	----	----	----	----	----	----	----	----
20 / 11 AM	0.9	105	98	19.4	7.6	25	Yes	1200
21 / 11 AM	1.0	105	108	19.4	7.7	26	Yes	1200
22 / 11 AM	1.0	105	105	19.4	8.0	30	Yes	1200
23 / 11 AM	1.1	105	110	20.0	8.1	29	Yes	1200
24 / 11 AM	1.2	105	123	19.4	8.0	30	Yes	1200
25 / 11 AM	----	----	----	----	----	----	----	----
26 / 11 AM	----	----	----	----	----	----	----	----
27 / 11 AM	1.2	105	122	18.3	8.0	32	Yes	1200
28 / 11 AM	1.2	105	124	20.6	8.0	27	Yes	1200
29 / 11 AM	1.2	105	123	17.8	8.0	34	Yes	1200
30 / 11 AM	1.1	105	120	18.9	8.2	33	Yes	1200
31 / 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012