

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP.:WTP-A Month/Year: July 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	0.04	0.04	----	----	0.04
2	----	----	----	----	----	----	----
3	----	----	----	----	----	----	----
4	----	----	----	0.04	----	----	0.04
5	----	----	0.05	0.04	0.04	----	0.05
6	----	----	0.04	0.04	----	----	0.04
7	----	----	0.04	----	----	----	0.04
8	----	----	0.04	0.04	----	----	0.04
9	----	----	----	----	----	----	----
10	----	----	----	----	----	----	----
11	----	----	0.05	0.04	0.04	----	0.05
12	----	----	0.04	0.04	0.04	----	0.04
13	----	----	----	----	----	----	----
14	----	----	0.05	0.05	0.05	----	0.05
15	----	----	----	0.04	0.05	----	0.05
16	----	----	----	----	----	----	----
17	----	----	----	----	----	----	----
18	----	----	----	0.04	0.03	----	0.04
19	----	----	0.03	0.03	0.03	----	0.03
20	----	----	0.03	0.03	----	----	0.03
21	----	----	0.03	----	----	----	0.03
22	----	----	0.03	----	0.03	----	0.03
23	----	----	----	----	----	----	----
24	----	----	----	----	----	----	----
25	----	----	0.04	0.03	0.03	----	0.04
26	----	----	0.03	0.03	0.03	----	0.03
27	----	----	0.03	0.03	0.04	----	0.04
28	----	----	----	0.03	0.03	----	0.03
29	----	----	0.03	0.03	----	----	0.03
30	----	----	----	----	----	----	----
31	----	----	----	----	----	----	----

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ²		
Notes:	PRINTED NAME: <u>Ryan A. Sherman</u>	
	SIGNATURE: <u>[Signature]</u>	DATE: August 1, 2022
	PHONE #: (541) 572-2589	CERT #: <u>9184</u>

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: July 2022								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	105	113	18.9	8.1	31	Yes	1200
2 / 11 AM	----	----	----	----	----	----	----	----
3 / 11 AM	----	----	----	----	----	----	----	----
4 / 11 AM	0.8	105	87	19.4	8.1	30	Yes	1200
5 / 11 AM	1.0	105	108	20.6	8.1	28	Yes	1200
6 / 11 AM	1.1	105	113	18.3	8.0	32	Yes	1200
7 / 11 AM	1.1	105	113	19.4	8.1	30	Yes	1200
8 / 11 AM	1.1	105	110	20.0	8.1	29	Yes	1200
9 / 11 AM	----	----	----	----	----	----	----	----
10 / 11 AM	----	----	----	----	----	----	----	----
11 / 11 AM	1.0	105	105	20.6	8.1	29	Yes	1200
12 / 11 AM	1.1	105	111	21.1	8.2	28	Yes	1200
13 / 11 AM	----	----	----	----	----	----	----	----
14 / 11 AM	1.1	105	117	21.7	8.3	28	Yes	1200
15 / 11 AM	0.9	105	91	22.2	8.2	26	Yes	1200
16 / 11 AM	----	----	----	----	----	----	----	----
17 / 11 AM	----	----	----	----	----	----	----	----
18 / 11 AM	0.9	105	93	22.2	7.9	23	Yes	1200
19 / 11 AM	0.9	105	90	22.2	8.0	24	Yes	1200
20 / 11 AM	0.8	105	88	22.2	8.1	24	Yes	1200
21 / 11 AM	0.9	105	91	22.2	8.1	25	Yes	1200
22 / 11 AM	0.9	105	89	22.8	8.1	24	Yes	1200
23 / 11 AM	----	----	----	----	----	----	----	----
24 / 11 AM	----	----	----	----	----	----	----	----
25 / 11 AM	0.8	105	87	23.3	8.0	22	Yes	1200
26 / 11 AM	0.9	105	99	23.3	7.9	21	Yes	1200
27 / 11 AM	1.0	105	106	23.3	7.9	22	Yes	1200
28 / 11 AM	1.0	105	105	23.9	8.0	22	Yes	1200
29 / 11 AM	1.1	105	110	23.3	8.1	24	Yes	1200
30 / 11 AM	----	----	----	----	----	----	----	----
31 / 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012