

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: **October 2022**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	----	----	----	----	----
2	----	----	----	----	----	----	----
3	----	----	----	0.03	0.03	----	0.03
4	----	----	0.03	0.03	----	----	0.03
5	----	----	0.03	0.03	----	----	0.03
6	----	----	0.03	0.03	0.03	----	0.03
7	----	----	0.03	0.03	----	----	0.03
8	----	----	----	----	----	----	----
9	----	----	----	----	----	----	----
10	----	----	0.03	0.03	----	----	0.03
11	----	----	0.03	0.03	----	----	0.03
12	----	----	0.03	0.03	----	----	0.03
13	----	----	0.03	0.03	----	----	0.03
14	----	----	0.03	0.03	----	----	0.03
15	----	----	----	----	----	----	----
16	----	----	----	----	----	----	----
17	----	----	0.03	0.03	0.03	----	0.03
18	----	----	0.03	0.03	0.03	----	0.03
19	----	----	0.03	0.03	----	----	0.03
20	----	----	0.03	----	----	----	0.03
21	----	----	0.03	----	----	----	0.03
22	----	----	----	----	----	----	----
23	----	----	----	----	----	----	----
24	----	----	0.03	0.03	0.03	----	0.03
25	----	----	0.03	0.03	0.02	----	0.03
26	----	----	0.03	0.03	0.03	----	0.03
27	----	----	0.03	0.03	0.03	----	0.03
28	----	----	0.05	0.03	0.03	----	0.05
29	----	----	----	----	----	----	----
30	----	----	----	----	----	----	----
31	----	----	0.04	0.03	0.03	----	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No	
All the 4 hour turbidity readings ≤ 1 NTU? Yes/No			
All turbidity readings < IFE ² triggers? Yes/No ²			
Notes:	PRINTED NAME: Ryan A. Sherman		DATE: November 1, 2022
	SIGNATURE: <i>Ryan A. Sherman</i>		CERT #: 9184
	PHONE #: (541) 572-2589		

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: October 2022								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	----	----	----	----	----	----	----	----
2 / 11 AM	----	----	----	----	----	----	----	----
3 / 11 AM	0.9	105	99	18.3	8.1	32	Yes	1200
4 / 11 AM	1.0	105	103	17.8	8.0	33	Yes	1200
5 / 11 AM	1.0	105	108	17.8	8.0	33	Yes	1200
6 / 11 AM	1.1	105	117	17.8	8.1	34	Yes	1200
7 / 11 AM	1.0	105	101	17.8	7.9	31	Yes	1200
8 / 11 AM	----	----	----	----	----	----	----	----
9 / 11 AM	----	----	----	----	----	----	----	----
10 / 11 AM	0.9	105	96	17.2	8.0	34	Yes	1200
11 / 11 AM	1.0	105	105	17.2	8.0	34	Yes	1200
12 / 11 AM	1.0	105	109	16.7	8.1	36	Yes	1200
13 / 11 AM	1.1	105	111	16.7	8.1	37	Yes	1200
14 / 11 AM	1.1	105	113	16.7	8.1	37	Yes	1200
15 / 11 AM	----	----	----	----	----	----	----	----
16 / 11 AM	----	----	----	----	----	----	----	----
17 / 11 AM	0.8	105	85	16.1	8.1	37	Yes	1200
18 / 11 AM	0.9	105	98	16.7	8.0	35	Yes	1200
19 / 11 AM	1.0	105	101	16.7	8.0	36	Yes	1200
20 / 11 AM	1.0	105	100	16.1	7.9	35	Yes	1200
21 / 11 AM	1.0	105	103	16.1	7.9	36	Yes	1200
22 / 11 AM	----	----	----	----	----	----	----	----
23 / 11 AM	----	----	----	----	----	----	----	----
24 / 11 AM	0.9	105	99	15.6	8.0	38	Yes	1200
25 / 11 AM	1.0	105	106	15.6	8.1	39	Yes	1200
26 / 11 AM	1.0	105	106	15.6	8.0	38	Yes	1200
27 / 11 AM	1.2	105	121	15.6	8.1	40	Yes	1200
28 / 11 AM	1.2	105	124	15.6	8.1	41	Yes	1200
29 / 11 AM	----	----	----	----	----	----	----	----
30 / 11 AM	----	----	----	----	----	----	----	----
31 / 11 AM	0.9	105	91	15.0	8.1	40	Yes	1200

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012