

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: November 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	0.03	0.03	0.04	----	0.04
2	----	----	----	0.03	0.03	----	0.03
3	----	----	0.03	0.03	0.03	----	0.03
4	----	----	0.03	0.03	----	----	0.03
5	----	----	----	----	----	----	----
6	----	----	----	----	----	----	----
7	----	----	0.04	0.03	0.03	----	0.04
8	----	----	0.03	0.03	0.04	----	0.04
9	----	----	0.04	0.03	0.03	----	0.04
10	----	----	0.03	0.03	0.03	----	0.03
11	----	----	0.06	0.03	0.03	----	0.06
12	----	----	----	----	----	----	----
13	----	----	----	----	----	----	----
14	----	----	0.03	0.03	0.03	0.03	0.03
15	----	----	0.04	0.05	0.04	0.04	0.05
16	----	----	0.03	0.03	0.03	0.03	0.03
17	----	----	----	0.03	0.03	----	0.03
18	----	----	0.03	0.05	0.06	0.03	0.06
19	----	----	----	----	----	----	----
20	----	----	----	----	----	----	----
21	----	----	0.03	0.03	0.03	----	0.03
22	----	----	0.03	0.06	0.03	----	0.06
23	----	----	0.03	0.03	0.03	----	0.03
24	----	----	0.03	0.02	----	----	0.03
25	----	----	0.03	0.03	0.03	----	0.03
26	----	----	----	----	----	----	----
27	----	----	----	----	----	----	----
28	----	----	0.05	0.02	0.02	----	0.05
29	----	----	0.02	0.02	0.02	----	0.02
30	----	----	0.03	0.04	0.04	----	0.04
31	----	----	----	----	----	----	----

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes <input type="radio"/> No ²		
Notes:	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. S.</i>	DATE: December 2, 2022
	PHONE #: (541) 572-2589	CERT #: 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: November 2022								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	0.9	105	96	16.1	8.1	37	Yes	850
2 / 11 AM	1.0	105	100	13.9	8.0	41	Yes	850
3 / 11 AM	1.0	105	103	13.3	8.0	44	Yes	850
4 / 11 AM	1.0	105	108	13.3	8.0	44	Yes	850
5 / 11 AM	----	----	----	----	----	----	----	----
6 / 11 AM	----	----	----	----	----	----	----	----
7 / 11 AM	0.9	105	96	13.9	7.8	39	Yes	850
8 / 11 AM	1.0	105	106	13.3	7.9	42	Yes	850
9 / 11 AM	1.0	105	106	12.2	8.4	54	Yes	850
10 / 11 AM	1.1	105	114	11.7	8.3	55	Yes	850
11 / 11 AM	1.2	105	122	11.7	8.4	58	Yes	850
12 / 11 AM	----	----	----	----	----	----	----	----
13 / 11 AM	----	----	----	----	----	----	----	----
14 / 11 AM	1.0	105	101	11.1	8.4	58	Yes	850
15 / 11 AM	1.1	105	111	11.1	8.4	60	Yes	850
16 / 11 AM	1.2	105	123	10.6	8.4	62	Yes	850
17 / 11 AM	1.2	105	125	10.0	8.4	66	Yes	850
18 / 11 AM	1.3	105	137	10.0	8.4	65	Yes	850
19 / 11 AM	----	----	----	----	----	----	----	----
20 / 11 AM	----	----	----	----	----	----	----	----
21 / 11 AM	1.3	105	135	10.0	8.3	64	Yes	850
22 / 11 AM	1.3	105	140	9.4	8.3	65	Yes	850
23 / 11 AM	1.4	105	143	9.4	8.3	66	Yes	850
24 / 11 AM	1.3	105	135	9.4	8.2	64	Yes	850
25 / 11 AM	1.3	105	137	8.9	8.3	68	Yes	850
26 / 11 AM	----	----	----	----	----	----	----	----
27 / 11 AM	----	----	----	----	----	----	----	----
28 / 11 AM	1.3	105	138	8.3	8.1	65	Yes	850
29 / 11 AM	1.4	105	147	7.8	8.2	71	Yes	850
30 / 11 AM	1.5	105	160	7.8	8.2	73	Yes	850
31 / 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012