

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: January 2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	----	----	----	----	----
2	----	----	0.03	0.02	0.02	----	0.03
3	----	----	----	0.02	0.02	----	0.02
4	----	----	0.02	0.02	0.02	----	0.02
5	----	----	0.02	0.02	0.02	----	0.02
6	----	----	0.02	0.02	0.02	----	0.02
7	----	----	----	----	----	----	----
8	----	----	----	----	----	----	----
9	----	----	0.03	0.03	0.02	----	0.03
10	----	----	0.03	0.04	0.04	----	0.04
11	----	----	0.03	0.02	0.02	----	0.03
12	----	----	0.02	0.02	0.02	----	0.02
13	----	----	0.02	0.03	0.02	----	0.03
14	----	----	----	----	----	----	----
15	----	----	----	----	----	----	----
16	----	----	0.03	0.03	0.04	----	0.04
17	----	----	0.03	0.03	0.03	----	0.03
18	----	----	0.02	0.02	0.02	----	0.02
19	----	----	0.03	0.03	0.03	----	0.03
20	----	----	0.05	0.02	0.03	----	0.05
21	----	----	----	----	----	----	----
22	----	----	----	----	----	----	----
23	----	----	0.03	0.03	0.02	----	0.03
24	----	----	0.02	0.02	0.02	----	0.02
25	----	----	0.03	0.03	0.03	----	0.03
26	----	----	----	0.03	0.02	0.02	0.03
27	----	----	0.02	0.02	----	----	0.02
28	----	----	----	----	----	----	----
29	----	----	----	----	----	----	----
30	----	----	0.03	0.02	0.02	----	0.03
31	----	----	0.03	0.03	0.03	----	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / No ²		
Notes:	PRINTED NAME: <i>RYAN A. SHEPHERD</i>	
	SIGNATURE: <i>Ryan A. S.</i>	DATE: February 1, 2023
	PHONE #: (541) 572-2589	CERT #: 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: January 2023

Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	----	----	----	----	----	----	----	----
2 / 11 AM	0.9	105	97	7.2	8.1	67	Yes	850
3 / 11 AM	1.0	105	102	7.8	8.1	66	Yes	850
4 / 11 AM	1.0	105	104	8.3	8.1	64	Yes	850
5 / 11 AM	1.1	105	111	7.8	8.1	66	Yes	850
6 / 11 AM	1.0	105	109	8.3	8.1	64	Yes	850
7 / 11 AM	----	----	----	----	----	----	----	----
8 / 11 AM	----	----	----	----	----	----	----	----
9 / 11 AM	1.2	105	121	9.4	8.0	58	Yes	850
10 / 11 AM	1.2	105	122	8.9	8.1	62	Yes	850
11 / 11 AM	1.2	105	128	8.9	8.1	63	Yes	850
12 / 11 AM	1.3	105	138	9.4	8.2	62	Yes	850
13 / 11 AM	1.3	105	132	10.0	8.0	57	Yes	850
14 / 11 AM	----	----	----	----	----	----	----	----
15 / 11 AM	----	----	----	----	----	----	----	----
16 / 11 AM	1.0	105	106	11.1	7.9	49	Yes	850
17 / 11 AM	1.0	105	105	11.1	7.7	46	Yes	850
18 / 11 AM	1.1	105	111	11.7	7.8	46	Yes	850
19 / 11 AM	1.1	105	114	11.1	7.8	49	Yes	850
20 / 11 AM	1.1	105	119	11.1	7.9	50	Yes	850
21 / 11 AM	----	----	----	----	----	----	----	----
22 / 11 AM	----	----	----	----	----	----	----	----
23 / 11 AM	1.0	105	108	8.3	8.0	61	Yes	850
24 / 11 AM	1.1	105	116	8.9	8.0	60	Yes	850
25 / 11 AM	1.1	105	118	8.9	8.1	62	Yes	850
26 / 11 AM	1.2	105	125	8.3	8.1	65	Yes	850
27 / 11 AM	1.2	105	127	8.3	8.1	66	Yes	850
28 / 11 AM	----	----	----	----	----	----	----	----
29 / 11 AM	----	----	----	----	----	----	----	----
30 / 11 AM	1.2	105	128	7.8	8.2	70	Yes	850
31 / 11 AM	1.4	105	142	7.2	8.2	74	Yes	850

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012