

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: 2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	0.03	0.03	0.03	----	0.03
2	----	----	----	0.04	0.03	----	0.04
3	----	----	0.04	0.04	0.04	----	0.04
4	----	----	----	----	----	----	----
5	----	----	----	----	----	----	----
6	----	----	0.04	0.04	0.03	----	0.04
7	----	----	0.04	0.04	0.04	----	0.04
8	----	----	----	0.03	0.03	----	0.03
9	----	----	0.03	0.03	0.03	----	0.03
10	----	----	0.03	0.03	0.03	----	0.03
11	----	----	----	----	----	----	----
12	----	----	----	----	----	----	----
13	----	----	0.03	0.03	0.03	----	0.03
14	----	----	0.03	0.05	0.04	----	0.05
15	----	----	0.03	0.03	0.03	----	0.03
16	----	----	0.03	0.03	0.03	----	0.03
17	----	----	0.03	0.03	0.03	----	0.03
18	----	----	----	----	----	----	----
19	----	----	----	----	----	----	----
20	----	----	----	0.03	0.03	----	0.03
21	----	----	0.03	0.03	0.03	----	0.03
22	----	----	0.03	0.03	0.03	----	0.03
23	----	----	0.03	0.03	0.03	----	0.03
24	----	----	0.04	0.03	0.04	----	0.04
25	----	----	----	----	----	----	----
26	----	----	----	----	----	----	----
27	----	----	0.03	0.03	0.02	----	0.03
28	----	----	0.02	0.02	0.02	----	0.02
29	----	----	0.02	0.02	0.02	----	0.02
30	----	----	0.02	0.02	0.02	----	0.02
31	----	----	0.02	0.02	0.02	----	0.02

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4 hour turbidity readings ≤ 1 NTU?			
All turbidity readings < IFE ² triggers?			
Notes:		PRINTED NAME: RYAN A. SHERMAN	DATE: April 3, 2023
		SIGNATURE: <i>Ryan A. Sherman</i>	CERT #: 9184
		PHONE #: (541) 572-2589	

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP:- WTP-A Month/Year: 2023 Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.0	105	105	8.9	7.9	57	Yes	850
2 / 11 AM	1.1	105	114	9.4	8.0	58	Yes	850
3 / 11 AM	1.2	105	122	8.9	8.1	62	Yes	850
4 / 11 AM	----	----	----	----	----	----	----	----
5 / 11 AM	----	----	----	----	----	----	----	----
6 / 11 AM	1.1	105	114	7.8	7.9	62	Yes	850
7 / 11 AM	1.2	105	122	7.8	7.9	63	Yes	850
8 / 11 AM	1.2	105	126	7.2	8.0	69	Yes	850
9 / 11 AM	1.2	105	122	7.8	8.0	65	Yes	850
10 / 11 AM	1.2	105	124	7.8	8.0	66	Yes	850
11 / 11 AM	----	----	----	----	----	----	----	----
12 / 11 AM	----	----	----	----	----	----	----	----
13 / 11 AM	1.1	105	120	8.3	8.1	65	Yes	850
14 / 11 AM	1.2	105	126	7.8	8.2	71	Yes	850
15 / 11 AM	1.2	105	127	8.9	8.2	66	Yes	850
16 / 11 AM	1.1	105	118	8.3	8.1	64	Yes	850
17 / 11 AM	1.2	105	123	8.9	8.1	63	Yes	850
18 / 11 AM	----	----	----	----	----	----	----	----
19 / 11 AM	----	----	----	----	----	----	----	----
20 / 11 AM	1.1	105	112	9.4	8.1	59	Yes	850
21 / 11 AM	1.1	105	114	9.4	8.1	60	Yes	850
22 / 11 AM	1.1	105	120	9.4	7.8	54	Yes	850
23 / 11 AM	1.2	105	128	9.4	8.0	57	Yes	850
24 / 11 AM	1.3	105	133	9.4	8.0	59	Yes	850
25 / 11 AM	----	----	----	----	----	----	----	----
26 / 11 AM	----	----	----	----	----	----	----	----
27 / 11 AM	1.1	105	119	10.0	8.0	56	Yes	850
28 / 11 AM	1.2	105	123	10.0	7.9	53	Yes	850
29 / 11 AM	1.2	105	125	10.0	7.9	54	Yes	850
30 / 11 AM	1.2	105	127	10.0	8.0	55	Yes	850
31 / 11 AM	1.2	105	128	10.6	8.0	54	Yes	850

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012