

## OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: Septiembre 2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	----	----	0.03	0.03	----	----	0.03
2	----	----	----	----	----	----	----
3	----	----	----	----	----	----	----
4	----	----	----	0.03	0.03	----	0.03
5	----	----	0.03	0.03	0.03	----	0.03
6	----	----	0.03	0.03	0.03	----	0.03
7	----	----	0.03	0.03	0.03	----	0.03
8	----	----	0.05	0.04	----	----	0.05
9	----	----	----	----	----	----	----
10	----	----	----	----	----	----	----
11	----	----	----	0.04	0.04	----	0.04
12	----	----	0.03	0.02	0.02	----	0.03
13	----	----	----	----	----	----	----
14	----	----	0.02	0.02	0.01	----	0.02
15	----	----	0.02	0.01	0.01	----	0.02
16	----	----	----	----	----	----	----
17	----	----	----	----	----	----	----
18	----	----	----	0.02	0.01	----	0.02
19	----	----	0.02	0.01	----	----	0.02
20	----	----	0.03	0.01	----	----	0.03
21	----	----	0.03	0.01	----	----	0.03
22	----	----	0.03	0.01	----	----	0.03
23	----	----	----	----	----	----	----
24	----	----	----	----	----	----	----
25	----	----	----	0.02	0.02	----	0.02
26	----	----	0.03	0.02	0.02	----	0.03
27	----	----	0.03	0.03	----	----	0.03
28	----	----	0.03	----	----	----	0.03
29	----	----	0.05	----	----	----	0.05
30	----	----	----	----	----	----	----
31	----	----	----	----	----	----	----

<b>Conventional or Direct Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <span style="float: right;">Yes No</span>	CT's met everyday? <small>(see back)</small> Yes/No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes/No
All the 4 hour turbidity readings ≤ 1 NTU? <span style="float: right;">Yes/ No</span>		
All turbidity readings < IFE <sup>2</sup> triggers? <span style="float: right;">Yes/ No<sup>2</sup></span>		
<b>Notes:</b>	PRINTED NAME: <i>Ryan D. Sherman</i>	
	SIGNATURE: <i>Ryan D. Sherman</i>	DATE: October 2, 2023
	PHONE #: ( 541 ) 572-2589	CERT #: 91841

<sup>1</sup> Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

**MYRTLE POINT, CITY OF ID #: OR4100551 WTP:- WTP-A Month/Year: Septiembre 2023**

Required Log Inactivation: 1

Date / Time	Min. Cl <sub>2</sub> Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.3	105	132	21.7	8.0	26	Yes	1200
2 / 11 AM	----	----	----	----	----	----	----	----
3 / 11 AM	----	----	----	----	----	----	----	----
4 / 11 AM	0.9	105	96	21.7	7.9	24	Yes	1200
5 / 11 AM	1.1	105	112	21.7	7.7	23	Yes	1200
6 / 11 AM	1.2	105	124	21.1	7.8	24	Yes	1200
7 / 11 AM	1.3	105	131	21.1	7.9	26	Yes	1200
8 / 11 AM	1.3	105	135	21.1	7.9	26	Yes	1200
9 / 11 AM	----	----	----	----	----	----	----	----
10 / 11 AM	----	----	----	----	----	----	----	----
11 / 11 AM	1.0	105	107	20.6	8.0	27	Yes	1200
12 / 11 AM	1.0	105	104	20.0	8.0	28	Yes	1200
13 / 11 AM	----	----	----	----	----	----	----	----
14 / 11 AM	1.0	105	109	20.0	7.9	27	Yes	1200
15 / 11 AM	1.2	105	126	20.0	7.9	28	Yes	1200
16 / 11 AM	----	----	----	----	----	----	----	----
17 / 11 AM	----	----	----	----	----	----	----	----
18 / 11 AM	1.0	105	106	20.0	7.9	27	Yes	1200
19 / 11 AM	1.1	105	112	19.4	7.9	29	Yes	1200
20 / 11 AM	1.2	105	122	18.9	8.0	31	Yes	1200
21 / 11 AM	1.2	105	126	18.3	8.0	32	Yes	1200
22 / 11 AM	1.2	105	128	18.9	8.0	31	Yes	1200
23 / 11 AM	----	----	----	----	----	----	----	----
24 / 11 AM	----	----	----	----	----	----	----	----
25 / 11 AM	0.9	105	98	18.3	8.1	32	Yes	1200
26 / 11 AM	1.0	105	108	17.8	8.1	34	Yes	1200
27 / 11 AM	1.0	105	109	17.2	8.2	37	Yes	1200
28 / 11 AM	1.1	105	116	17.8	8.1	34	Yes	1200
29 / 11 AM	0.9	105	95	16.7	8.0	35	Yes	1200
30 / 11 AM	----	----	----	----	----	----	----	----
31 / 11 AM	----	----	----	----	----	----	----	----

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012