

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP.:WTP-A Month/Year: 2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	---	---	---	---	---	---	---
2	---	---	---	0.06	0.06	---	0.06
3	---	---	0.05	0.04	0.03	---	0.05
4	---	---	0.03	0.03	0.03	---	0.03
5	---	---	0.03	0.02	0.03	---	0.03
6	---	---	0.03	0.02	---	---	0.03
7	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---
9	---	---	---	0.02	0.02	---	0.02
10	---	---	0.02	0.02	---	---	0.02
11	---	---	0.02	0.02	0.02	---	0.02
12	---	---	0.03	---	0.02	---	0.03
13	---	---	---	0.02	---	---	0.02
14	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---
16	---	---	---	0.02	0.02	---	0.02
17	---	---	0.02	0.02	---	---	0.02
18	---	---	---	0.02	---	---	0.02
19	---	---	0.02	0.02	---	---	0.02
20	---	---	0.02	---	---	---	0.02
21	---	---	---	---	---	---	---
22	---	---	---	---	---	---	---
23	---	---	---	0.02	0.02	---	0.02
24	---	---	0.02	0.02	0.02	---	0.02
25	---	---	0.04	0.02	0.02	---	0.04
26	---	---	0.02	0.02	0.02	---	0.02
27	---	---	0.02	0.02	---	---	0.02
28	---	---	---	---	---	---	---
29	---	---	---	---	---	---	---
30	---	---	0.02	---	0.04	---	0.04
31	---	---	0.02	0.02	0.03	---	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ²		
Notes:	PRINTED NAME: <i>RYAN A. SHERMAN</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: November 1, 2023
	PHONE #: (541) 572-2589	CERT #: 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: 2023								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1/ 11 AM	----	----	----	----	----	----	----	----
2/ 11 AM	0.8	105	84	16.7	8.0	34	Yes	850
3/ 11 AM	0.9	105	98	17.2	8.1	35	Yes	850
4/ 11 AM	1.0	105	102	17.2	7.6	29	Yes	850
5/ 11 AM	0.7	105	72	17.8	8.1	33	Yes	850
6/ 11 AM	0.9	105	92	17.8	7.7	29	Yes	850
7/ 11 AM	----	----	----	----	----	----	----	----
8/ 11 AM	----	----	----	----	----	----	----	----
9/ 11 AM	0.6	105	65	17.2	7.8	30	Yes	850
10/ 11 AM	0.7	105	77	16.7	8.0	34	Yes	850
11/ 11 AM	0.7	105	77	16.7	7.9	33	Yes	850
12/ 11 AM	0.7	105	78	16.7	8.4	39	Yes	850
13/ 11 AM	0.7	105	70	16.1	8.4	41	Yes	850
14/ 11 AM	----	----	----	----	----	----	----	----
15/ 11 AM	----	----	----	----	----	----	----	----
16/ 11 AM	0.6	105	66	16.7	8.4	39	Yes	850
17/ 11 AM	0.8	105	81	16.7	8.4	39	Yes	850
18/ 11 AM	0.7	105	78	15.6	8.0	37	Yes	850
19/ 11 AM	0.8	105	83	16.1	8.5	42	Yes	850
20/ 11 AM	0.8	105	81	15.6	8.4	43	Yes	850
21/ 11 AM	----	----	----	----	----	----	----	----
22/ 11 AM	----	----	----	----	----	----	----	----
23/ 11 AM	0.6	105	63	17.8	8.2	33	Yes	850
24/ 11 AM	0.6	105	63	17.2	8.1	33	Yes	850
25/ 11 AM	0.8	105	79	15.6	8.2	39	Yes	850
26/ 11 AM	0.9	105	93	15.0	8.0	39	Yes	850
27/ 11 AM	1.0	105	105	15.0	8.2	42	Yes	850
28/ 11 AM	----	----	----	----	----	----	----	----
29/ 11 AM	----	----	----	----	----	----	----	----
30/ 11 AM	0.7	105	71	14.4	8.1	41	Yes	850
31/ 11 AM	0.9	105	91	13.9	8.0	42	Yes	850

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012