

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: 2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	---	---	---	0.03	0.03	---	0.03
2	---	---	0.03	0.03	0.02	---	0.03
3	---	---	0.02	0.03	---	---	0.03
4	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---
6	---	---	---	0.03	0.02	---	0.03
7	---	---	0.03	0.02	0.03	---	0.03
8	---	---	0.04	0.05	0.03	---	0.05
9	---	---	0.03	0.03	0.03	---	0.03
10	---	---	0.03	0.03	0.03	---	0.03
11	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---
13	---	---	0.03	0.04	0.03	---	0.04
14	---	---	---	0.03	0.03	---	0.03
15	---	---	0.03	0.03	0.03	---	0.03
16	---	---	---	0.03	0.03	---	0.03
17	---	---	0.03	0.03	0.03	---	0.03
18	---	---	---	---	---	---	---
19	---	---	---	---	---	---	---
20	---	---	---	0.03	0.03	---	0.03
21	---	---	0.03	0.03	0.03	---	0.03
22	---	---	0.03	0.03	0.03	---	0.03
23	---	---	0.04	0.04	0.04	---	0.04
24	---	---	---	0.03	0.04	---	0.04
25	---	---	---	---	---	---	---
26	---	---	---	---	---	---	---
27	---	---	---	0.05	0.03	---	0.05
28	---	---	0.03	0.03	0.03	---	0.03
29	---	---	0.03	0.03	0.03	---	0.03
30	---	---	0.03	0.03	0.03	---	0.03
31	---	---	---	---	---	---	---

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / No ²		
Notes:	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: December 1, 2023
	PHONE #: (541) 572-2589	CERT #: 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP:- WTP-A Month/Year: 2023 Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	0.8	105	88	16.1	8.0	37	Yes	850
2 / 11 AM	0.9	105	93	14.4	8.0	41	Yes	850
3 / 11 AM	1.0	105	102	14.4	8.2	43	Yes	850
4 / 11 AM	----	----	----	----	----	----	----	----
5 / 11 AM	----	----	----	----	----	----	----	----
6 / 11 AM	0.9	105	90	14.4	8.3	45	Yes	850
7 / 11 AM	0.9	105	96	14.4	8.3	45	Yes	850
8 / 11 AM	1.0	105	101	13.9	8.4	48	Yes	850
9 / 11 AM	1.0	105	109	13.9	8.1	45	Yes	850
10 / 11 AM	1.1	105	116	13.3	8.2	48	Yes	850
11 / 11 AM	----	----	----	----	----	----	----	----
12 / 11 AM	----	----	----	----	----	----	----	----
13 / 11 AM	1.0	105	103	13.3	8.6	54	Yes	850
14 / 11 AM	1.2	105	129	13.3	8.5	55	Yes	850
15 / 11 AM	1.0	105	105	13.9	8.6	53	Yes	850
16 / 11 AM	1.1	105	116	13.9	8.6	53	Yes	850
17 / 11 AM	1.1	105	112	11.7	8.7	63	Yes	850
18 / 11 AM	----	----	----	----	----	----	----	----
19 / 11 AM	----	----	----	----	----	----	----	----
20 / 11 AM	1.0	105	100	11.1	8.8	68	Yes	850
21 / 11 AM	1.1	105	111	10.6	8.9	73	Yes	850
22 / 11 AM	1.0	105	108	10.6	8.8	71	Yes	850
23 / 11 AM	1.1	105	110	10.6	8.7	70	Yes	850
24 / 11 AM	1.2	105	122	9.4	8.8	78	Yes	850
25 / 11 AM	----	----	----	----	----	----	----	----
26 / 11 AM	----	----	----	----	----	----	----	----
27 / 11 AM	1.2	105	122	9.4	8.9	80	Yes	850
28 / 11 AM	1.2	105	123	8.3	9.0	89	Yes	850
29 / 11 AM	1.2	105	126	7.8	8.9	89	Yes	850
30 / 11 AM	1.3	105	138	7.2	8.8	92	Yes	850
31 / 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012