

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth, or Unfiltered

County: COOS
 Month/Year: 11-21

WTP: TP - A

System Name: Bridge Water District	ID#: 41 00552						Highest Reading of the day ¹ [NTU]	Min. Cl ₂ Residual at 1st User [ppm or mg/L]
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]		
1							0.1	0.2
2							0.1	0.2
3							0.1	0.2
4							0.1	0.2
5							0.1	0.2
6							0.1	0.2
7							0.1	0.2
8							0.1	0.3
9							0.1	0.4
10							0.1	0.3
11							0.1	0.3
12							0.1	0.2
13							0.1	0.2
14							0.1	0.2
15							0.1	0.2
16							0.1	0.2
17							0.0	0.2
18							0.0	0.2
19							0.0	0.3
20							0.0	0.2
21							0.1	0.2
22							0.1	0.2
23							0.1	0.2
24							0.1	0.2
25							0.0	0.2
26							0.0	0.2
27							0.0	0.2
28							0.0	0.2
29							0.0	0.2
30							0.0	0.2
31								

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No	Monthly Summary (Answer Yes or No) All Cl ₂ residual measurements at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Monthly UV Summary (circle Yes or No) Was the volume of off-spec water produced less than 5% for the month? Yes / No	PRINTED NAME: ERNEST NEWTON SIGNATURE: <i>Ernest Newton</i> PHONE #: (541) 572-5877 DATE: 12-9-21 CERT #: 2674

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

Slow Sand Filtration with UV *Giardia/Crypto* Disinfection

County: Coos

Month/Year: 11-21

System Name: Bridge Water District

ID# 41- 00552

WTP ID: A

Minimum Dose requirement: 186 mJ/cm²

Date	Minimum Dose Indicator Light	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[green or red]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * [%]
1			9642		
2			10974		
3			9454		
4			8162		
5			12023		
6			12911		
7			11622		
8			12185		
9			9402		
10			10056		
11			9729		
12			10359		
13			10002		
14			8916		
15			9759		
16			10289		
17			5272		
18			5440		
19			5610		
20			6844		
21			8022		
22			7500		
23			8612		
24			14818		
25			13151		
26			12421		
27			12816		
28			11215		
29			10616		
30			6597		
31					
Monthly Cumulative % Off-Spec Water Produced ³					

³ If ≥ 5% of total water produced is off-spec., notify DWS within 24 hours.