

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth, or Unfiltered

County: **COOS**
 Month/Year: **Feb-25**

System Name: **Bridge Water District** ID#: **41 00552** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	Min. Cl2 Residual at 1st User [ppm or mg/L]
1							0.40	0.20
2							0.40	0.20
3							0.40	0.20
4							0.50	0.20
5							0.70	0.20
6							0.80	0.20
7							0.90	0.20
8							0.90	0.30
9								
10								
11								
12								
13							0.90	0.30
14							0.90	0.30
15							0.80	0.30
16							0.80	0.30
17							0.80	0.20
18							0.70	0.20
19							0.70	0.30
20							0.50	0.30
21							0.50	0.30
22							0.50	0.30
23							0.50	0.20
24							0.50	0.20
25							0.40	0.20
26							0.40	0.20
27							0.40	0.20
28							0.40	0.20
29							0.50	0.20
30							0.50	0.20
31							0.50	0.20

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	All Cl2 residual measurements at entry point ≥ 0.2 mg/l?	Yes
All daily turbidity readings ≤ 5 NTU?	Yes		
Monthly UV Summary (circle Yes or No)		PRINTED NAME: Ernie Newton	
Was the volume of off-spec water produced less than 5% for the month?	Yes	SIGNATURE: <i>Ernie Newton</i>	DATE: 3/10/2025
		PHONE #: (541) 572-5877	CERT #: 2674

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form	County:	Coos
Slow Sand Filtration with UV <i>Giardia</i>/<i>Crypto</i> Disinfection	Month/Year:	Feb-25
System Name: <u>Bridge Water District</u>	ID# 41- <u>00552</u>	WTP ID: <u>A</u>

Minimum Dose requirement: 186 mJ/cm²

Date	Minimum Dose Indicator Light	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[green or red]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * [%]
1			9792		
2			10608		
3			7752		
4			12648		
5			12240		
6			7344		
7			8976		
8			8160		
9					
10					
11					
12					
13			9936		
14			12420		
15			7452		
16			9936		
17			13800		
18			16200		
19			13200		
20			13200		
21			10800		
22			21000		
23			13200		
24			14400		
25			9600		
26			12636		
27			12636		
28			11700		
29			10764		
30			9072		
31			9936		
Monthly Cumulative % Off-Spec Water Produced ³					

³ If ≥ 5% of total water produced is off-spec., notify DWS within 24 hours.

Return by 10th of following month by email, fax or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350