

OHA - Drinking Water Services - Surface Water Quality Data Form

County: COOS

Slow Sand, Membrane, Diatomaceous Earth, or Unfiltered

Month/Year: Aug-25

System Name: Bridge Water District ID#: 41 00552 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	Min. Cl ₂ Residual at 1st User [ppm or mg/L]
1							0.10	0.20
2							0.10	0.20
3							0.10	0.20
4							0.10	0.20
5							0.10	0.20
6							0.10	0.30
7							0.10	0.30
8							0.10	0.20
9							0.10	0.30
10							0.10	0.20
11							0.10	0.20
12							0.10	0.20
13							0.10	0.20
14							0.10	0.20
15							0.10	0.20
16							0.10	0.20
17							0.10	0.20
18							0.10	0.30
19							0.10	0.30
20							0.10	0.30
21							0.10	0.30
22							0.10	0.30
23							0.10	0.30
24							0.10	0.20
25							0.10	0.20
26							0.10	0.30
27							0.10	0.20
28							0.10	0.20
29							0.10	0.20
30							0.10	0.20
31							0.10	0.20

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ² Yes		All Cl ₂ residual measurements at entry point $\geq$ 0.2 mg/l? Yes	
All daily turbidity readings $\leq$ 5 NTU? Yes			
Monthly UV Summary (circle Yes or No)		PRINTED NAME: Ernie Newton	
Was the volume of off-spec water produced less than 5% for the month? Yes		SIGNATURE: 	9/10/2025
		PHONE #: 541-572-5877	CERT #: 2674

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form		County: Coos
Slow Sand Filtration <u>with</u> UV <i>Giardia</i>/<i>Crypto</i> Disinfection		Month/Year: Aug-25
System Name: Bridge Water District	ID# 41- 00552	WTP ID: A

Minimum Dose requirement: 186 mJ/cm²

Date	Minimum Dose Indicator Light	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[green or red]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1			12528	0	
2			13572	0	
3			9918	0	
4			16182	0	
5			15660	0	
6			9396	0	
7			11484	0	
8			10440	0	
9			12144	0	
10			15456	0	
11			14904	0	
12			12696	0	
13			13248	0	
14			16560	0	
15			9936	0	
16			13248	0	
17			12696	0	
18			14904	0	
19			12144	0	
20			12144	0	
21			9936	0	
22			19320	0	
23			12144	0	
24			13248	0	
25			8832	0	
26			14418	0	
27			14418	0	
28			13350	0	
29			13884	0	
30			11214	0	
31			12282	0	
Monthly Cumulative % Off-Spec Water Produced ³					

³ If ≥ 5% of total water produced is off-spec., notify DWS within 24 hours.

Return by 10th of following month by email, fax or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350