


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth, or Unfiltered

County: **COOS**
 Month/Year: **Jan-26**

System Name: **Bridge Water District** ID#: **41 00552** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	Min. Cl2 Residual at 1st User [ppm or mg/L]
1							0.50	0.20
2							0.50	0.20
3							0.40	0.20
4							0.40	0.20
5							0.40	0.20
6							0.50	0.20
7							0.80	0.30
8							0.80	0.30
9							0.90	0.20
10							0.90	0.20
11								
12							No Production	
13								
14							0.90	0.30
15							0.90	0.30
16							0.90	0.30
17							0.90	0.30
18							0.90	0.30
19							0.90	0.30
20							0.80	0.20
21							0.80	0.20
22							0.60	0.20
23							0.60	0.20
24							0.50	0.30
25							0.50	0.30
26							0.50	0.20
27							0.50	0.20
28							0.60	0.20
29							0.60	0.20
30							0.50	0.20
31							0.50	0.30

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	All Cl2 residual measurements at entry point ≥ 0.2 mg/l? Yes	
All daily turbidity readings ≤ 5 NTU? Yes		
Monthly UV Summary (circle Yes or No)	PRINTED NAME: Earnie Newton	
Was the volume of off-spec water produced less than 5% for the month? Yes	SIGNATURE: 	2/9/2026
	PHONE #: (541) 572-5877	CERT #: 2674

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form		County: Coos
Slow Sand Filtration with UV <i>Giardia</i>/<i>Crypto</i> Disinfection		Month/Year: Dec-25
System Name: Bridge Water District	ID# 41- 00552	WTP ID: A

Minimum Dose requirement: 186 mJ/cm²

Date	Minimum Dose Indicator Light	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[green or red]	[Y or N]	[gal]	[gal]	$(\text{Mo. Sum } \{B\}) \div (\text{Mo. Sum } \{A\}) * 100$ [%]
1			13248		
2			14352		
3			10488		
4			17112		
5			16560		
6			9936		
7			12144		
8			11040		
9			10032		
10			12768		
11					
12			No Production		
13					
14			13680		
15			8208		
16			10944		
17			10212		
18			11988		
19			9768		
20			9768		
21			7992		
22			15540		
23			9768		
24			10656		
25			7104		
26			10449		
27			10449		
28			9675		
29			10062		
30			8127		
31			8901		
Monthly Cumulative % Off-Spec Water Produced ³					

³ If ≥ 5% of total water produced is off-spec., notify DWS within 24 hours.

Return by 10th of following month by email, fax or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350