

Feb

OHA - Drinking Water Services – Turbidity Monitoring Report Form

County: Tillamook

Cartridge or Bag Filtration

Month/Year: 02/2026

System Name: City of Nehalem		ID# 41-00554		WTP ID: WTP-A		
DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	65	56	9	20	.05	.08
2						off
3	65	56	9	20	.05	.07
4						off
5	65	56	9	20	.04	.07
6						off
7	65	56	9	20	.04	.07
8						off
9	65	56	9	20	.04	.07
10						off
11	65	56	9	20	.04	.07
12						off
13	65	56	9	20	.05	.07
14						off
15	65	56	9	20	.04	.06
16						off
17	65	56	9	20	.04	.07
18						off
19	65	56	9	20	.05	.08
20						off
21	65	56	9	20	.04	.07
22						off
23	65	56	9	20	.04	.07
24	65	56	9	20	.05	.08
25						off
26	65	56	9	20	.04	.07
27						off
28	65	56	9	20	.04	.07
29						
30						
31						

Cartridge Filtration Monthly Summary	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	Yes / No Yes / No	CT's met everyday? (see back) Yes / No
		All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: BRIAN MOORE	
	SIGNATURE: <i>[Signature]</i>	DATE: 2/28/2026
	PHONE #: (503)801-5001	
	Both level 2 CERT #: D-09185 T-09363	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

Feb

OHA - Drinking Water Services – Surface Water Quality Data Form

Month/Year: 02/2026

System Name: City of Nehalem			ID# 41-00554			WTP: WTP-A		
Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/800	.35	240	84	9	7.2	40	Yes	110
2/800	OFF							
3/800	.36	262	94	9	7.2	40	Yes	110
4/800	OFF							
5/800	.38	240	91	9	7.2	40	Yes	120
6/800	OFF							
7/800	.42	262	110	9	7.2	40	Yes	110
8/800	OFF							
9/800	.45	240	108	9	7.2	40	Yes	120
10/800	OFF							
11/800	.49	262	128	9	7.2	40	Yes	120
12/800	OFF							
13/800	.40	262	105	9	7.2	40	Yes	120
14/800	OFF							
15/800	.45	240	108	9	7.2	40	Yes	130
16/800	OFF							
17/800	.43	240	103	9	7.2	40	Yes	130
18/800	OFF							
19/800	.46	262	120	8	7.2	43	Yes	120
20/800	OFF							
21/800	.38	320	122	8	7.2	43	Yes	100
22/800	OFF							
23/800	.30	262	79	8	7.2	43	Yes	120
24/800	.41	288	118	8	7.2	43	Yes	110
25/800	OFF							
26/800	.40	262	105	8	7.2	43	Yes	120
27/800	OFF							
28/800	.38	288	109	8	7.2	43	Yes	120
29/								
30/								
31/								

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised November 2022
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:
dlp.dmce@oha.oregon.gov; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350