

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Feb-21

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.161	0.139	0.147	0.208	PO	PO	0.280
2	PO	PO	0.152	0.157	0.097	PO	0.221
3	PO	PO	0.073	0.080	0.035	0.043	0.144
4	0.038	0.034	0.041	0.058	0.056	0.078	0.142
5	0.052	0.027	0.129	0.196	0.169	0.048	0.236
6	0.037	0.058	0.044	0.074	0.071	0.034	0.223
7	0.043	0.042	0.046	0.155	0.095	0.052	0.234
8	0.086	0.067	0.064	0.029	0.038	0.032	0.086
9	0.063	0.041	0.031	0.064	0.026	0.023	0.268
10	0.024	0.025	0.028	0.025	0.029	0.037	0.158
11	0.067	0.046	0.035	0.029	0.021	0.025	0.112
12	0.029	0.025	0.023	0.063	0.070	0.111	0.227
13	PO	PO	PO	0.093	0.080	0.070	0.221
14	0.080	0.054	0.090	0.040	0.042	0.034	0.134
15	0.071	0.064	0.115	0.167	0.158	0.104	0.224
16	0.064	0.104	0.070	0.081	0.057	0.142	0.216
17	0.119	0.096	0.105	0.031	0.042	0.036	0.219
18	0.060	0.049	0.054	0.090	0.057	0.030	0.219
19	0.021	0.040	0.036	0.054	0.051	0.102	0.174
20	0.135	0.092	0.030	0.036	0.035	0.047	0.195
21	0.040	0.032	0.111	0.152	0.190	0.041	0.229
22	0.063	0.057	0.046	PO	PO	PO	0.257
23	PO	PO	PO	0.133	0.156	0.034	0.179
24	0.032	0.048	0.040	0.064	0.042	0.071	0.117
25	0.065	0.052	0.141	0.030	0.036	0.029	0.164
26	0.045	0.045	0.042	0.054	0.059	0.042	0.277
27	0.023	0.021	0.019	0.027	0.029	0.045	0.092
28	0.040	0.042	0.042	0.038	0.023	0.021	0.284

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: MICHAEL SLIBSAGA	
	SIGNATURE: <i>[Signature]</i>	DATE: 2-2-21
	PHONE #: (503) 842-9405	CERT #: 5314

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Feb-21	Disinfection Giardia Log Reduction	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	8:30	1.10	140	154.0	9.4	7.71	26.1	Yes	105	
2	8:30	0.96	140	134.4	9.4	7.69	25.5	Yes	97	
3	8:30	0.88	140	123.2	9.4	7.62	24.6	Yes	90	
4	8:30	0.88	140	123.2	9.6	7.68	24.8	Yes	101	
5	8:30	0.91	140	127.4	9.5	7.68	25.1	Yes	105	
6	8:30	0.95	140	133.0	9.5	7.70	25.4	Yes	140	
7	8:30	0.97	140	135.8	9.4	7.70	25.6	Yes	152	
8	8:30	1.09	140	152.6	9.6	7.64	25.1	Yes	115	
9	8:30	1.18	140	165.2	9.7	7.68	25.5	Yes	144	
10	8:30	1.19	140	166.6	9.7	7.72	25.9	Yes	90	
11	8:30	1.23	140	172.2	9.7	7.71	25.9	Yes	153	
12	8:30	1.22	140	170.8	9.4	7.70	26.3	Yes	198	
13	8:30	1.19	140	166.6	9.4	7.71	26.3	Yes	337	
14	8:30	1.13	140	158.2	9.3	7.43	23.8	Yes	127	
15	8:30	1.05	140	147.0	9.4	7.42	23.4	Yes	132	
16	8:30	0.95	140	133.0	9.3	7.41	23.2	Yes	110	
17	8:30	0.92	140	128.8	9.4	7.40	22.9	Yes	108	
18	8:30	0.94	140	131.6	9.6	7.43	22.9	Yes	113	
19	8:30	1.02	140	142.8	9.6	7.49	23.6	Yes	106	
20	8:30	1.04	140	145.6	9.7	7.52	23.7	Yes	155	
21	8:30	1.05	140	147.0	9.6	7.56	24.2	Yes	159	
22	8:30	1.10	140	154.0	9.6	7.56	24.4	Yes	105	
23	8:30	1.03	140	144.2	9.5	7.58	24.5	Yes	102	
24	8:30	0.96	140	134.4	9.5	7.60	24.5	Yes	104	
25	8:30	1.01	140	141.4	9.7	7.63	24.6	Yes	101	
26	8:30	1.03	140	144.2	9.7	7.60	24.4	Yes	120	
27	8:30	1.01	140	141.4	9.6	7.63	24.7	Yes	163	
28	8:30	1.08	140	151.2	9.7	7.66	25.0	Yes	158	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012