

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: **Tillamook**

Conventional or Direct Filtration

Month/Year: **Mar-21**

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.024	0.031	0.035	0.042	0.036	0.026	0.170
2	0.030	0.020	0.017	0.023	0.023	0.021	0.197
3	0.020	0.020	0.021	0.025	0.030	0.025	0.071
4	0.040	0.037	0.020	0.021	0.023	0.020	0.131
5	0.030	0.026	PO	0.064	0.029	0.023	0.197
6	0.025	0.034	0.042	0.040	0.045	0.054	0.188
7	0.021	0.023	0.019	0.024	0.032	0.030	0.141
8	0.045	0.042	0.065	0.042	0.023	0.020	0.179
9	0.020	0.020	0.019	0.034	0.032	0.049	0.098
10	0.058	0.054	0.022	0.025	0.024	0.029	0.279
11	0.026	0.037	0.047	0.024	0.046	0.026	0.196
12	0.024	0.025	0.020	0.027	0.030	0.046	0.063
13	0.032	0.031	0.021	0.024	0.026	0.027	0.141
14	0.031	0.042	0.032	0.024	0.042	0.041	0.154
15	0.038	0.051	0.041	0.048	0.060	0.046	0.172
16	0.024	0.027	0.021	0.030	0.029	0.036	0.122
17	0.041	0.037	0.040	0.026	0.024	0.024	0.240
18	0.030	0.026	0.036	0.038	0.042	0.046	0.192
19	0.025	0.024	0.020	0.025	0.031	0.045	0.222
20	0.029	0.036	0.021	0.027	0.028	0.031	0.164
21	0.045	0.039	0.031	0.024	0.023	0.024	0.174
22	0.085	0.125	0.120	0.137	0.101	0.035	0.195
23	0.034	0.036	0.042	0.054	0.054	0.086	0.203
24	0.026	0.027	0.024	0.056	0.167	0.243	0.245
25	PO	PO	0.171	0.053	0.047	0.038	0.257
26	0.054	0.042	0.028	0.027	0.042	0.035	0.122
27	0.064	0.042	0.065	0.065	0.030	0.024	0.197
28	0.025	0.029	0.033	0.076	0.054	0.043	0.200
29	0.036	0.040	0.030	0.043	0.037	0.076	0.104
30	0.065	0.053	0.024	0.023	0.023	0.023	0.167
31	0.034	0.031	0.029	0.043	0.038	0.026	0.122

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl2 residual at entry point <b>Yes / No</b>
All daily turbidity readings ≤ 1 NTU? <b>Yes / No</b>		
All turbidity readings < IFE <sup>2</sup> triggers <b>Yes / No</b>		

Notes:	PRINTED NAME: <b>MICHAEL SLIBSDORF</b>
	SIGNATURE: <i>[Signature]</i> DATE: <b>3-1-21</b>
	PHONE #: <b>(503) 842-9405</b> CERT #: <b>5314</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Mar-21	Disinfection Giardia Log Location	0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	8:30	1.12	140	156.8	9.7	7.66	25.2	Yes	108	
2	8:30	1.24	140	173.6	9.8	7.67	25.4	Yes	117	
3	8:30	1.21	140	169.4	9.7	7.66	25.4	Yes	111	
4	8:30	1.23	140	172.2	9.7	7.66	25.5	Yes	131	
5	8:30	1.22	140	170.8	9.7	7.69	25.7	Yes	119	
6	8:30	1.08	140	151.2	9.8	7.69	25.1	Yes	146	
7	8:30	1.05	140	147.0	9.7	7.71	25.4	Yes	163	
8	8:30	1.11	140	155.4	9.7	7.68	25.3	Yes	112	
9	8:30	1.12	140	156.8	9.7	7.64	25.0	Yes	101	
10	8:30	1.09	140	152.6	9.6	7.71	25.7	Yes	106	
11	8:30	1.12	140	156.8	9.7	7.69	25.4	Yes	129	
12	8:30	1.12	140	156.8	9.6	7.68	25.5	Yes	134	
13	8:30	1.13	140	158.2	9.6	7.71	25.8	Yes	170	
14	8:30	1.16	140	162.4	9.7	7.70	25.6	Yes	137	
15	8:30	1.10	140	154.0	9.6	7.76	26.2	Yes	165	
16	8:30	1.20	140	168.0	9.1	7.74	27.2	Yes	119	
17	8:30	1.15	140	161.0	9.7	7.73	25.9	Yes	186	
18	8:30	1.10	140	154.0	9.8	7.72	25.5	Yes	114	
19	8:30	1.07	140	149.8	9.7	7.66	25.0	Yes	155	
20	8:30	1.11	140	155.4	9.9	7.71	25.2	Yes	172	
21	8:30	1.09	140	152.6	9.7	7.70	25.4	Yes	166	
22	8:30	1.01	140	141.4	9.5	7.79	26.4	Yes	143	
23	8:30	0.97	140	135.8	9.5	7.69	25.3	Yes	146	
24	8:30	1.02	140	142.8	9.5	7.67	25.3	Yes	144	
25	8:30	0.95	140	133.0	9.6	7.80	26.1	Yes	142	
26	8:30	0.93	140	130.2	9.5	7.67	25.0	Yes	146	
27	8:30	0.99	140	138.6	9.5	7.68	25.3	Yes	178	
28	8:30	1.03	140	144.2	9.6	7.68	25.2	Yes	167	
29	8:30	1.07	140	149.8	9.6	7.71	25.6	Yes	121	
30	8:30	1.09	140	152.6	9.6	7.71	25.7	Yes	128	
31	8:30	0.99	140	138.6	9.7	7.72	25.3	Yes	117	

3 If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012