

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Apr-21

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.021	0.024	0.020	0.027	0.029	0.038	0.113
2	0.051	0.045	0.021	0.024	0.024	0.025	0.192
3	0.027	0.026	0.036	0.049	0.026	0.024	0.233
4	0.031	0.027	0.023	0.034	0.037	0.032	0.181
5	0.029	0.029	0.025	0.026	0.026	0.027	0.082
6	0.048	0.043	0.020	0.025	0.029	0.023	0.153
7	0.023	0.023	0.021	0.031	0.036	0.032	0.104
8	0.052	0.038	0.022	0.024	0.026	0.029	0.168
9	0.043	0.041	0.038	0.048	0.031	0.025	0.180
10	0.025	0.025	0.025	0.030	0.046	0.037	0.106
11	0.024	0.032	0.025	0.027	0.025	0.037	0.137
12	0.037	0.035	0.021	0.032	0.023	0.023	0.102
13	0.024	0.023	0.027	0.035	0.021	0.023	0.185
14	0.024	0.023	0.025	0.023	0.023	0.026	0.051
15	0.025	0.030	0.035	0.042	0.020	0.019	0.251
16	0.019	0.020	0.017	0.027	0.023	0.019	0.200
17	0.019	0.023	0.019	0.038	0.019	0.019	0.238
18	0.020	0.023	0.015	0.038	0.018	0.018	0.226
19	0.019	0.021	0.018	0.019	0.020	0.020	0.052
20	0.023	0.021	0.036	0.032	0.020	0.019	0.216
21	0.019	0.019	0.020	0.036	0.040	0.028	0.170
22	0.023	0.019	0.018	0.021	0.023	0.030	0.054
23	0.034	0.031	0.026	0.020	0.019	0.019	0.233
24	0.024	0.023	0.064	0.078	0.065	0.031	0.129
25	0.038	0.023	0.019	0.026	0.026	0.025	0.125
26	0.020	0.019	0.018	0.018	0.019	0.021	0.078
27	0.023	0.020	0.021	0.021	0.020	0.020	0.244
28	0.020	0.024	0.020	0.036	0.019	0.021	0.235
29	0.019	0.019	0.019	0.024	0.037	0.029	0.177
30	0.019	0.020	0.018	0.020	0.045	0.020	0.135

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	Yes/No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	Yes/No	Yes/No	Yes/No
All turbidity readings < IFE <sup>2</sup> triggers	Yes/No		
<b>Notes:</b>	<b>PRINTED NAME:</b> MICHAEL SLIBSAGE		<b>DATE:</b> 3-3-21
	<b>SIGNATURE:</b> [Signature]		<b>CERT #:</b> 5314
	<b>PHONE #:</b> (503) 842-9405		

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Apr-21	Disinfection Giardia Log Reduction	0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.18	140	165.2	9.5	7.68	25.9	Yes	172
2	8:30	1.26	140	176.4	9.6	7.70	26.1	Yes	129
3	8:30	1.33	140	186.2	9.6	7.72	26.5	Yes	157
4	8:30	1.37	140	191.8	9.7	7.73	26.5	Yes	174
5	8:30	1.17	140	163.8	9.5	7.70	26.0	Yes	130
6	8:30	1.09	140	152.6	9.6	7.72	25.8	Yes	134
7	8:30	1.12	140	156.8	9.7	7.71	25.6	Yes	144
8	8:30	1.04	140	145.6	9.8	7.68	24.9	Yes	148
9	8:30	1.12	140	156.8	9.7	7.71	25.6	Yes	145
10	8:30	1.09	140	152.6	9.6	7.70	25.6	Yes	164
11	8:30	1.12	140	156.8	9.6	7.71	25.8	yes	172
12	8:30	1.14	140	159.6	9.6	7.72	25.9	yes	139
13	8:30	1.14	140	159.6	9.7	7.72	25.8	Yes	140
14	8:30	1.09	140	152.6	9.7	7.72	25.6	Yes	167
15	8:30	1.21	140	169.4	9.8	7.76	26.2	Yes	150
16	8:30	1.15	140	161.0	9.7	7.70	25.6	Yes	170
17	8:30	1.21	140	169.4	10.1	7.74	25.5	Yes	196
18	8:30	1.09	140	152.6	10.6	7.72	24.1	Yes	220
19	8:30	1.07	140	149.8	10.6	7.71	24.0	Yes	147
20	8:30	1.05	140	147.0	10.6	7.72	24.0	Yes	148
21	8:30	1.11	140	155.4	10.8	7.71	23.8	Yes	146
22	8:30	1.05	140	147.0	10.8	7.76	24.0	Yes	129
23	8:30	1.07	140	149.8	10.8	7.70	23.6	Yes	127
24	8:30	1.12	140	156.8	10.8	7.74	24.1	Yes	151
25	8:30	1.10	140	154.0	10.7	7.72	24.0	Yes	172
26	8:30	1.08	140	151.2	10.7	7.70	23.8	Yes	168
27	8:30	1.09	140	152.6	10.5	7.75	24.5	Yes	121
28	8:30	1.00	140	140.0	10.5	7.74	24.2	Yes	149
29	8:30	1.14	140	159.6	10.6	7.73	24.3	Yes	144
30	8:30	0.98	140	137.2	10.8	7.72	23.5	Yes	134

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012