

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Feb-21



System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.030	0.021	0.017	0.020	0.023	0.030	0.217
2	0.032	0.030	0.023	0.018	0.020	0.024	0.196
3	0.029	0.068	0.032	0.019	0.018	0.018	0.268
4	0.091	0.093	0.028	0.064	0.021	0.019	0.230
5	0.027	0.024	0.026	0.041	0.020	0.018	0.240
6	0.023	0.021	0.018	0.026	0.035	0.052	0.233
7	0.042	0.020	0.021	0.030	0.029	0.031	0.100
8	0.042	0.023	0.020	0.019	0.020	0.020	0.288
9	0.030	0.027	0.039	0.020	0.018	0.019	0.158
10	0.023	0.020	0.033	0.041	0.023	0.019	0.272
11	0.020	0.019	0.017	0.025	0.046	0.019	0.228
12	0.018	0.018	0.017	0.021	0.020	0.032	0.103
13	0.032	0.013	0.015	0.018	0.020	0.019	0.206
14	0.031	0.027	0.097	0.060	0.022	0.015	0.232
15	0.030	0.027	0.056	0.016	0.015	0.015	0.256
16	0.032	0.032	0.058	0.016	0.016	0.023	0.169
17	0.019	0.023	0.034	0.052	0.019	0.019	0.213
18	0.016	0.021	0.021	0.021	0.043	0.043	0.144
19	0.021	0.019	0.021	0.032	0.037	0.038	0.131
20	0.046	0.038	0.033	0.026	0.020	0.026	0.103
21	0.038	0.032	0.044	0.021	0.018	0.031	0.294
22	0.015	0.020	0.031	0.035	0.038	0.020	0.131
23	0.021	0.025	0.034	0.049	0.074	0.079	0.283
24	0.018	0.024	0.021	0.126	0.122	0.102	0.167
25	0.090	0.084	PO	0.135	0.238	0.104	0.268
26	0.043	0.090	0.052	0.067	0.034	0.036	0.249
27	0.025	0.030	0.109	0.179	0.145	0.075	0.185
28	0.032	0.034	0.033	0.037	0.054	0.034	0.128
29	0.032	0.023	0.016	0.020	0.029	0.049	0.200
30	0.056	0.015	0.017	0.025	0.027	0.098	0.288
31	0.024	0.020	0.023	0.032	0.046	0.016	0.228

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: MICHAEL SLIASAKH

SIGNATURE: *[Signature]* DATE: 2-2-21

PHONE #: (503) 842-9405 CERT #: 5314

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A  
 Disinfection  
 Giardia Log  
 Inactivation 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Jan-21	Giardia Log Inactivation	0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	8:30	1.13	140	158.2	10.7	7.74	24.2	Yes	162	
2	8:30	1.22	140	170.8	10.8	7.78	24.7	Yes	158	
3	8:30	1.33	140	186.2	10.7	7.75	24.9	Yes	152	
4	8:30	1.28	140	179.2	10.8	7.66	23.8	Yes	135	
5	8:30	1.27	140	177.8	11.6	7.76	23.4	Yes	136	
6	8:30	1.21	140	169.4	11.6	7.73	23.0	Yes	136	
7	8:30	1.16	140	162.4	11.6	7.72	22.8	Yes	151	
8	8:30	1.09	140	152.6	11.5	7.72	22.7	Yes	173	
9	8:30	1.02	140	142.8	11.5	7.70	22.4	Yes	185	
10	8:30	1.06	140	148.4	11.3	7.71	22.9	Yes	147	
11	8:30	1.11	140	155.4	11.5	7.69	22.5	Yes	159	
12	8:30	1.15	140	161.0	11.5	7.70	22.7	Yes	160	
13	8:30	1.08	140	151.2	11.7	7.70	22.2	Yes	158	
14	8:30	1.09	140	152.6	11.6	7.69	22.3	Yes	182	
15	8:30	1.05	140	147.0	11.6	7.71	22.4	Yes	218	
16	8:30	1.08	140	151.2	11.6	7.72	22.5	Yes	226	
17	8:30	1.04	140	145.6	11.6	7.71	22.4	Yes	144	
18	8:30	1.12	140	156.8	11.7	7.68	22.2	Yes	139	
19	8:30	1.05	140	147.0	11.5	7.72	22.6	Yes	137	
20	8:30	1.11	140	155.4	11.5	7.69	22.5	Yes	138	
21	8:30	1.11	140	155.4	11.6	7.71	22.5	Yes	160	
22	8:30	1.12	140	156.8	11.5	7.72	22.8	Yes	190	
23	8:30	1.10	140	154.0	11.3	7.70	22.9	Yes	184	
24	8:30	0.95	140	133.0	11.6	7.71	22.1	Yes	133	
25	8:30	0.93	140	130.2	11.6	7.69	21.9	Yes	136	
26	8:30	0.94	140	131.6	11.5	7.71	22.3	Yes	146	
27	8:30	0.84	140	117.6	11.6	7.71	21.9	Yes	152	
28	8:30	0.89	140	124.6	11.6	7.68	21.8	Yes	159	
29	8:30	1.04	140	145.6	11.7	7.71	22.2	Yes	216	
30	8:30	1.02	140	142.8	11.7	7.68	21.9	Yes	222	
31	8:30	1.09	140	152.6	11.8	7.69	22.0	Yes	272	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012