

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Dec-21

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.057	0.053	0.037	0.027	0.031	0.023	0.161
2	0.024	0.024	0.026	0.024	0.024	0.025	0.147
3	0.020	0.019	0.058	0.019	0.020	0.024	0.295
4	0.216	0.018	0.057	0.027	0.092	0.177	0.280
5	0.273	0.268	0.068	0.036	0.037	0.026	0.276
6	0.054	0.051	0.067	0.157	0.192	0.172	0.225
7	0.137	0.117	0.181	0.053	0.042	0.047	0.170
8	0.097	0.122	0.144	0.151	0.107	0.047	0.207
9	0.030	0.030	0.065	0.126	0.151	0.157	0.263
10	0.087	0.056	0.044	0.054	0.130	0.155	0.170
11	PO	PO	PO	PO	PO	PO	PO
12	PO	PO	0.125	0.142	0.103	0.095	0.163
13	0.098	0.081	0.086	0.135	0.093	0.048	0.192
14	0.038	0.036	0.034	0.040	0.026	0.056	0.200
15	0.040	0.026	0.020	0.024	0.029	0.042	0.087
16	0.089	0.074	0.061	0.023	0.023	0.021	0.136
17	0.042	0.035	0.050	0.023	0.029	0.042	0.117
18	0.024	0.023	0.026	0.025	0.101	PO	0.254
19	PO	PO	0.165	0.151	0.084	0.035	0.225
20	0.068	0.184	0.085	0.150	0.217	0.269	0.280
21	PO	PO	0.070	0.052	0.027	0.034	0.189
22	0.038	0.082	0.074	0.020	0.021	0.018	0.225
23	0.019	0.023	0.033	0.045	0.046	0.049	0.115
24	0.058	0.041	0.056	0.084	0.060	0.075	0.144
25	0.064	0.049	0.048	0.024	0.023	0.064	0.073
26	0.020	0.035	0.027	0.027	0.020	0.016	0.041
27	0.018	0.016	0.019	0.024	0.026	0.041	0.041
28	0.037	0.025	0.023	0.029	0.026	0.038	0.054
29	0.043	0.054	0.063	0.025	0.034	0.043	0.102
30	0.058	0.062	0.121	0.076	0.073	0.078	0.135
31	0.097	0.069	0.069	0.076	0.091	0.073	0.134

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:

PRINTED NAME: *[Signature]*

SIGNATURE: *[Signature]* DATE: 1-4-2022

PHONE #: (503)-812-8802 CERT #: 1457

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Netarts Water District							ID#: 41		00556		Month/Year: Dec-21		WTP - : A		Disinfection Giardia Log Location		0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow									
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]									
1	8:30	1.08	140	151.2	11.5	7.58	21.6	Yes	106									
2	8:30	1.06	140	148.4	11.6	7.56	21.3	Yes	179									
3	8:30	1.12	140	156.8	11.3	7.51	21.5	Yes	140									
4	8:30	1.11	140	155.4	11.3	7.56	21.8	Yes	121									
5	8:30	1.1	140	154.0	11.1	7.53	21.8	Yes	148									
6	8:30	1.11	140	155.4	11.0	7.55	22.2	Yes	106									
7	8:30	1.01	140	141.4	11.0	7.54	21.8	Yes	111									
8	8:30	1.05	140	147.0	11.0	7.66	22.9	Yes	104									
9	8:30	1.05	140	147.0	10.9	7.52	21.9	Yes	100									
10	8:30	1.06	140	148.4	10.9	7.54	22.1	Yes	112									
11	8:30	1.03	140	144.2	11.0	7.53	21.8	Yes	126									
12	8:30	0.99	140	138.6	10.8	7.52	21.9	Yes	139									
13	8:30	1.03	140	144.2	10.4	7.54	22.8	Yes	101									
14	8:30	1.05	140	147.0	10.5	7.53	22.6	Yes	111									
15	8:30	1.08	140	151.2	10.4	7.56	23.1	Yes	103									
16	8:30	1.11	140	155.4	10.2	7.55	23.4	Yes	99									
17	8:30	1.13	140	158.2	10.2	7.57	23.6	Yes	105									
18	8:30	1.15	140	161.0	10.3	7.56	23.4	Yes	122									
19	8:30	1.18	140	165.2	10.1	7.58	24.0	Yes	128									
20	8:30	1.13	140	158.2	10.1	7.54	23.5	Yes	139									
21	8:30	1.09	140	152.6	10.3	7.55	23.2	Yes	126									
22	8:30	1.09	140	152.6	10.4	7.53	22.9	Yes	124									
23	8:30	1.04	140	145.6	10.4	7.55	22.9	Yes	130									
24	8:30	1.05	140	147.0	10.3	7.57	23.2	Yes	188									
25	8:30	1.03	140	144.2	10.4	7.54	22.8	Yes	112									
26	8:30	0.96	140	134.4	10.1	7.51	22.8	Yes	122									
27	8:30	1.02	140	142.8	10.0	7.55	23.4	Yes	164									
28	8:30	1.1	140	154.0	9.8	7.56	24.1	Yes	161									
29	8:30	1.12	140	156.8	9.6	7.59	24.7	Yes	138									
30	8:30	1.14	140	159.6	9.3	7.58	25.2	Yes	147									
31	8:30	1.13	140	158.2	9.4	7.55	24.7	Yes	150									

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012