

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Feb/2022

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.029	0.027	0.048	0.041	0.027	0.025	0.058
2	0.024	0.114	0.109	0.023	0.023	0.023	0.116
3	0.018	0.019	0.023	0.051	0.087	0.046	0.106
4	0.030	0.029	0.019	0.020	0.021	0.027	0.042
5	0.041	0.051	0.034	0.026	0.027	0.043	1.051
6	0.027	0.034	0.016	0.035	0.016	0.023	0.064
7	0.053	0.040	0.030	0.021	0.015	0.018	0.050
8	0.016	0.023	0.020	0.025	0.020	0.034	0.034
9	0.024	0.042	0.037	0.024	0.018	0.023	0.081
10	0.019	0.019	0.069	0.024	0.015	0.018	0.170
11	0.015	0.018	0.027	0.020	0.026	0.037	0.101
12	0.018	0.020	0.016	0.020	0.024	0.030	0.167
13	0.019	0.025	0.017	0.021	0.018	0.027	0.048
14	0.180	0.019	0.050	0.036	0.021	0.037	0.167
15	0.016	0.021	0.020	0.027	0.020	0.015	0.112
16	0.016	0.019	0.017	0.016	0.023	0.025	0.164
17	0.027	0.020	0.024	0.023	0.023	0.021	0.108
18	0.019	0.019	0.023	0.021	0.030	0.021	0.078
19	0.036	0.019	0.028	0.035	0.018	0.053	0.073
20	0.064	0.109	0.106	0.092	0.093	0.123	0.225
21	0.098	0.093	0.100	0.129	0.122	0.128	0.249
22	0.201	0.106	0.147	0.081	0.071	0.032	0.192
23	0.034	0.029	0.181	0.048	0.037	0.065	0.210
24	0.048	0.037	0.065	0.032	0.019	0.034	0.136
25	0.027	0.015	0.026	0.030	0.027	0.031	0.047
26	0.020	0.020	0.032	0.030	0.018	0.024	0.142
27	0.031	0.065	0.049	0.023	0.103	0.141	0.201
28	0.136	PO	PO	PO	PO	PO	0.136
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: <i>[Signature]</i>		
	SIGNATURE: <i>[Signature]</i>	DATE:	
	PHONE #: (503) 812-8802	CERT #:	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Feb/2022	Disinfection Giardia Log Negative		0.5
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.02	140	142.8	10.2	7.69	24.3	Yes	98
2	8:30	1.02	140	142.8	10.0	7.57	23.6	Yes	100
3	8:30	1.1	140	154.0	10.1	7.70	24.8	Yes	104
4	8:30	1.08	140	151.2	10.4	7.63	23.6	Yes	109
5	8:30	1.08	140	151.2	10.4	7.58	23.2	Yes	152
6	8:30	1.11	140	155.4	11.2	7.57	22.0	Yes	171
7	8:30	1.05	140	147.0	10.5	7.61	23.2	Yes	116
8	8:30	1.1	140	154.0	10.1	7.60	23.9	Yes	110
9	8:30	1.23	140	172.2	10.0	7.73	25.6	Yes	173
10	8:30	1.27	140	177.8	10.0	7.55	24.1	Yes	135
11	8:30	1.17	140	163.8	10.1	7.75	25.4	Yes	122
12	8:30	1.19	140	166.6	10.2	7.67	24.6	Yes	152
13	8:30	1.25	140	175.0	10.2	7.72	25.2	Yes	166
14	8:30	1.47	140	205.8	10.5	7.70	25.2	Yes	122
15	8:30	1.40	140	196.0	10.3	7.67	25.0	Yes	114
16	8:30	1.58	140	221.2	10.4	7.70	25.7	Yes	172
17	8:30	1.21	140	169.4	10.5	7.57	23.3	Yes	210
18	8:30	1.26	140	176.4	10.1	7.72	25.4	Yes	171
19	8:30	1.24	140	173.6	10.1	7.65	24.7	Yes	146
20	8:30	1.34	140	187.6	10.1	7.62	24.8	Yes	175
21	8:30	1.18	140	165.2	10.0	7.67	24.9	Yes	169
22	8:30	0.99	140	138.6	9.7	7.67	24.9	Yes	138
23	8:30	1	140	140.0	8.1	7.65	27.5	Yes	141
24	8:30	1.05	140	147.0	9.3	7.73	26.3	Yes	123
25	8:30	1.19	140	166.6	9.0	7.67	26.7	Yes	192
26	8:30	1.25	140	175.0	9.9	7.55	24.2	Yes	136
27	8:30	1.37	140	191.8	10.2	7.59	24.4	Yes	211
28	8:30	1.27	140	177.8	10.1	7.68	25.1	Yes	130
29	8:30		140	0.0			4.2		
30	8:30		140	0.0			4.2		
31	8:30		140	0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012