

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: March/2022

System Name: Netarts Water District ID#: 41 00556 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	PO	PO	PO	0.170	0.133	0.123	0.280
2	0.093	0.098	0.147	0.159	0.142	0.166	0.250
3	0.133	0.172	0.129	0.139	0.162	0.108	0.214
4	0.049	0.047	0.026	0.060	0.079	0.032	0.150
5	0.073	0.058	0.039	0.087	0.029	0.078	0.118
6	0.084	0.249	0.096	0.037	0.024	0.016	0.273
7	0.023	0.019	0.025	0.035	0.030	0.021	0.181
8	0.025	0.016	0.018	0.018	0.018	0.027	0.068
9	0.054	0.052	0.126	0.027	0.020	0.016	0.057
10	0.016	0.016	0.028	0.020	0.020	0.024	0.137
11	0.030	0.018	0.024	0.027	0.018	0.021	0.067
12	0.037	0.021	0.028	0.029	0.018	0.019	0.096
13	0.065	0.096	0.112	0.104	0.186	PO	0.295
14	PO	PO	0.141	0.056	0.051	0.049	0.288
15	0.260	0.107	0.103	0.114	0.112	0.063	0.172
16	0.046	0.058	0.050	0.024	0.035	0.030	0.238
17	0.024	0.054	0.031	0.040	0.031	0.031	0.177
18	0.026	0.025	0.038	0.047	0.064	0.089	0.152
19	0.048	0.049	0.060	0.082	0.098	0.089	0.106
20	0.060	0.057	0.086	0.038	0.042	0.030	0.060
21	0.030	0.054	0.075	0.282	PO	PO	0.282
22	PO	PO	0.171	0.101	0.114	0.038	0.257
23	0.053	0.034	0.030	0.043	0.059	0.079	0.117
24	0.081	0.075	0.028	0.040	0.027	0.030	0.081
25	0.036	0.038	0.028	0.021	0.020	0.024	0.112
26	0.031	0.027	0.038	0.041	0.037	0.040	0.076
27	0.021	0.038	0.026	0.036	0.047	0.019	0.048
28	0.041	0.018	0.019	0.040	0.029	0.042	0.074
29	0.019	0.020	0.039	0.041	0.020	0.021	0.073
30	0.021	0.021	0.029	0.034	0.020	0.031	0.065
31	0.018	0.018	0.020	0.045	0.025	0.045	0.080

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:

PRINTED NAME: *JIM WILSON*

SIGNATURE: *[Signature]* DATE: *4-4-22*

PHONE #: ( ) CERT #: *1657*

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A  
 Disinfection  
 Giardia Log  
 Inactivation  
 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	March/2022		
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.08	140	151.2	9.6	7.62	24.9	Yes	108
2	8:30	0.97	140	135.8	10.0	7.44	22.4	Yes	102
3	8:30	0.89	140	124.6	10.1	7.43	22.0	Yes	103
4	8:30	1	140	140.0	9.6	7.41	22.9	Yes	118
5	8:30	1.08	140	151.2	10.0	7.49	23.1	Yes	154
6	8:30	1.06	140	148.4	10.0	7.58	23.8	Yes	159
7	8:30	1.35	140	189.0	10.1	7.52	23.9	Yes	147
8	8:30	1.31	140	183.4	10.5	7.65	24.3	Yes	116
9	8:30	1.38	140	193.2	10.2	7.67	25.2	Yes	117
10	8:30	0.9	140	126.0	10.0	7.68	24.2	Yes	135
11	8:30	1.46	140	204.4	9.9	7.70	26.2	Yes	153
12	8:30	1.5	140	210.0	10.1	7.55	24.6	Yes	147
13	8:30	1.5	140	210.0	9.9	7.61	25.5	Yes	196
14	8:30	1.4	140	196.0	10.2	7.63	24.9	Yes	110
15	8:30	1.39	140	194.6	9.9	7.69	25.9	Yes	104
16	8:30	1.48	140	207.2	9.9	7.63	25.6	Yes	114
17	8:30	1.63	140	228.2	10.1	7.58	25.2	Yes	109
18	8:30	1.58	140	221.2	10.1	7.63	25.5	Yes	144
19	8:30	1.31	140	183.4	10.1	7.55	24.1	Yes	141
20	8:30	1.12	140	156.8	10.1	7.57	23.7	Yes	154
21	8:30	1.16	140	162.4	10.7	7.49	22.3	Yes	146
22	8:30	1.12	140	156.8	10.1	7.48	23.0	Yes	147
23	8:30	1.04	140	145.6	10.3	7.48	22.5	Yes	150
24	8:30	1.25	140	175.0	10.4	7.54	23.4	Yes	154
25	8:30	1.39	140	194.6	10.4	7.47	23.1	Yes	180
26	8:30	1.15	140	161.0	10.5	7.69	24.2	Yes	183
27	8:30	1.31	140	183.4	10.7	7.60	23.5	Yes	191
28	8:30	0.99	140	138.6	10.6	7.61	22.9	Yes	129
29	8:30	1.03	140	144.2	11.1	7.41	20.8	Yes	109
30	8:30	1.03	140	144.2	10.6	7.72	24.0	Yes	135
31	8:30	1.06	140	148.4	10.6	7.60	23.0	P	111

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012