

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: April/2022

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.019	0.020	0.020	0.024	0.025	0.025	0.102
2	0.018	0.018	0.046	0.035	0.018	0.024	0.223
3	0.031	0.021	0.019	0.031	0.030	0.030	0.082
4	0.024	0.144	0.170	0.128	0.134	0.158	0.158
5	0.123	0.049	0.031	0.036	0.024	0.035	0.098
6	0.024	0.043	0.021	0.034	0.035	0.037	0.101
7	0.059	0.020	0.033	0.032	0.026	0.016	0.093
8	0.018	0.036	0.031	0.071	0.029	0.027	0.093
9	0.035	0.035	0.031	0.029	0.026	0.091	0.162
10	0.037	0.067	0.047	0.047	0.027	0.032	0.245
11	0.025	0.246	0.298	0.820	0.010	0.009	0.298
12	0.157	0.084	0.028	0.133	0.084	0.035	0.272
13	0.034	0.111	0.050	0.122	0.147	0.086	0.155
14	0.126	0.027	0.045	0.127	0.027	0.036	0.184
15	0.032	0.042	0.049	0.027	0.023	0.036	0.113
16	0.038	0.023	0.033	0.043	0.040	0.058	0.118
17	0.019	0.016	0.019	0.040	0.032	0.036	0.073
18	0.038	0.016	0.019	0.027	0.040	0.139	0.192
19	0.147	0.156	0.119	0.024	0.114	0.093	0.200
20	0.024	0.019	0.019	0.031	0.026	0.023	0.117
21	0.030	0.037	0.034	0.065	0.031	0.090	0.145
22	0.024	0.024	0.025	0.034	0.040	0.019	0.196
23	0.042	0.019	0.026	0.036	0.036	0.026	0.059
24	0.043	0.036	0.019	0.023	0.016	0.017	0.068
25	0.027	0.023	0.021	0.018	0.018	0.016	0.069
26	0.018	0.019	0.020	0.025	0.019	0.036	0.179
27	0.064	0.064	0.023	0.024	0.024	0.030	0.065
28	0.024	0.024	0.023	0.021	0.019	0.021	0.173
29	0.025	0.047	0.028	0.124	0.018	0.019	0.163
30	0.070	PO	0.192	PO	PO	PO	
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No
 All daily turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point Yes / No

Notes:

PRINTED NAME: TIM WEAVER

SIGNATURE: [Signature]

DATE: 4-5-22

PHONE #: ()

CERT #: 1657

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A
 Disinfection
 Giardia Log
 Location: 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: April/2022			
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.11	140	155.4	10.6	7.69	23.9	Yes	176
2	8:30	1.29	140	180.6	10.6	7.65	24.1	Yes	148
3	8:30	1.35	140	189.0	10.5	7.63	24.2	Yes	162
4	8:30	1.2	140	168.0	10.9	7.67	23.5	Yes	122
5	8:30	1.21	140	169.4	10.5	7.66	24.1	Yes	130
6	8:30	1.02	140	142.8	10.5	7.59	23.0	Yes	130
7	8:30	1.29	140	180.6	10.5	7.74	25.0	Yes	143
8	8:30	1.18	140	165.2	11.0	7.67	23.3	Yes	133
9	8:30	1.11	140	155.4	10.7	7.54	22.5	Yes	162
10	8:30	1.2	140	168.0	10.8	7.56	22.8	Yes	163
11	8:30	1.22	140	170.8	10.5	7.72	24.6	Yes	119
12	8:30	1.18	140	165.2	11.0	7.79	24.3	Yes	111
13	8:30	1.16	140	162.4	10.2	7.81	25.8	Yes	111
14	8:30	1.19	140	166.6	10.0	7.71	25.3	Yes	106
15	8:30	1.06	140	148.4	10.0	7.74	25.2	Yes	128
16	8:30	1.13	140	158.2	9.4	7.76	26.6	Yes	157
17	8:30	0.85	140	119.0	9.8	7.47	22.7	Yes	168
18	8:30	1.3	140	182.0	10.0	7.53	24.0	Yes	118
19	8:30	1.21	140	169.4	10.0	7.73	25.5	Yes	153
20	8:30	1.16	140	162.4	10.0	7.68	24.9	Yes	118
21	8:30	1.05	140	147.0	10.0	7.60	23.9	Yes	126
22	8:30	1.32	140	184.8	10.1	7.59	24.4	Yes	127
23	8:30	1.22	140	170.8	10.2	7.58	23.9	Yes	164
24	8:30	1.14	140	159.6	10.3	7.53	23.1	Yes	186
25	8:30	1.10	140	154.0	10.0	7.41	22.5	Yes	124
26	8:30	1.17	140	163.8	10.6	7.61	23.4	Yes	112
27	8:30	1.24	140	173.6	10.6	7.45	22.3	Yes	118
28	8:30	1.06	140	148.4	10.6	7.57	22.8	Yes	120
29	8:30	1.28	140	179.2	10.6	7.47	22.6	Yes	127
30	8:30	1.28	140	179.2	10.7	7.45	22.3	Yes	162
31	8:30		140	0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012