

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: May-22

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PO	PO	0.025	0.210	0.082	0.037	0.274
2	0.021	0.051	0.049	0.049	0.078	0.051	0.145
3	0.079	0.074	0.112	0.092	0.096	0.032	0.151
4	0.023	0.023	0.023	0.027	0.021	0.023	0.120
5	0.023	0.018	0.030	0.073	0.063	0.100	0.131
6	0.200	0.202	0.206	PO	PO	0.161	0.283
7	0.239	0.272	0.116	0.112	0.130	0.123	0.243
8	0.125	0.164	0.184	0.140	0.103	0.100	0.178
9	0.058	0.042	0.062	0.082	0.021	0.021	0.128
10	0.020	0.019	0.024	0.021	0.025	0.027	0.112
11	0.016	0.018	0.021	0.018	0.018	0.019	0.045
12	0.020	0.020	0.101	PO	PO	0.139	0.184
13	0.136	0.136	0.131	0.058	0.057	0.069	0.276
14	PO	PO	PO	PO	0.135	0.152	0.214
15	0.079	0.032	0.035	0.092	0.192	0.089	0.197
16	0.041	0.126	0.143	0.135	0.124	0.030	0.172
17	0.026	0.026	0.023	0.020	0.026	0.031	0.151
18	0.030	0.029	0.020	0.018	0.024	0.026	0.130
19	0.024	0.024	0.037	0.056	0.018	0.018	0.163
20	0.016	0.023	0.020	0.027	0.024	0.029	0.183
21	0.029	0.036	0.020	0.031	0.020	0.031	0.078
22	0.045	0.029	0.061	0.029	0.029	0.019	0.067
23	0.020	0.039	0.023	0.043	0.075	0.024	0.123
24	0.016	0.036	0.019	0.032	0.021	0.034	0.102
25	0.034	0.020	0.020	0.018	0.020	0.032	0.065
26	0.020	0.038	0.025	0.040	0.021	0.035	0.135
27	0.020	0.020	0.030	0.018	0.026	0.030	0.079
28	0.019	0.019	0.027	0.021	0.051	0.067	0.199
29	0.164	0.141	0.140	0.015	0.026	0.300	0.092
30	0.032	0.026	0.026	0.092	0.049	0.037	0.092
31	0.019	0.018	0.017	0.021	0.019	0.020	0.024

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No
 All daily turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? (see back) Yes / No
 All Cl2 residual at entry point Yes / No

Notes:

PRINTED NAME: *Tina Lyda*

SIGNATURE: *Tina Lyda*

PHONE #: ()

DATE: 5-2-22

CERT #: 1657

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A
 Disinfection
 Giardia Log
 Location: 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Jan-21	Disinfection Giardia Log Location:	0.5
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.16	140	162.4	10.7	7.51	22.4	Yes	162
2	8:30	1.04	140	145.6	11.5	7.52	21.1	Yes	146
3	8:30	0.97	140	135.8	10.7	7.53	22.1	Yes	135
4	8:30	0.94	140	131.6	10.7	7.52	22.0	Yes	130
5	8:30	1.03	140	144.2	10.5	7.54	22.6	Yes	106
6	8:30	1.17	140	163.8	10.9	7.70	23.7	Yes	149
7	8:30	1.09	140	152.6	11.0	7.41	21.1	Yes	162
8	8:30	1.22	140	170.8	11.0	7.40	21.3	Yes	149
9	8:30	1.03	140	144.2	10.8	7.63	22.9	Yes	144
10	8:30	0.89	140	124.6	10.7	7.62	22.6	Yes	135
11	8:30	1.07	140	149.8	10.8	7.59	22.7	Yes	133
12	8:30	1.16	140	162.4	10.7	7.57	22.9	Yes	114
13	8:30	1.33	140	186.2	10.8	7.64	23.8	Yes	132
14	8:30	1.21	140	169.4	10.9	7.62	23.1	Yes	168
15	8:30	1.24	140	173.6	10.7	7.43	22.0	Yes	197
16	8:30	0.89	140	124.6	11.3	7.61	21.7	Yes	128
17	8:30	0.88	140	123.2	11.1	7.81	23.5	Yes	114
18	8:30	1.15	140	161.0	11.0	7.73	23.7	Yes	109
19	8:30	1.06	140	148.4	11.1	7.71	23.2	Yes	120
20	8:30	1.09	140	152.6	11.1	7.65	22.8	Yes	125
21	8:30	1.11	140	155.4	11.1	7.63	22.7	Yes	221
22	8:30	1.17	140	163.8	11.1	7.59	22.5	Yes	187
23	8:30	1.21	140	169.4	11.1	7.58	22.5	Yes	138
24	8:30	1.27	140	177.8	11.3	7.53	22.0	Yes	171
25	8:30	1.23	140	172.2	11.5	7.55	21.7	Yes	105
26	8:30	1.21	140	169.4	11.5	7.57	21.8	Yes	119
27	8:30	1.18	140	165.2	11.5	7.75	23.2	Yes	136
28	8:30	1.1	140	154.0	11.3	7.70	22.9	Yes	164
29	8:30	1.31	140	183.4	11.9	7.72	22.7	Yes	186
30	8:30	1.1	140	154.0	11.6	7.73	22.7	Yes	186
31	8:30	1.1	140	154.0	11.5	7.70	22.6	Yes	128

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012