

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Feb-21

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.015	0.016	0.016	0.018	0.015	0.018	0.051
2	0.024	0.027	0.018	0.016	0.016	0.015	0.045
3	0.016	0.018	0.017	0.021	0.025	0.015	0.085
4	0.016	0.016	0.015	0.021	0.025	0.015	0.085
5	0.016	0.016	0.015	0.015	0.020	0.023	0.048
6	0.018	0.016	0.018	0.015	0.020	0.023	0.048
7	0.019	0.018	0.020	0.015	0.016	0.019	0.059
8	0.015	0.015	0.020	0.018	0.029	0.015	0.098
9	0.018	0.016	0.017	0.018	0.018	0.021	0.109
10	0.023	0.019	0.017	0.015	0.018	0.016	0.038
11	0.026	0.016	0.010	0.015	0.016	0.018	0.145
12	0.016	0.043	0.024	0.018	0.016	0.019	0.185
13	0.019	0.020	0.020	0.019	0.016	0.020	0.112
14	0.035	0.018	0.019	0.019	0.020	0.014	0.126
15	0.016	0.041	0.017	0.024	0.019	0.016	0.098
16	0.018	0.021	0.027	0.019	0.021	0.018	0.100
17	0.016	0.019	0.017	0.041	0.025	0.026	0.081
18	0.031	0.016	0.021	0.034	0.023	0.021	0.057
19	0.027	0.031	0.017	0.019	0.020	0.024	0.065
20	0.019	0.025	0.017	0.020	0.030	0.021	0.032
21	0.029	0.023	0.020	0.018	0.019	0.026	0.073
22	0.029	0.037	0.118	0.085	0.043	0.023	0.140
23	0.035	0.054	0.034	0.025	0.023	0.026	0.071
24	0.021	0.034	0.046	0.025	0.030	0.016	0.057
25	0.021	0.030	0.021	0.021	0.026	0.023	0.064
26	0.032	0.025	0.022	0.016	0.036	0.015	0.059
27	0.021	0.030	0.026	0.018	0.031	0.018	0.093
28	0.025	0.027	0.020	0.030	0.032	0.037	0.074
29	0.056	0.074	0.082	0.040	0.048	0.029	0.086
30	0.064	0.096	0.050	0.038	0.027	0.038	0.096
31	0.058	0.075	0.043	0.015	0.043	0.036	0.078

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes/No  
 All daily turbidity readings ≤ 1 NTU? Yes/No  
 All turbidity readings < IFE<sup>2</sup> triggers Yes/No

CT's met everyday? (see back) Yes/No  
 All Cl2 residual at entry point Yes/No

Notes:

PRINTED NAME: DAVID HANCOCK  
 SIGNATURE: [Signature] DATE: 8/11/2022  
 PHONE #: (503) 812-0322 CERT #: T-09183

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

971-241-7203

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A  
 Disinfection  
 Giardia Log  
 Reduction

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Jan-21	Disinfection Giardia Log Reduction	0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	8:30	1.20	140	168.0	12.6	7.70	21.2	Yes	180	
2	8:30	1.07	140	149.8	13.3	7.65	19.6	Yes	206	
3	8:30	1	140	140.0	12.6	7.70	20.7	Yes	225	
4	8:30	0.95	140	133.0	12.3	7.68	20.9	Yes	261	
5	8:30	0.97	140	135.8	12.5	7.71	20.8	Yes	218	
6	8:30	1.09	140	152.6	12.6	7.68	20.8	Yes	234	
7	8:30	1.14	140	159.6	13.0	7.73	20.7	Yes	188	
8	8:30	1.12	140	156.8	12.6	7.69	20.9	Yes	383	
9	8:30	0.98	140	137.2	12.8	7.76	20.8	Yes	264	
10	8:30	1.18	140	165.2	12.8	7.70	20.8	Yes	246	
11	8:30	1.3	140	182.0	12.8	7.71	21.2	Yes	294	
12	8:30	1.25	140	175.0	12.9	7.65	20.5	Yes	226	
13	8:30	1.1	140	154.0	13.1	7.68	20.1	Yes	229	
14	8:30	1.21	140	169.4	13.1	7.67	20.3	Yes	256	
15	8:30	1.23	140	172.2	12.9	7.66	20.5	Yes	251	
16	8:30	1.03	140	144.2	12.7	7.65	20.3	Yes	278	
17	8:30	1.15	140	161.0	12.9	7.65	20.3	Yes	271	
18	8:30	1.11	140	155.4	12.7	7.66	20.5	Yes	279	
19	8:30	1.07	140	149.8	12.6	7.70	20.9	Yes	265	
20	8:30	1.06	140	148.4	12.9	7.61	19.8	Yes	289	
21	8:30	0.99	140	138.6	12.8	7.70	20.4	Yes	240	
22	8:30	1.18	140	165.2	12.7	7.73	21.2	Yes	275	
23	8:30	1	140	140.0	13.0	7.74	20.5	Yes	245	
24	8:30	1.08	140	151.2	13.1	7.72	20.4	Yes	360	
25	8:30	0.95	140	133.0	12.9	7.74	20.5	Yes	261	
26	8:30	1	140	140.0	12.9	7.73	20.5	Yes	394	
27	8:30	1.1	140	154.0	12.9	7.73	20.8	Yes	262	
28	8:30	1.13	140	158.2	13.0	7.77	21.0	Yes	251	
29	8:30	1	140	140.0	13.0	7.58	19.3	Yes	243	
30	8:30	0.94	140	131.6	13.9	7.56	17.9	Yes	271	
31	8:30	1.09	140	152.6	13.9	7.63	18.7	Yes	261	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012