



System Name: Netarts Water District		ID#: 41		00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.053	0.089	0.069	0.092	0.082	0.064	0.136
2	0.111	0.104	0.066	0.090	0.086	0.046	0.120
3	0.084	0.091	0.059	0.161	0.122	0.098	0.175
4	0.107	0.101	0.067	0.023	0.062	0.098	0.166
5	0.097	0.103	0.058	0.091	0.092	0.043	0.119
6	0.081	0.103	0.052	0.091	0.053	0.089	0.134
7	0.100	0.026	0.055	0.067	0.065	0.082	0.113
8	0.060	0.124	0.069	0.080	0.115	0.084	0.124
9	0.057	0.106	0.020	0.102	0.091	0.114	0.125
10	0.074	0.115	0.082	0.084	0.070	0.093	0.140
11	0.126	0.140	0.092	0.103	0.111	0.057	0.140
12	0.126	0.122	0.083	0.090	0.080	0.045	0.218
13	0.108	0.111	0.083	0.267	0.075	0.062	0.267
14	0.103	0.109	0.066	0.095	0.049	0.101	0.123
15	0.115	0.091	0.070	0.104	0.081	0.080	0.265
16	0.106	0.086	0.107	0.073	0.111	0.111	0.139
17	0.084	0.147	0.106	0.064	0.054	0.085	0.148
18	0.093	0.126	0.076	0.124	0.118	0.124	0.134
19	0.139	0.134	0.092	0.053	0.063	0.085	0.133
20	0.074	0.073	0.118	0.092	0.093	0.071	0.134
21	0.071	0.115	0.088	0.064	0.103	0.063	0.156
22	0.106	0.063	0.065	0.079	0.067	0.135	0.181
23	0.114	0.106	0.087	0.064	0.069	0.113	0.133
24	0.109	0.068	0.024	0.069	0.075	0.084	0.161
25	0.119	0.120	0.116	0.109	0.084	0.101	0.199
26	0.080	0.109	0.037	0.024	0.040	0.025	0.125
27	0.025	0.054	0.029	0.137	0.124	0.145	0.229
28	0.229	PO	0.238	0.190	0.155	0.144	0.289
29	0.173	0.062	0.094	0.057	0.034	0.023	0.181
30							
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU?  Yes /  No  
 All daily turbidity readings ≤ 1 NTU?  Yes /  No  
 All turbidity readings < IFE<sup>2</sup> triggers  Yes /  No

CT's met everyday? (see back)

Yes /  No

All Cl<sub>2</sub> residual at entry point

Yes /  No

Notes:

PRINTED NAME: DAVID B HANCOCK

SIGNATURE: *David Hancock*

DATE: 10/5/22

PHONE #: (503) 812 0322

CERT #:

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

T-09183  
D-09449

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Netarts Water District							ID#: 41		00556		Month/Year: Jan-21		Disinfection Giardia Log		0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow							
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]							
1	8:30	1.12	140	156.8	13.1	7.69	20.2	Yes	255							
2	8:30	0.98	140	137.2	13.2	7.62	19.3	Yes	327							
3	8:30	1.07	140	149.8	13.3	7.77	20.4	Yes	224							
4	8:30	1.06	140	148.4	13.1	7.78	20.8	Yes	237							
5	8:30	1.01	140	141.4	13.1	7.80	20.8	Yes	269							
6	8:30	0.96	140	134.4	12.7	7.78	21.1	Yes	357							
7	8:30	0.95	140	133.0	12.6	7.64	20.1	Yes	217							
8	8:30	1.02	140	142.8	12.9	7.69	20.3	Yes	288							
9	8:30	0.96	140	134.4	12.5	7.61	20.1	Yes	357							
10	8:30	1.06	140	148.4	13.3	7.46	18.2	Yes	302							
11	8:30	0.93	140	130.2	13.1	7.45	18.1	Yes	259							
12	8:30	0.84	140	117.6	13.2	7.46	17.9	Yes	227							
13	8:30	0.91	140	127.4	13.1	7.43	17.9	Yes	243							
14	8:30	1.02	140	142.8	13.3	7.52	18.6	Yes	296							
15	8:30	1.08	140	151.2	13.1	7.45	18.4	Yes	195							
16	8:30	1.04	140	145.6	12.9	7.50	18.9	Yes	305							
17	8:30	1.06	140	148.4	12.9	7.57	19.5	Yes	246							
18	8:30	1.05	140	147.0	12.7	7.56	19.60	Yes	346							
19	8:30	1.14	140	159.6	12.5	7.59	20.3	Yes	289							
20	8:30	1.1	140	154.0	12.5	7.77	21.6	Yes	250							
21	8:30	0.88	140	123.2	12.6	7.60	19.7	Yes	183							
22	8:30	1	140	140.0	12.5	7.60	20.1	Yes	233							
23	8:30	1.1	140	154.0	12.6	7.64	20.5	Yes	292							
24	8:30	0.97	140	135.8	12.8	7.65	20.0	Yes	303							
25	8:30	1.07	140	149.8	13.1	7.63	19.7	Yes	277							
26	8:30	0.96	140	134.4	14.1	7.63	18.2	Yes	347							
27	8:30	1.27	140	177.8	12.6	7.62	20.7	Yes	275							
28	8:30	1.12	140	156.8	12.5	7.61	20.4	Yes	259							
29	8:30	1	140	140.0	12.6	7.62	20.1	Yes	263							
30	8:30	0.73	140	102.2	12.6	7.64	19.6	Yes	282							
31	8:30		140	0.0			4.2									

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012