

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: October 2022

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.029	0.037	0.047	0.023	0.029	0.029	0.090
2	0.040	0.020	0.022	0.020	0.023	0.021	0.032
3	0.025	0.031	0.030	0.037	0.016	0.015	0.158
4	0.032	0.018	0.030	0.026	0.031	0.024	0.142
5	0.032	0.029	0.025	0.019	0.018	0.018	0.086
6	0.027	0.026	0.036	0.020	0.014	0.016	0.173
7	0.023	0.025	0.044	0.174	0.016	0.018	0.174
8	0.019	0.026	0.025	0.036	0.016	0.016	0.201
9	0.018	0.019	0.041	0.038	0.036	0.038	0.128
10	0.016	0.018	0.019	0.023	0.025	0.034	0.058
11	0.043	0.032	0.015	0.020	0.020	0.021	0.086
12	0.036	0.030	0.047	0.037	0.018	0.016	0.086
13	0.024	0.020	0.047	0.036	0.090	0.036	0.117
14	0.019	0.018	0.020	0.023	0.025	0.025	0.217
15	0.037	0.227	0.028	0.080	0.035	0.034	0.228
16	0.038	0.043	0.040	0.029	0.023	0.023	0.071
17	0.021	0.025	0.039	0.040	0.019	0.018	0.161
18	0.019	0.019	0.023	0.049	0.034	0.058	0.079
19	0.029	0.024	0.022	0.025	0.025	0.031	0.068
20	0.045	0.034	0.025	0.020	0.021	0.023	0.225
21	0.024	0.032	0.034	0.118	0.100	0.091	0.232
22	0.092	0.090	0.261	0.091	0.092	0.090	0.262
23	0.090	0.090	0.040	0.049	0.027	0.051	0.255
24	0.020	0.021	0.144	0.210	0.157	0.153	0.251
25	0.125	0.135	0.192	0.156	0.185	0.219	0.227
26	PO	PO	0.233	0.238	0.194	0.247	0.283
27	0.126	0.153	0.209	0.240	0.152	0.152	0.244
28	0.026	0.139	PO	PO	PO	0.199	0.226
29	0.186	0.192	0.192	0.126	0.140	0.115	0.192
30	0.135	0.139	0.073	0.085	0.091	0.075	0.184
31	0.159	0.153	PO	PO	PO	PO	0.233

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No
 All daily turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point Yes / No

Notes:

PRINTED NAME: DAVID HANCOCK
 SIGNATURE: *David Hancock*
 PHONE #: (503) 812-0322

DATE: 11/2/2022
 CERT #: D-09449
 T-09183

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A
 Disinfection
 Giardia Log
 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: October 2022			
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.07	140	149.8	12.6	7.70	20.9	Yes	285
2	8:30	1.1	140	154.0	12.6	7.68	20.8	Yes	346
3	8:30	1.28	140	179.2	12.7	7.70	21.2	Yes	285
4	8:30	1.23	140	172.2	13.3	7.71	20.4	Yes	258
5	8:30	1.18	140	165.2	12.5	7.73	21.5	Yes	237
6	8:30	1.10	140	154.0	12.4	7.75	21.7	Yes	259
7	8:30	1.06	140	148.4	12.4	7.73	21.4	Yes	237
8	8:30	1.14	140	159.6	12.2	7.70	21.7	Yes	255
9	8:30	1.19	140	166.6	12.2	7.70	21.8	Yes	198
10	8:30	1.06	140	148.4	15.5	7.69	17.1	Yes	165
11	8:30	1.25	140	175.0	12.1	7.77	22.6	Yes	223
12	8:30	1.17	140	163.8	12.2	7.74	22.0	Yes	163
13	8:30	1.08	140	151.2	12.1	7.73	21.9	Yes	168
14	8:30	1.06	140	148.4	12.3	7.73	21.6	Yes	167
15	8:30	1.11	140	155.4	12.4	7.72	21.5	Yes	215
16	8:30	1.09	140	152.6	12.4	7.72	21.4	Yes	215
17	8:30	1.09	140	152.6	12.4	7.73	21.5	Yes	218
18	8:30	1.12	140	156.8	12.4	7.74	21.6	Yes	177
19	8:30	1	140	140.0	12.4	7.73	21.3	Yes	160
20	8:30	1.09	140	152.6	12.4	7.70	21.2	Yes	157
21	8:30	1.16	140	162.4	12.3	7.70	21.6	Yes	166
22	8:30	1.02	140	142.8	12.1	7.71	21.6	Yes	177
23	8:30	0.86	140	120.4	12.0	7.66	21.0	Yes	196
24	8:30	1.03	140	144.2	11.9	7.66	21.5	Yes	190
25	8:30	0.89	140	124.6	11.6	7.62	21.3	Yes	139
26	8:30	0.73	140	102.2	11.6	7.72	21.7	Yes	141
27	8:30	0.75	140	105.0	11.2	7.62	21.5	Yes	150
28	8:30	0.94	140	131.6	11.5	7.64	21.7	Yes	152
29	8:30	0.96	140	134.4	11.6	7.50	20.6	Yes	169
30	8:30	1.19	140	166.6	11.5	7.52	21.4	Yes	176
31	8:30	0.46	140	64.4	13.1	7.58	18.0	Yes	144

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012