

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Dec-22

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.195	0.194	0.196	0.225	0.222	0.211	0.279
2	0.167	0.192	0.224	0.180	0.153	0.146	0.235
3	0.124	0.151	0.115	0.114	0.130	0.110	0.175
4	0.160	0.150	0.118	0.145	0.131	0.163	0.170
5	0.135	0.130	0.078	0.090	0.065	0.074	0.135
6	0.084	0.064	0.058	0.078	0.074	0.087	0.090
7	0.038	0.091	0.074	0.067	0.047	0.042	0.180
8	0.042	0.041	PO	PO	0.242	0.208	0.290
9	0.172	0.148	0.085	0.123	0.140	0.169	0.288
10	PO	PO	0.240	0.234	0.230	0.230	0.271
11	PO	PO	0.215	0.247	0.212	0.202	0.277
12	0.079	0.201	0.173	0.179	0.230	0.158	0.294
13	0.146	0.263	0.155	0.124	0.126	0.126	0.263
14	0.102	0.124	0.109	0.115	0.082	0.071	0.162
15	0.059	0.054	0.048	0.040	0.043	0.035	0.069
16	0.031	0.034	0.031	0.030	0.067	0.027	0.122
17	0.026	0.026	0.029	0.030	0.030	0.074	0.200
18	0.021	0.023	0.024	0.051	0.051	0.113	0.157
19	0.031	0.025	0.028	0.027	0.037	0.032	0.164
20	0.019	0.020	0.021	0.059	0.112	0.137	0.168
21	0.168	0.161	0.167	0.109	0.076	0.060	0.191
22	0.030	0.032	0.031	0.030	0.026	0.018	0.052
23	0.020	0.032	0.046	0.070	0.117	0.157	0.169
24	0.106	0.131	0.116	0.064	PO	PO	0.294
25	PO	PO	PO	0.090	0.010	0.032	0.263
26	0.035	0.035	0.047	PO	PO	PO	0.047
27	PO	PO	PO	PO	PO	0.035	0.201
28	0.010	0.032	0.037	0.206	0.194	0.212	0.244
29	0.097	0.047	0.094	0.097	0.128	PO	0.222
30	PO	PO	0.205	0.190	0.156	0.153	0.223
31	0.159	0.156	0.145	0.142	0.141	0.128	0.175

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No
 All daily turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point Yes / No

Notes:

PRINTED NAME: DAVID HANCOCK
 SIGNATURE: *David Hancock* DATE: 01/04/2023
 PHONE #: (503) 812-0322 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

T 09183
 D 09449

OHA - Drinking Water Program - Surface Water Quality Data Form

Dec 2022

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Jan 21	Disinfection Giardia Log Location	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.36	140	190.4	9.3	7.43	24.5	Yes	124
2	8:30	1.06	140	148.4	9.0	7.41	24.0	Yes	168
3	8:30	0.83	140	116.2	8.8	7.49	24.3	Yes	148
4	8:30	1.01	140	141.4	8.8	7.58	25.6	Yes	205
5	8:30	1.03	140	144.2	9.1	7.53	24.7	Yes	134
6	8:30	1.62	140	226.8	8.8	7.55	27.2	Yes	123
7	8:30	1.5	140	210.0	8.9	7.63	27.4	Yes	152
8	8:30	1.47	140	205.8	8.9	7.59	27.0	Yes	143
9	8:30	1.13	140	158.2	9.1	7.34	23.4	Yes	125
10	8:30	1.16	140	162.4	9.1	7.35	23.6	Yes	150
11	8:30	1.08	140	151.2	9.2	7.38	23.4	Yes	161
12	8:30	0.78	140	109.2	9.3	7.36	22.3	Yes	141
13	8:30	0.77	140	107.8	9.2	7.49	23.5	Yes	186
14	8:30	0.8	140	112.0	9.3	7.59	24.3	Yes	124
15	8:30	0.98	140	137.2	8.9	7.53	24.9	Yes	148
16	8:30	1.16	140	162.4	8.9	7.60	26.1	Yes	173
17	8:30	1.23	140	172.2	8.9	7.67	27.0	Yes	150
18	8:30	1.34	140	187.6	8.8	7.69	27.7	Yes	162
19	8:30	1.1	140	154.0	8.9	7.73	27.2	Yes	122
20	8:30	1.36	140	190.4	9.0	7.76	28.1	Yes	142
21	8:30	1.29	140	180.6	8.6	7.64	27.4	Yes	136
22	8:30	1.27	140	177.8	8.0	7.77	29.9	Yes	142
23	8:30	1.36	140	190.4	8.1	7.75	29.8	Yes	163
24	8:30	1.18	140	165.2	8.9	7.70	27.1	Yes	159
25	8:30	1.21	140	169.4	9.0	7.79	27.9	Yes	137
26	8:30	1	140	140.0	9.5	7.40	22.9	Yes	140
27	8:30	0.87	140	121.8	9.4	7.42	22.9	Yes	152
28	8:30	0.71	140	99.4	9.6	7.42	22.2	Yes	139
29	8:30	0.84	140	117.6	9.7	7.55	23.4	Yes	145
30	8:30	0.94	140	131.6	9.7	7.59	24.0	Yes	137
31	8:30	1.03	140	144.2	9.8	7.56	23.9	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012