

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Feb-23

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.015	0.015	0.023	0.019	0.020	0.029	0.076
2	0.015	0.015	0.016	0.016	0.019	0.023	0.079
3	0.020	0.026	0.020	0.016	0.015	0.097	0.133
4	0.120	0.120	0.126	0.107	0.049	0.045	0.141
5	0.021	0.023	0.107	0.089	0.118	0.108	0.158
6	0.155	0.158	0.151	0.111	0.131	0.109	0.166
7	0.054	0.080	0.048	0.126	0.118	0.117	0.129
8	0.122	0.096	0.054	0.036	0.035	0.025	0.125
9	0.024	0.023	0.025	0.025	0.024	0.025	0.048
10	0.024	0.027	0.023	0.019	0.023	0.034	0.053
11	0.020	0.024	0.025	0.020	0.019	0.016	0.063
12	0.020	0.018	0.021	0.021	0.023	0.018	0.097
13	0.023	0.023	0.068	0.026	0.026	0.036	0.098
14	0.030	0.025	0.023	0.062	0.068	PO	0.085
15	PO	PO	0.060	0.057	0.029	0.018	0.147
16	0.016	0.016	0.018	0.036	0.032	0.018	0.107
17	0.016	0.021	0.019	0.023	0.018	0.037	0.092
18	0.015	0.015	0.024	0.038	0.102	0.108	0.135
19	0.058	0.040	0.023	0.036	0.036	0.183	0.183
20	0.179	0.178	0.096	0.157	0.141	0.136	0.173
21	0.229	0.195	0.169	0.142	0.146	0.139	0.221
22	0.112	0.151	0.115	0.062	0.130	0.139	0.220
23	0.105	0.040	0.052	0.052	0.052	0.032	0.161
24	0.036	0.033	0.035	0.026	0.037	0.037	0.137
25	0.023	0.021	0.034	0.056	0.020	0.023	0.087
26	0.025	0.026	0.153	0.202	0.178	0.169	0.269
27	0.163	0.135	0.134	0.173	0.134	0.128	0.202
28	0.129	0.125	0.120	0.111	0.169	0.170	0.240
29							
30							
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? **4**
 All daily turbidity readings ≤ 1 NTU? **Yes/No**
 All turbidity readings < IFE² triggers **Yes/No**

CT's met everyday? - (see back) **Yes/No**
 All Cl2 residual at entry point **Yes/No**

Notes: PRINTED NAME: DAVID HANCOCK
 SIGNATURE: *David Hancock* DATE: 3/1/2023
 PHONE #: (971) 241 7203 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

D-09449
T-09183

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: FEB-23	Disinfection Giardia Log Location	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.21	140	169.4	9.6	7.57	24.8	Yes	113
2	8:30	1.2	140	168.0	8.9	7.58	26.0	Yes	124
3	8:30	1.21	140	169.4	8.9	7.46	25.0	Yes	113
4	8:30	1.2	140	168.0	8.9	7.40	24.4	Yes	130
5	8:30	1.03	140	144.2	9.3	7.49	24.1	Yes	146
6	8:30	1.29	140	180.6	9.3	7.46	24.5	Yes	114
7	8:30	1.02	140	142.8	9.3	7.52	24.3	Yes	109
8	8:30	1	140	140.0	9.2	7.55	24.7	Yes	173
9	8:30	1.02	140	142.8	9.2	7.61	25.3	Yes	109
10	8:30	1.08	140	151.2	9.4	7.52	24.3	Yes	120
11	8:30	1.11	140	155.4	9.4	7.58	24.9	Yes	141
12	8:30	1.03	140	144.2	9.4	7.62	25.0	Yes	162
13	8:30	1.15	140	161.0	10.7	7.59	23.0	Yes	109
14	8:30	1.15	140	161.0	9.3	7.50	24.5	Yes	111
15	8:30	1.00	140	140.0	9.4	7.58	24.6	Yes	118
16	8:30	1.14	140	159.6	9.1	7.60	25.7	Yes	114
17	8:30	1.21	140	169.4	9.1	7.56	25.5	Yes	152
18	8:30	1.25	140	175.0	9.1	7.51	25.2	Yes	166
19	8:30	1.18	140	165.2	9.1	7.54	25.3	Yes	186
20	8:30	1.16	140	162.4	9.2	7.42	24.0	Yes	165
21	8:30	1.08	140	151.2	9.3	7.52	24.5	Yes	112
22	8:30	0.93	140	130.2	9.2	7.55	24.5	Yes	105
23	8:30	0.89	140	124.6	9.0	7.50	24.3	Yes	111
24	8:30	0.99	140	138.6	8.5	7.55	25.8	Yes	253
25	8:30	1.10	140	154.0	8.4	7.61	26.9	Yes	207
26	8:30	1.14	140	159.6	8.2	7.58	27.1	Yes	184
27	8:30	1	140	140.0	8.2	7.44	25.4	Yes	138
28	8:30	0.93	140	130.2	7.9	7.43	25.6	Yes	127
29	8:30		140	0.0			4.2		
30	8:30		140	0.0			4.2		
31	8:30		140	0.0			4.2		

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012