

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.025	0.025	0.027	0.025	0.024	0.027	0.117
2	0.031	0.030	0.028	0.024	0.023	0.026	0.057
3	0.027	0.026	0.030	0.023	0.023	0.029	0.087
4	0.030	0.029	0.026	0.025	0.026	0.029	0.089
5	0.037	0.026	0.025	0.015	0.034	0.025	0.064
6	0.024	0.024	0.027	0.034	0.040	0.021	0.046
7	0.021	0.024	0.028	0.025	0.023	0.023	0.041
8	0.025	0.025	0.027	0.021	0.020	0.019	0.046
9	0.021	0.021	0.025	0.029	0.019	0.020	0.089
10	0.029	0.021	0.092	0.029	0.021	0.021	0.035
11	0.023	0.025	0.023	0.021	0.020	0.025	0.109
12	0.023	0.023	0.023	0.032	0.032	0.031	0.063
13	0.030	0.026	0.043	0.043	0.048	0.037	0.073
14	0.032	0.046	0.036	0.027	0.048	0.034	0.074
15	0.027	0.026	0.026	0.031	0.029	0.024	0.062
16	0.024	0.024	0.170	0.035	0.025	0.025	0.170
17	0.021	0.024	0.029	0.023	0.025	0.023	0.046
18	0.023	0.024	0.024	0.035	0.038	0.070	0.086
19	0.068	0.034	0.024	0.024	0.034	0.021	0.068
20	0.021	0.023	0.026	0.045	0.027	0.015	0.065
21	0.021	0.023	0.024	0.023	0.026	0.020	0.059
22	0.021	0.021	0.027	0.024	0.021	0.025	0.056
23	0.021	0.023	0.018	0.018	0.024	0.021	0.035
24	0.029	0.021	0.022	0.024	0.020	0.020	0.034
25	0.024	0.030	0.023	0.023	0.024	0.024	0.100
26	0.031	0.029	0.030	0.023	0.021	0.027	0.129
27	0.025	0.024	0.023	0.025	0.030	0.034	0.068
28	0.076	0.029	0.028	0.030	0.025	0.031	0.076
29	0.042	0.035	0.026	0.026	0.029	0.046	0.157
30	0.043	0.029	0.026	0.031	0.029	0.031	0.075
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes/No
 All daily turbidity readings ≤ 1 NTU? Yes/No
 All turbidity readings < IFE² triggers Yes/No

CT's met everyday? (see back) Yes/No
 All Cl₂ residual at entry point Yes/No

Notes:

PRINTED NAME: DAVID HANKO
 SIGNATURE: David Hanko DATE: 7/5/2023
 PHONE #: (503) 842-0322 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

T-09183
 D-09449

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Jun-23	Disinfection Giardia Log	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.14	140	159.6	11.4	7.80	23.7	Yes	313
2	8:30	1.08	140	151.2	11.4	7.74	23.0	Yes	216
3	8:30	1.14	140	159.6	11.4	7.83	23.9	Yes	236
4	8:30	1.12	140	156.8	11.4	7.75	23.2	Yes	261
5	8:30	1.13	140	158.2	11.6	7.75	22.9	Yes	204
6	8:30	1.09	140	152.6	11.4	7.70	22.7	Yes	273
7	8:30	1.19	140	166.6	12.4	7.73	21.7	Yes	211
8	8:30	1.22	140	170.8	11.6	7.71	22.8	Yes	176
9	8:30	1.24	140	173.6	11.6	7.76	23.3	Yes	215
10	8:30	1.18	140	165.2	12.2	7.79	22.5	Yes	354
11	8:30	1.09	140	152.6	12.4	7.76	21.7	Yes	277
12	8:30	1.29	140	180.6	11.6	7.69	22.8	Yes	255
13	8:30	1.19	140	166.6	11.8	7.81	23.3	Yes	246
14	8:30	1.00	140	140.0	11.6	7.75	22.6	Yes	245
15	8:30	1.07	140	149.8	11.8	7.72	22.2	Yes	249
16	8:30	1.16	140	162.4	11.8	7.73	22.5	Yes	225
17	8:30	1.05	140	147.0	11.7	7.77	22.7	Yes	220
18	8:30	1.10	140	154.0	11.8	7.71	22.2	Yes	189
19	8:30	1.09	140	152.6	11.8	7.71	22.2	Yes	179
20	8:30	1.14	140	159.6	11.7	7.73	22.6	Yes	165
21	8:30	1.10	140	154.0	11.6	7.70	22.4	Yes	188
22	8:30	1.11	140	155.4	11.8	7.76	22.6	Yes	230
23	8:30	1.18	140	165.2	11.8	7.65	22.0	Yes	231
24	8:30	1.18	140	165.2	11.7	7.75	22.9	Yes	236
25	8:30	1.10	140	153.7	11.8	7.79	22.9	Yes	233
26	8:30	1.15	140	161.0	11.9	7.80	22.9	Yes	220
27	8:30	1.14	140	159.6	14.4	7.64	18.3	Yes	266
28	8:30	1.24	140	173.6	12.1	7.58	21.1	Yes	226
29	8:30	1.08	140	151.2	12.0	7.62	21.2	Yes	264
30	8:30	1.17	140	163.8	12.4	7.68	21.3	Yes	229
31	8:30		140	0.0					

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012