

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: July 23

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.034	0.030	0.029	0.035	0.031	0.027	0.059
2	0.026	0.027	0.027	0.123	0.085	0.075	0.150
3	0.076	0.054	0.046	0.021	0.023	0.016	0.213
4	0.018	0.018	0.023	0.036	0.184	0.016	0.162
5	0.019	0.046	0.059	0.031	0.016	0.018	0.185
6	0.024	0.024	0.036	0.027	0.045	0.020	0.100
7	0.020	0.021	0.025	0.032	0.098	0.018	0.103
8	0.018	0.021	0.033	0.025	0.032	0.019	0.103
9	0.018	0.018	0.022	0.018	0.036	0.049	0.198
10	0.018	0.018	0.020	0.024	0.042	0.026	0.274
11	0.020	0.019	0.022	0.026	0.024	0.027	0.175
12	0.018	0.019	0.021	0.023	0.034	0.042	0.197
13	0.019	0.018	0.025	0.025	0.036	0.019	0.056
14	0.019	0.019	0.023	0.030	0.027	0.020	0.145
15	0.025	0.025	0.026	0.037	0.019	0.021	0.156
16	0.029	0.027	0.040	0.020	0.020	0.023	0.203
17	0.031	0.020	0.021	0.045	0.067	0.037	0.203
18	0.035	0.035	0.023	0.024	0.027	0.030	0.200
19	0.027	0.020	0.021	0.030	0.027	0.029	0.185
20	0.021	0.020	0.025	0.030	0.037	0.035	0.118
21	0.029	0.027	0.037	0.049	0.031	0.025	0.085
22	0.025	0.025	0.062	0.027	0.030	0.025	0.207
23	0.026	0.025	0.027	0.020	0.032	0.030	0.041
24	0.025	0.026	0.029	0.053	0.029	0.031	0.200
25	0.184	0.161	0.114	0.085	0.062	0.047	0.206
26	0.041	0.052	0.017	0.029	0.029	0.029	0.069
27	0.041	0.034	0.026	0.026	0.031	0.038	0.051
28	0.040	0.038	0.017	0.025	0.027	0.032	0.059
29	0.026	0.027	0.028	0.027	0.034	0.025	0.082
30	0.024	0.024	0.031	0.027	0.026	0.023	0.074
31	0.025	0.043	0.025	0.024	0.030	0.035	0.122

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 0.3 NTU? Yes/No
 All daily turbidity readings \leq 1 NTU? Yes/No
 All turbidity readings < IFE² triggers Yes/No

CT's met everyday? (see back) Yes/No
 All Cl₂ residual at entry point Yes/No

Notes:

PRINTED NAME: David Harlock
 SIGNATURE: *David Harlock* DATE: 8/3/2023
 PHONE #: (503) 812-0322 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

T = 09183
 D = 09449

41-0055C

July 2023

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: June 2023 July	Disinfection Giardia Log Location:	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:30	1.22	140	170.8	11.4	7.73	23.3	Yes	286
2	8:30	1.24	140	173.6	11.6	7.66	22.5	Yes	295
3	8:30	1.31	140	183.4	12.1	7.65	21.8	Yes	315
4	8:30	1.24	140	173.6	12.6	7.73	21.5	Yes	274
5	8:30	1.14	140	159.6	12.4	7.76	21.8	Yes	263
6	8:30	1.12	140	156.8	12.3	7.62	20.9	Yes	286
7	8:30	1.04	140	145.6	12.3	7.63	20.8	Yes	249
8	8:30	1.07	140	149.8	12.3	7.60	20.6	Yes	273
9	8:30	0.98	140	137.2	12.2	7.67	21.1	Yes	257
10	8:30	1.02	140	142.8	12.4	7.70	21.1	Yes	286
11	8:30	1.14	140	159.6	12.3	7.78	22.1	Yes	258
12	8:30	1.19	140	166.6	12.5	7.77	21.8	Yes	251
13	8:30	1.41	140	197.4	12.6	7.77	22.2	Yes	226
14	8:30	1.32	140	184.8	12.5	7.81	22.5	Yes	278
15	8:30	1.46	140	204.1	12.6	7.77	22.4	Yes	285
16	8:30	1.19	140	166.6	13.1	7.81	21.3	Yes	257
17	8:30	1.19	140	166.6	12.8	7.76	21.3	Yes	281
18	8:30	0.98	140	137.2	12.8	7.76	20.8	Yes	277
19	8:30	0.97	140	135.8	13.1	7.79	20.6	Yes	248
20	8:30	1.04	140	145.6	12.9	7.79	21.1	Yes	241
21	8:30	1.21	140	169.4	12.8	7.79	21.6	Yes	211
22	8:30	1.12	140	156.8	12.8	7.80	21.5	Yes	207
23	8:30	1.18	140	165.2	13.0	7.87	21.9	Yes	269
24	8:30	1.35	140	189.0	12.9	7.81	22.0	Yes	293
25	8:30	1.30	140	182.0	12.8	7.82	22.1	Yes	354
26	8:30	1.19	140	166.6	12.7	7.82	22.0	Yes	306
27	8:30	1.11	140	155.4	12.6	7.79	21.7	Yes	338
28	8:30	1.32	140	184.8	12.9	7.81	21.9	Yes	249
29	8:30	1.09	140	152.6	12.8	7.81	21.5	Yes	269
30	8:30	1.23	140	172.2	12.7	7.65	20.7	Yes	286
31	8:30	1.05	140	147.0	12.6	7.78	21.4	Yes	282

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012