

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Month/Year: Jan-24

Conventional or Direct Filtration

System Name:	Netarts Water District		ID#: 41	00556		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.024	0.024	0.050	0.060	0.032	0.023	0.107
2	0.021	0.020	0.028	0.027	0.040	0.051	0.075
3	0.019	0.018	0.056	0.048	0.076	0.026	0.155
4	0.021	0.020	0.155	0.161	0.258	P.O.	0.271
5	0.273	0.246	0.234	0.029	0.047	0.056	0.273
6	0.120	0.107	0.097	0.096	0.090	0.119	0.130
7	0.288	0.076	0.054	0.048	0.060	0.070	0.194
8	0.053	0.042	0.057	0.048	0.043	P.O.	0.335
9	P.O.	P.O.	P.O.	0.086	0.130	0.087	0.289
10	0.130	0.109	0.101	0.081	0.068	0.057	0.161
11	0.048	0.054	0.030	0.025	0.043	0.042	0.128
12	0.036	0.021	0.025	0.029	0.025	0.032	0.163
13	0.031	0.058	0.085	PO	PO	0.059	0.288
14	0.052	0.278	0.055	0.047	0.063	0.043	0.115
15	0.048	0.024	0.032	0.037	0.062	0.065	0.085
16	0.048	0.048	0.044	0.051	0.030	0.032	0.097
17	0.031	0.042	0.040	0.054	0.05PO9	0.123	0.202
18	0.163	0.174	0.281	0.203	0.056	0.118	0.280
19	0.043	0.040	0.064	0.031	0.021	0.053	0.249
20	0.075	0.045	0.052	0.032	0.034	0.040	0.283
21	0.283	0.244	0.047	0.058	0.053	0.118	0.283
22	0.096	0.222	0.160	0.163	0.153	0.158	0.291
23	0.170	0.134	0.251	0.164	0.079	0.062	0.200
24	0.045	0.042	0.158	0.156	0.053	0.046	0.225
25	0.064	0.059	0.059	0.058	0.059	0.155	0.236
26	0.035	0.032	0.039	0.034	0.119	0.062	0.288
27	0.058	0.115	PO	PO	PO	PO	PO
28	PO	PO	PO	0.025	0.029	0.118	0.278
29	0.046	0.048	0.070	0.031	0.035	0.024	0.278
30	0.024	0.025	0.227	0.037	0.024	0.027	0.273
31	0.036	0.027	0.035	0.037	0.023	0.023	0.208

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes/No
 All daily turbidity readings ≤ 1 NTU? Yes/No
 All turbidity readings < IFE² triggers Yes/No

CT's met everyday? (see back) Yes/No
 All Cl₂ residual at entry point Yes/No

Notes: PRINTED NAME: DAVID HANCOCK
 SIGNATURE: David Hancock DATE: 2/6/24
 PHONE #: (971) 241-7203 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

D-09449
T. 09183

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Jan-20	Disinfection Giardia Log Inactivation	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	10:00	1.22	140	170.8	5.4	7.75	35.2	Yes	178
2	8:30	1.27	140	0.0	5.3	7.55	33.1	Yes	115
3	9:45	1.33	140	186.2	5.3	7.57	33.6	Yes	99
4	9:15	1.23	140	172.2	5.3	7.68	34.6	Yes	100
5	9:15	1.18	140	165.2	5.3	7.56	32.9	Yes	115
6	9:15	1.10	140	154.0	5.2	7.62	33.5	Yes	125
7	9:15	1.10	140	154.0	5.2	7.55	32.7	Yes	140
8	9:00\	1.09	140	152.6	5.1	7.50	32.3	Yes	81
9	10:00	1.23	140	172.2	5.2	7.45	32.0	Yes	135
10	9:15	1.48	140	207.2	5.3	7.52	33.6	Yes	81
11	8:30	1.44	140	201.6	4.9	7.50	34.1	Yes	86
12	10:00	1.41	140	197.4	4.8	7.79	38.1	Yes	263
13	10:00	1.16	140	162.4	4.6	7.41	32.6	Yes	117
14	11:30	1.24	140	173.6	4.6	7.48	33.8	Yes	140
15	10:30	1.27	140	177.8	4.4	7.62	36.2	Yes	124
16	9:30	1.31	140	183.4	4.8	7.67	36.0	Yes	159
17	8:30	1.41	140	197.4	5.2	7.50	33.3	Yes	134
18	9:00\	1.41	140	197.4	3.8	7.62	38.3	Yes	108
19	9:00\	1.87	140	261.8	3.9	7.50	38.4	Yes	112
20	8:45	1.88	140	263.2	4.1	7.54	38.5	Yes	130
21	9:00\	1.16	140	162.4	4.2	7.52	34.9	Yes	135
22	9:20	1.59	140	222.6	4.4	7.40	34.6	Yes	117
23	9:20	1.51	140	211.4	4.4	7.95	42.0	Yes	125
24	9:00\	1.57	140	219.8	4.8	7.93	40.8	Yes	115
25	9:00\	1.54	140	215.6	4.8	8.05	42.5	Yes	113
26	9:15	1.34	140	187.6	5.3	8.09	40.7	Yes	95
27	11:15	1.10	140	154.0	5.4	8.14	40.0	Yes	142
28	10:00	1.00	140	140.0	5.1	8.05	39.1	Yes	142
29	9:15	0.99	140	138.6	5.4	7.85	35.5	Yes	132
30	9:15	1.00	140	140.0	5.9	7.77	33.4	Yes	141
31	8:30	1.03	140	144.2	5.5	7.98	37.2	Yes	107

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012