

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Feb-24

System Name:	Netarts Water District		ID#: 41	00556			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.026	0.021	0.031	0.024	0.021	0.027	0.198
2	0.025	0.021	0.034	0.021	0.030	0.019	0.142
3	0.019	0.024	0.023	0.019	0.019	0.019	0.038
4	0.020	0.024	0.020	0.019	0.019	0.200	0.078
5	0.019	0.019	0.022	0.021	0.027	0.019	0.047
6	0.020	0.019	0.025	0.019	0.018	0.021	0.146
7	0.020	0.019	0.028	0.024	0.023	0.019	0.144
8	0.019	0.024	0.028	0.047	0.025	0.021	0.293
9	0.021	0.021	0.027	0.026	0.025	0.020	0.051
10	0.019	0.019	0.022	0.021	0.032	0.025	0.148
11	0.027	0.021	0.020	0.023	0.021	0.023	0.144
12	0.019	0.019	0.021	0.102	0.019	0.021	0.152
13	0.019	0.018	0.022	0.023	0.023	0.020	0.035
14	0.020	0.029	0.020	0.029	0.030	0.026	0.273
15	0.234	0.238	0.273	0.234	0.238	0.245	0.277
16	0.147	0.238	0.035	0.030	0.048	0.034	0.076
17	0.035	0.036	0.082	0.038	0.026	0.024	0.106
18	0.025	0.025	0.024	0.050	0.029	0.031	0.060
19	0.023	0.023	0.026	0.020	0.026	0.020	0.159
20	0.045	0.140	0.045	0.024	0.021	0.024	0.203
21	0.019	0.026	0.024	0.021	0.030	0.021	0.112
22	0.079	0.098	0.026	0.027	0.032	0.020	0.146
23	0.020	0.023	0.077	0.029	0.023	0.020	0.178
24	0.020	0.020	0.025	0.023	0.025	0.020	0.178
25	0.024	0.023	0.020	0.021	0.020	0.082	0.244
26	0.297	0.295	0.138	0.109	0.076	0.057	0.276
27	0.051	0.112	0.123	0.046	0.172	0.175	0.258
28	0.201	0.202	0.370	off	off	off	off
29	off	off	off	0.041	0.035	0.038	0.233
30							
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU?  Yes /  No  
 All daily turbidity readings ≤ 1 NTU?  Yes /  No  
 All turbidity readings < IFE<sup>2</sup> triggers  Yes /  No

CT's met everyday? (see back)  Yes /  No  
 All Cl<sub>2</sub> residual at entry point  Yes /  No

Notes:

PRINTED NAME: DAVID Hanipczk  
 SIGNATURE: *David Hanipczk*  
 PHONE #: (971) 241-7203  
 DATE: 3/5/24  
 CERT #: D-09449

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

T-09183

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A  
 Disinfection  
 Giardia Log  
 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Feb-24	Giardia Log	0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	10:20	1.29	140	180.6	5.7	7.95	37.4	Yes	114	
2	9:00	1.41	140	197.4	5.5	7.82	36.7	Yes	118	
3	8:45	1.42	140	198.8	5.7	7.95	38.0	Yes	159	
4	9:00	1.49	140	208.6	5.4	7.93	38.8	Yes	164	
5	9:10	1.61	140	225.4	5.4	7.91	39.1	Yes	121	
6	9:00	1.47	140	205.8	5.3	7.91	38.7	Yes	166	
7	8:45	1.46	140	204.4	5.3	7.82	37.4	Yes	90	
8	9:15	1.44	140	160.2	5.3	7.91	38.6	Yes	84	
9	9:00	1.35	140	189.0	5.4	7.95	38.4	Yes	116	
10	11:00	0.94	140	131.6	5.7	7.95	35.9	Yes	117	
11	9:00	1.42	140	198.8	5.3	7.95	39.0	Yes	130	
12	9:10	1.42	140	198.8	5.1	7.91	39.0	Yes	94	
13	9:20	1.44	140	201.6	5.1	7.89	38.8	Yes	84	
14	9:05	1.35	140	189.0	5.1	7.82	37.4	Yes	90	
15	9:00	1.28	140	179.2	5.0	7.89	38.3	Yes	479	
16	8:45	1.19	140	166.6	5.3	7.87	36.9	Yes	109	
17	9:10	1.15	140	161.0	4.9	7.93	38.6	Yes	127	
18	8:55	1.13	140	158.2	4.8	7.93	38.8	Yes	150	
19	9:10	1.13	140	158.2	4.8	8.06	40.7	Yes	150	
20	8:45	1.10	140	154.0	4.9	7.99	39.2	Yes	99	
21	8:25	1.10	140	154.0	4.9	8.04	39.9	Yes	98	
22	9:40	1.08	140	151.2	5.1	7.93	37.7	Yes	207	
23	10:00	1.17	140	163.8	5.1	8.08	40.3	Yes	143	
24	3:00	1.10	140	154.0	5.1	7.86	36.9	Yes	143	
25	11:00	1.14	140	159.6	5.1	7.86	37.0	Yes	140	
26	9:00	1.15	140	161.0	5.1	7.81	36.4	Yes	194	
27	10:00	1.18	140	165.2	4.9	7.54	33.6	Yes	90	
28	8:35	1.10	140	154.0	4.9	7.65	34.6	Yes	86	
29	8:45	1.00	140	140.0	4.7	7.62	34.3	Yes		
30	8:30		140	0.0			4.2			
31	8:30		140	0.0			4.2			

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012