

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Mar-24

System Name:	Netarts Water District			ID#: 41	00556	WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.045	0.023	0.056	0.057	0.056	0.075	0.173
2	0.093	0.029	0.027	0.032	0.031	0.040	0.168
3	0.026	0.025	0.032	0.034	0.060	0.101	0.184
4	0.118	0.111	0.053	0.035	0.045	0.075	0.141
5	0.046	0.045	0.025	0.024	0.030	0.025	0.111
6	0.034	0.029	0.040	0.018	0.040	0.021	0.150
7	0.020	0.019	0.030	0.020	0.024	0.027	0.087
8	0.060	0.045	0.031	0.038	0.018	0.020	0.063
9	0.018	0.019	0.021	0.018	0.018	0.018	0.074
10	0.018	0.018	0.018	0.029	0.016	0.021	0.147
11	0.020	0.019	0.018	0.019	0.023	0.027	0.279
12	0.101	0.274	0.094	0.056	0.025	0.030	0.274
13	0.038	0.021	0.021	0.025	0.023	0.023	0.038
14	0.037	0.032	0.029	0.036	0.024	0.024	0.065
15	0.024	0.029	0.026	0.024	0.026	0.043	0.108
16	0.023	0.023	0.020	0.021	0.020	0.024	0.040
17	0.023	0.020	0.020	0.019	0.036	0.018	0.040
18	0.018	0.018	0.021	0.024	0.024	0.018	0.038
19	0.018	0.016	0.017	0.020	0.016	0.016	0.031
20	0.016	0.016	0.017	0.020	0.015	0.016	0.018
21	0.016	0.016	0.027	0.030	0.018	0.018	0.036
22	0.020	0.019	0.027	0.019	0.018	0.018	0.034
23	0.020	0.019	0.017	0.016	0.016	0.019	0.249
24	0.170	0.042	0.020	0.021	0.020	0.052	0.221
25	0.093	0.103	0.109	0.130	0.164	0.080	0.188
26	0.069	0.060	0.046	0.029	0.020	0.016	0.151
27	0.018	0.020	0.023	0.018	0.020	0.019	0.163
28	0.082	0.123	0.101	0.108	0.118	0.107	0.211
29	0.168	0.113	0.115	0.109	0.100	0.104	0.136
30	0.102	0.093	0.100	.048	0.025	0.029	0.145
31	0.021	0.021	0.020	0.024	0.021	0.019	0.043

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: DAVID HANLOCK	
		SIGNATURE:	DATE:
		PHONE #: (503) 842-9429	CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

David Hanlock

D-09449
T-09183

4/3/24

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A
 Disinfection
 Giardia Log
 Negative
 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Mar-24		
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	8:20	1.19	140	0.0	4.5	7.45	33.4	Yes	89
2	9:05	1.26	140	176.4	4.7	7.91	39.3	Yes	127
3	9:15	1.39	140	194.6	4.6	7.87	39.6	Yes	123
4	9:20	1.38	140	193.2	4.4	7.95	41.3	Yes	105
5	8:55	1.35	140	189.0	4.3	7.98	41.9	Yes	103
6	9:30	1.35	140	189.0	4.2	8.09	44.0	Yes	94
7	9:30	1.41	140	197.4	4.2	8.20	46.2	Yes	106
8	9:30	1.30	140	182.0	4.2	8.20	45.6	Yes	130
9	10:30	1.22	140	170.8	4.2	8.17	44.6	Yes	136
10	11:30	1.19	140	166.6	4.2	8.25	45.8	Yes	135
11	9:00	1.20	140	168.0	4.2	8.22	45.3	Yes	101
12	8:50	1.12	140	156.8	4.3	8.23	44.8	Yes	86
13	8:15	0.97	140	135.8	4.4	8.00	40.1	Yes	395
14	9:30	1.15	140	161.0	4.5	7.85	38.5	Yes	101
15	8:45	1.15	140	161.0	4.6	7.87	38.5	Yes	115
16	9:00	1.22	140	170.8	4.8	7.79	37.2	Yes	149
17	8:50	1.24	140	173.6	4.8	7.87	38.4	Yes	163
18	9:15	1.22	140	170.8	4.9	7.84	37.6	Yes	109
19	9:20	1.27	140	177.8	5.1	7.85	37.5	Yes	97
20	8:45	1.29	140	180.6	5.1	7.89	38.1	Yes	75
21	9:20	1.38	140	193.2	5.2	7.86	37.8	Yes	92
22	11:00	1.40	140	196.0	5.1	7.98	39.9	Yes	143
23	1:15	1.40	140	196.0	5.1	7.99	40.1	Yes	161
24	2:15	1.29	140	180.6	5.2	7.96	38.9	Yes	161
25	8:45	1.31	140	183.4	5.3	7.85	37.1	Yes	1487
26	9:00	1.24	140	173.6	5.3	7.85	36.8	Yes	136
27	9:40	1.01	140	141.4	5.3	7.93	36.9	Yes	219
28	10:20	1.04	140	145.6	5.3	8.06	38.9	Yes	154
29	8:30	0.85	140	119.0	5.3	8.05	37.9	Yes	163
30	9:15	0.83	140	116.2	5.4	8.03	37.2	Yes	169
31	8:50	0.76	140	106.4	5.3	8.04	37.3	Yes	157

if met, DWP to be notified by end of next business day.

Revised February 2012