

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Jun-24

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.020	0.020	0.023	0.019	0.019	0.018	0.078
2	0.029	0.024	0.069	0.074	0.096	0.200	0.278
3	PO	PO	0.273	0.222	0.196	0.092	0.233
4	0.153	0.155		0.091	0.048	0.092	0.160
5	0.087	0.040	0.091	0.035	0.037	0.041	0.195
6	0.040	0.058	0.028	0.053	0.067	0.062	0.205
7	0.030	0.027	0.068	0.029	0.067	0.026	0.183
8	0.063	0.148	0.031	0.057	0.053	0.156	0.156
9	0.029	0.030	0.058	0.018	0.024	0.016	0.066
10	0.018	0.019	0.022	0.021	0.020	0.016	0.278
11	0.018	0.019	0.051	0.016	0.016	0.016	0.158
12	0.016	0.018	0.018	0.016	0.016	0.016	0.076
13	0.018	0.016	0.019	0.019	0.023	0.018	0.058
14	0.016	0.018	0.023	0.013	0.021	0.018	0.134
15	0.021	0.062	0.023	0.019	0.041	0.020	0.128
16	0.018	0.018	0.020	0.019	0.018	0.019	0.200
17	0.192	0.174	0.030	0.018	0.029	0.020	0.192
18	0.034	0.018	0.022	0.019	0.021	0.016	0.053
19	0.016	0.018	0.022	0.021	0.018	0.018	0.035
20	0.018	0.018	0.019	0.018	0.018	0.019	0.070
21	0.019	0.019	0.022	0.023	0.019	0.018	0.071
22	0.018	0.019	0.020	0.019	0.016	0.023	0.071
23	0.020	0.020	0.024	0.020	0.018	0.023	0.052
24	0.023	0.019	0.027	0.036	0.024	0.040	0.114
25	0.029	0.018	0.018	0.016	0.026	0.016	0.049
26	0.018	0.037	0.020	0.016	0.016	0.016	0.070
27	0.016	0.018	0.054	0.018	0.019	0.034	0.036
28	0.018	0.018	0.019	0.021	0.018	0.038	0.107
29	0.085	0.082	0.057	0.060	0.018	0.018	0.092
30	0.020	0.020	0.027	0.016	0.018	0.025	0.065
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? **Yes/No**
 All daily turbidity readings ≤ 1 NTU? **Yes/No**
 All turbidity readings < IFE² triggers **Yes/No**

CT's met everyday? (see back) **Yes/No**
 All Cl2 residual at entry point **Yes/No**

Notes:

PRINTED NAME: DAVID Hancock

SIGNATURE: *David Hancock* DATE: 7/1/24

PHONE #: (503) 842-9405 CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns

¹ 12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

David Hancock

T-09183
D-09449

OHA - Drinking Water Program - Surface Water Quality Data Form

June 24

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Jun-24	Disinfection Log	Giardia Log	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	10:00	1.33	108	143.6	12.3	7.81	22.8	Yes	281	
2	9:00	1.24	108	133.9	12.6	7.71	21.3	Yes	143	
3	8:45	0.99	108	106.9	13.0	7.67	19.9	Yes	128	
4	8:30	0.88	108	95.0	12.7	7.67	20.1	Yes	128	
5	9:30	0.85	108	91.8	12.0	7.64	20.8	Yes	124	
6	2:15	0.70	108	75.6	13.9	7.62	17.8	Yes	126	
7	8:30	1.04	108	112.3	13.3	7.62	19.3	Yes	135	
8	9:30	1.01	108	109.1	14.0	7.60	18.2	Yes	156	
9	8:55	0.96	108	103.7	14.0	7.62	18.2	Yes	175	
10	9:05	0.99	108	106.9	14.1	7.57	17.8	Yes	158	
11	9:00	1.21	108	130.7	14.1	7.55	18.2	Yes	172	
12	9:00	1.16	108	125.3	14.2	7.57	18.0	Yes	143	
13	8:45	1.16	108	125.3	14.1	7.59	18.3	Yes	152	
14	9:00	1.18	108	127.4	13.4	7.59	19.2	Yes	176	
15	9:00	1.01	108	109.1	13.4	7.60	18.9	Yes	176	
16	10:48	0.96	108	103.7	12.9	7.59	19.4	Yes	167	
17	8:55	0.95	108	102.6	13.1	7.62	19.3	Yes	163	
18	17:55	1.22	108	131.8	13.9	7.59	18.7	Yes	144	
19	9:15	1.24	108	133.9	14.1	7.59	18.5	Yes	209	
20	8:50	1.21	108	130.7	14.2	7.60	18.4	Yes	160	
21	11:00	1.18	108	127.4	14.5	7.62	18.1	Yes	188	
22	16:30	1.18	108	127.4	14.7	7.60	17.7	Yes	337	
23	8:50	1.24	108	133.0	15.2	7.64	17.5	Yes	248	
24	7:10	1.15	108	124.2	15.1	7.60	17.2	Yes	247	
25	8:40	1.13	108	122.0	15.6	7.60	16.6	Yes	250	
26	15:40	1.10	108	118.8	14.9	7.59	17.3	Yes	240	
27	8:30	1.13	108	122.0	15.0	7.62	17.4	Yes	237	
28	18:30	1.13	108	122.0	15.0	7.62	17.4	Yes	263	
29	16:35	1.10	108	118.8	15.1	7.62	17.2	Yes	254	
30	11:00	1.06	108	114.5	15.2	7.62	17.0	Yes	356	
31	8:30		108	0.0			1.2			

it met, DWP to be notified by end of next business day.

Revised February 2012