

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Aug-24

System Name: Netarts Water District		ID#: 41		00556		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.096	0.080	0.065	0.054	0.058	0.048	0.254
2	0.042	0.102	0.032	0.062	0.047	0.038	0.078
3	0.062	0.048	0.047	0.038	0.047	0.046	0.075
4	0.043	0.056	0.049	0.047	0.043	0.043	0.145
5	0.034	0.041	0.041	0.029	0.026	0.034	0.058
6	0.023	0.029	0.039	0.035	0.030	0.034	0.060
7	0.025	0.026	0.026	0.023	0.029	0.027	0.078
8	0.040	0.040	0.028	0.024	0.030	0.026	0.063
9	0.026	0.026	0.025	0.027	0.023	0.027	0.029
10	0.021	0.023	0.033	0.023	0.023	0.030	0.033
11	0.024	0.024	0.029	0.350	0.180	0.052	0.056
12	0.042	0.036	0.021	0.037	0.035	0.041	0.051
13	0.030	0.030	0.027	0.024	0.027	0.025	0.058
14	0.027	0.030	0.026	0.024	0.024	0.029	0.043
15	0.027	0.040	0.030	0.024	0.024	0.202	0.202
16	0.029	0.023	0.031	0.027	0.025	0.026	0.197
17	0.047	0.040	0.031	0.480	0.118	0.164	0.244
18	0.168	0.163	0.042	0.092	0.078	0.085	0.219
19	0.097	0.103		0.054	0.063	0.038	0.107
20	0.029	0.030	0.027	0.031	0.035	0.047	0.075
21	0.027	0.072	0.050	0.035	0.034	0.029	0.059
22	0.032	0.029	0.095	0.070	0.079	0.078	0.136
23	0.060	0.060	0.060	0.078	0.047	0.034	0.081
24	0.034	0.034	0.027	0.027	0.046	0.034	0.103
25	0.037	0.038	0.047	0.031	0.018	0.038	0.060
26	0.032	0.030	0.038	0.027	0.027	0.045	0.051
27	0.038	0.031	0.052	0.065	0.071	0.038	0.078
28	0.043	0.034	0.038	0.031	0.035	0.041	0.078
29	0.047	0.045	0.026	0.026	0.030	0.038	0.146
30	0.047	0.046	0.039	0.030	0.036	0.031	0.056
31	0.034	0.032	0.038	0.031	0.030	0.021	0.087

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
Notes:			PRINTED NAME: DAVID HANCOCK	
			SIGNATURE:	DATE:
			PHONE #: ()	CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns

12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

David Hancock 9/2/24
 503-812-9405
 D- ~~915710~~ 09449
 T- ~~915710~~ 09183

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Aug-24	Disinfection Giardia Log Location	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	14:38	0.95	108	102.6	14.1	7.71	18.7	yes	233
2	09:40	1.02	108	110.2	14.5	7.71	18.4	yes	412
3	23:00	1.23	108	132.8	14.4	7.74	19.1	yes	264
4	13:24	1.15	108	124.2	15.1	7.76	18.2	yes	255
5	22:20	0.93	108	100.4	15.2	7.45	15.8	yes	296
6	23:50	1.05	108	113.4	14.2	7.69	18.7	yes	266
7	03:30	1.05	108	113.4	14.0	7.69	18.9	yes	266
8	23:10	1.00	108	108.0	14.5	7.72	18.4	yes	251
9	03:50	0.99	108	106.9	14.3	7.72	18.6	yes	243
10	23:45	1.27	108	137.2	14.9	7.77	18.8	yes	265
11	08:10	1.18	108	127.4	14.6	7.84	19.5	yes	283
12	02:20	0.99	108	106.9	14.1	7.76	19.1	yes	246
13	23:00	1.07	108	115.6	14.5	7.89	19.7	yes	245
14	14:00	0.91	108	98.3	14.1	7.77	19.0	yes	300
15	07:40	0.91	108	98.3	14.4	7.77	18.7	yes	361
16	11:58	1.16	108	125.3	15.1	7.86	18.9	yes	287
17	15:50	0.96	108	103.7	14.2	7.86	19.7	yes	268
18	15:32	0.85	108	91.8	14.7	7.53	16.6	yes	247
19	16:39	0.85	108	91.8	14.0	7.55	17.5	yes	226
20	12:34	1.14	108	123.1	14.5	7.55	17.5	yes	254
21	03:45	1.18	108	127.4	13.9	7.57	18.5	yes	254
22	22:50	1.23	108	132.8	14.0	7.59	18.6	yes	315
23	09:30	1.21	108	130.7	13.9	7.59	18.7	yes	250
24	23:45	1.08	108	116.6	13.8	7.62	18.7	yes	214
25	10:30	0.95	108	102.6	14.7	7.60	17.3	yes	264
26	10:00	0.94	108	101.5	13.5	7.55	18.3	yes	242
27	07:18	1.19	108	128.5	14.6	7.60	17.9	yes	425
28	20:30	1.16	108	125.3	14.6	7.62	17.9	yes	247
29	10:00	1.14	108	123.1	15.1	7.59	17.1	yes	385
30	10:00	1.13	108	122.0	15.0	7.62	17.4	yes	254
31	09:30	1.10	108	118.8	15.0	7.64	17.5	yes	241

³ met, DWP to be notified by end of next business day.

Revised February 2012