

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Sep-24

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.034	0.031	0.042	0.025	0.036	0.027	0.078
2	0.030	0.030	0.031	0.054	0.059	0.054	0.118
3	0.076	0.079	0.069	0.064	0.080	0.058	0.170
4	0.036	0.043	0.052	0.031	0.027	0.057	0.095
5	0.067	0.048	0.038	0.034	0.049	0.047	0.076
6	0.042	0.063	0.043	0.037	0.047	0.049	0.074
7	0.062	0.042	0.029	0.030	0.031	0.037	0.074
8	0.034	0.034	0.046	0.034	0.051	0.046	0.129
9	0.058	0.058	0.047	0.019	0.029	0.021	0.076
10	0.021	0.021	0.029	0.021	0.021	0.020	0.177
11	0.026	0.027	P.O.	P.O.	P.O.	0.211	0.613
12	0.186	0.218	0.205	0.152	0.146	0.100	0.241
13	0.040	0.030	0.022	0.020	0.020	0.020	0.086
14	0.019	0.020	0.020	0.020	0.026	0.024	0.051
15	0.023	0.021	0.022	0.020	0.021	0.020	0.073
16	0.019	0.020	0.021	0.019	0.027	0.026	0.098
17	0.018	0.019	0.024	0.019	0.019	0.093	0.095
18	0.092	0.115	0.112	0.140	0.107	0.069	0.145
19	0.051	0.038	0.031	0.026	0.024	0.025	0.096
20	0.023	0.021	0.021	0.020	0.023	0.021	0.045
21	0.019	0.019	0.024	0.027	0.019	0.023	0.140
22	0.021	0.021	0.026	0.030	0.030	0.064	0.131
23	0.095	0.019	0.021	0.060	0.024	0.018	0.104
24	0.018	0.019	0.020	0.023	0.018	0.018	0.047
25	0.020	0.019	0.020	0.018	0.128	0.120	0.159
26	0.134	0.118	0.020	0.019	0.097	0.084	0.203
27	0.093	0.166	0.082	0.296	0.030	0.027	0.454
28	0.035	0.043	0.025	0.031	0.091	0.047	0.119
29	0.060	0.040	0.032	0.038	0.021	0.026	0.134
30	0.024	0.024	0.040	0.035	0.024	0.020	0.115
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No
 All daily turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point Yes / No

Notes:

PRINTED NAME: DAVID HANCOCK

SIGNATURE:

DATE: 10/3/24

PHONE #: (971) 241-7203

CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

David Hancock D-09449

T-09183

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Sep-24	Disinfection Giardia Log Location	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	Y	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	10:00	1.19	108	128.5	13.6	7.62	19.2	Yes	270
2	09:00	1.15	108	124.2	13.5	7.63	19.3	Yes	296
3	09:00	1.10	108	118.8	13.6	7.70	19.6	Yes	287
4	18:45	1.06	108	114.5	15.2	7.65	17.2	Yes	247
5	06:43	1.08	108	116.6	13.2	7.74	20.4	Yes	264
6	09:45	1.15	108	124.2	14.6	7.67	18.2	Yes	201
7	09:00	1.06	108	114.5	14.7	7.71	18.2	Yes	225
8	01:50	1.01	108	109.1	14.3	7.71	18.6	Yes	267
9	17:46	0.92	108	99.4	14.7	7.72	18.0	Yes	267
10	03:04	0.98	108	105.8	15.1	7.74	17.8	Yes	250
11	07:20	1.02	108	110.2	14.2	7.72	18.8	Yes	250
12	23:20	0.98	108	105.8	14.0	7.69	18.8	Yes	164
13	09:30	0.96	108	103.7	13.8	7.69	19.0	Yes	179
14	17:10	1.00	108	108.0	14.1	7.69	18.7	Yes	201
15	21:00	0.94	108	101.5	13.8	7.69	18.9	Yes	203
16	08:50	0.93	108	100.4	13.3	7.69	19.5	Yes	182
17	22:22	1.05	108	113.4	13.4	7.71	19.8	Yes	195
18	23:34	0.91	108	98.3	13.4	7.69	19.4	Yes	181
19	09:28	0.88	108	95.0	13.4	7.69	19.3	Yes	168
20	02:44	0.92	108	99.4	13.9	7.69	18.7	Yes	180
21	22:14	1.21	108	130.7	13.4	7.71	20.2	Yes	367
22	04:00	0.91	108	98.3	14.0	7.72	18.8	Yes	208
23	07:00	0.92	108	99.4	14.3	7.72	18.5	Yes	186
24	14:40	1.18	108	127.4	14.6	7.59	17.8	Yes	212
25	13:00	1.24	108	133.9	13.5	7.62	19.4	Yes	161
26	14:00	1.23	108	132.8	14.5	7.50	17.4	Yes	165
27	14:00	0.84	108	90.7	13.4	7.47	17.7	Yes	197
28	13:20	0.73	108	78.8	13.7	7.45	17.1	Yes	207
29	13:46	0.95	108	102.6	13.8	7.45	17.3	Yes	188
30	02:00	0.99	108	106.9	13.1	8.05	22.8	Yes	165
31			108	0.0			4.2		

³ If met, DWP to be notified by end of next business day.

Revised February 2012