

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Oct-24

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.035	0.034	0.051	0.041	0.018	0.036	0.123
2	0.034	0.029	0.034	0.034	0.023	0.052	0.095
3	0.025	0.024	0.044	0.047	0.018	0.024	0.097
4	0.024	0.021	0.024	P.O.	P.O.	0.192	0.363
5	0.090	0.036	0.026	0.032	0.029	0.042	0.217
6	0.019	0.019	0.028	0.036	0.019	0.018	0.087
7	0.021	0.021	0.026	0.030	0.019	0.030	0.156
8	0.019	0.019	0.039	0.029	0.024	0.048	0.140
9	0.018	0.035	0.032	0.041	0.019	0.018	0.164
10	0.024	0.025	0.031	0.023	0.034	0.027	0.130
11	0.037	0.024	0.026	0.018	0.016	0.021	0.040
12	0.018	0.016	0.022	0.019	0.016	0.018	0.045
13	0.019	0.020	0.030	0.019	0.021	0.018	0.026
14	0.018	0.018	0.023	0.021	0.058	0.098	0.195
15	0.172	0.159	0.178	0.218	0.057	0.053	0.238
16	0.038	0.029	0.206	0.305	0.216	0.145	0.570
17	0.241	0.238	0.179	0.064	0.092	0.043	0.260
18	0.049	0.049	0.024	0.020	0.024	0.034	0.100
19	0.019	0.019	0.025	0.025	0.038	0.037	0.064
20	0.021	0.023	0.023	0.041	0.019	0.034	0.321
21	0.172	0.312	0.106	0.128	0.227	0.276	0.482
22	0.034	0.090	0.093	0.019	0.025	0.031	0.190
23	0.018	0.018	0.020	0.020	0.024	0.038	0.228
24	0.016	0.023	0.023	0.036	0.021	0.018	0.074
25	0.020	0.032	0.019	0.026	0.026	0.045	0.286
26	0.040	0.020	0.069	0.247	0.246	0.173	0.506
27	0.234	0.232	0.260	0.389	0.478	0.475	0.571
28	0.425	0.406	PO	PO	PO	0.291	0.526
29	0.213	0.199	0.198	0.172	0.177	0.142	0.257
30	0.167	0.071	0.082	0.157	0.164	0.221	0.238
31	0.230	0.234	0.232	0.227	0.290	P.O	0.266

**Conventional or Direct Filtration**

**Monthly Summary (Answer Yes or No)**

95% of daily turbidity readings ≤ 0.3 NTU? Yes/No  
 All daily turbidity readings ≤ 1 NTU? Yes/No  
 All turbidity readings < IFE<sup>2</sup> triggers Yes/No

CT's met everyday? (see back) Yes/No  
 All Cl<sub>2</sub> residual at entry point Yes/No

Notes:

PRINTED NAME: DAVID HANCOCK

SIGNATURE:

DATE: 11/9/24

PHONE #: ( )

CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns

<sup>1</sup> 12 AM through 8 PM may not

correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

971.241.7203

D-09449

*David Hancock*

T-09183

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Oct-24	Disinfection Giardia Log Inactivation	0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	12:36	0.91	108	98.3	13.1	8.08	22.8	Yes	152
2	12:14	0.79	108	85.3	12.8	8.17	23.7	Yes	134
3	21:30	0.73	108	78.8	12.9	8.17	23.4	Yes	147
4	21:10	0.60	108	64.8	12.7	8.24	24.0	Yes	146
5	22:00	0.68	108	73.4	12.7	8.17	23.6	Yes	191
6	16:37	0.71	108	76.7	12.6	8.17	23.8	Yes	198
7	09:24	0.99	108	106.9	12.8	8.20	24.5	Yes	160
8	04:16	1.02	108	110.2	12.8	8.13	24.0	Yes	148
9	22:17	1.04	108	112.3	12.7	8.13	24.2	Yes	175
10	20:00	0.85	108	92.0	12.6	8.15	24.0	Yes	157
11	02:38	1.07	108	115.6	12.6	8.18	25.0	Yes	196
12	07:00	0.99	108	106.9	12.6	8.27	25.6	Yes	236
13	22:00	0.83	108	89.6	12.6	8.17	24.1	Yes	208
14	10:30	0.23	108	24.8	12.8	8.18	22.3	Yes	174
15	22:00	0.81	108	87.5	12.7	7.64	19.7	Yes	174
16	22:30	0.80	108	86.4	12.9	7.81	20.7	Yes	153
17	08:00	0.89	108	96.1	12.6	7.74	20.7	Yes	136
18	14:00	1.99	108	214.9	12.6	8.18	27.6	Yes	149
19	23:00	0.94	108	101.5	12.6	7.81	21.4	Yes	172
20	10:41	0.90	108	97.2	12.4	7.88	22.2	Yes	176
21	04:38	0.90	108	97.2	12.4	7.84	21.9	Yes	133
22	09:50	1.17	108	126.4	11.9	7.81	23.0	Yes	147
23	02:00	0.98	108	105.8	11.7	7.88	23.4	Yes	153
24	19:40	0.94	108	101.5	11.6	7.88	23.4	Yes	164
25	08:00	0.88	108	95.0	11.6	8.05	24.8	Yes	250
26	07:44	0.71	108	76.7	11.8	7.96	23.2	Yes	177
27	06:18	0.34	108	36.7	11.6	7.91	22.1	Yes	177
28	20:15	0.24	108	25.4	11.6	7.91	21.9	Yes	129
29	08:30	0.24	108	25.4	11.7	7.95	22.1	Yes	140
30	12:01	0.91	108	98.6	11.5	7.98	24.4	Yes	132
31	00:30	0.89	108	96.1	11.2	7.50	21.0	Yes	134

if met, DWP to be notified by end of next business day.

Revised February 2012