

Conventional or Direct Filtration

Month/Year: Nov-24

System Name:	Netarts Water District			ID#: 41	00556	WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	P.O.	P.O.	P.O.	P.O.	0.241	0.235	0.287
2	P.O.	0.230	0.156	0.283	0.271	0.265	0.296
3	P.O.	0.290	0.286	0.352	0.241	0.240	0.368
4	0.260	0.238	0.228	0.247	0.284	0.245	0.448
5	0.240	0.236	0.208	0.198	0.190	0.204	0.236
6	P.O.	P.O.	P.O.	0.064	0.065	0.059	0.191
7	0.039	0.037	0.065	0.042	0.158	0.035	0.101
8	0.048	0.040	0.036	0.029	0.124	0.041	0.146
9	0.038	0.038	0.030	0.021	0.036	0.057	0.126
10	0.036	0.059	0.034	0.038	0.040	0.032	0.596
11	0.192	0.203	0.201	po	po	po	0.591
12	po	po	0.240	0.224	0.236	0.286	0.381
13	0.222	0.219	0.355	0.379	0.015	0.255	0.550
14	po	po	PO	0.326	0.273	0.267	0.421
15	P.O.	0.243	0.203	0.188	0.186	0.166	0.260
16	0.166	0.162	0.187	0.170	0.181	0.191	0.272
17	P.O.	P.O.	P.O.	P.O.	0.352	0.277	0.963
18	0.268	0.252	0.289	0.238	0.221	0.295	0.408
19	0.263	0.258	0.260	0.233	0.260	0.298	0.323
20	po	po	0.278	0.297	0.256	0.293	0.510
21	0.228	0.283	0.261	0.241	0.234	0.289	0.294
22	0.208	0.201	0.265	0.267	0.240	0.227	0.308
23	0.236	0.196	0.230	0.185	0.153	0.202	0.265
24	0.180	0.167	0.164	0.155	P.O.	P.O.	0.605
25	P.O.	P.O.	P.O.	0.284	0.250	0.239	0.371
26	0.217	0.211	0.178	0.114	0.051	0.112	0.232
27	0.071	0.145	0.052	0.049	0.048	0.142	0.138
28	0.020	0.025	0.153	0.067	0.074	0.062	0.271
29	0.070	0.294	0.076	0.025	0.034	0.069	0.244
30	0.087	0.026	0.057	0.040	0.024	0.054	0.130
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<u>Yes</u> / No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	<u>Yes</u> / No	<u>Yes</u> / No	<u>Yes</u> / No
All turbidity readings < IFE ² triggers	<u>Yes</u> / No		
Notes:	PRINTED NAME: DAVID HANCOCK		
	SIGNATURE:		DATE: 12/6/24
	PHONE #: ()		CERT #:

¹Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ²IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

David Hancock
 T- 09183 503-842-9405
 D- 09449 971-241-7203

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Nov-24	Disinfection Giardia Log Reduction	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	09:00	0.83	108	89.6	11.2	7.52	21.0	Yes	128
2	13:00	0.80	108	86.4	11.3	7.48	20.5	Yes	161
3	12:00	0.75	108	81.0	11.2	7.50	20.6	Yes	184
4	03:40	0.77	108	83.2	11.2	7.50	20.7	Yes	141
5	12:30	0.80	108	86.4	11.1	7.51	21.0	Yes	164
6	23:00	0.77	108	83.2	10.7	7.53	21.6	Yes	135
7	04:30	0.84	108	90.7	10.5	7.55	22.3	Yes	141
8	04:49	0.75	108	81.4	10.5	7.57	22.1	Yes	165
9	13:36	0.76	108	82.1	10.7	7.59	22.0	Yes	176
10	16:41	1.01	108	109.1	10.6	7.60	22.9	Yes	254
11	06:17	0.83	108	89.6	10.6	7.60	22.4	Yes	162
12	12:18	0.94	108	101.5	10.7	7.40	21.0	Yes	121
13	06:45	0.74	108	79.9	10.6	7.89	24.6	Yes	127
14	10:00	0.72	108	77.8	10.7	7.85	24.1	Yes	123
15	16:14	0.50	108	54.0	10.5	7.93	24.5	Yes	123
16	19:04	0.69	108	74.5	10.2	7.98	26.0	Yes	155
17	19:54	0.75	108	81.0	9.9	7.91	26.0	Yes	176
18	06:04	0.77	108	83.2	9.4	7.65	24.6	Yes	179
19	14:02	0.98	108	105.8	10.0	7.47	22.7	Yes	92
20	10:02	0.90	108	97.2	9.3	7.47	23.5	Yes	92
21	02:15	1.10	108	118.8	9.3	7.76	26.8	Yes	103
22	08:42	1.10	108	118.8	9.3	7.74	26.5	Yes	131
23	11:32	1.10	108	118.8	9.6	7.74	26.1	Yes	118
24	08:12	0.99	108	107.2	9.3	7.74	26.2	Yes	136
25	11:24	0.82	108	88.8	9.6	7.71	24.9	Yes	122
26	01:24	0.84	108	90.7	9.4	7.71	25.3	Yes	208
27	01:20	0.84	108	90.7	9.4	7.71	25.3	Yes	124
28	12:40	0.74	108	79.9	9.7	7.74	24.8	Yes	161
29	03:10	0.85	108	91.8	9.1	7.77	26.4	Yes	158
30	23:30	1.12	108	121.0	8.7	7.81	28.4	Yes	168
31			108	0.0			4.2		

† met, DWP to be notified by end of next business day.

Revised February 2012