

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Dec-24

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.027	0.036	0.050	0.042	0.056	0.026	0.148
2	0.027	0.065	0.023	0.029	0.029	0.043	0.179
3	0.059	0.025	0.026	0.036	0.023	0.056	0.163
4	0.025	0.042	0.110	0.037	0.051	0.024	0.163
5	0.031	0.051	0.020	0.043	0.074	0.038	0.093
6	0.034	0.045	0.077	0.043	0.025	0.037	0.191
7	0.026	0.025	0.254	PO	PO	PO	0.976
8	PO	PO	PO	0.256	0.170	0.192	0.742
9	0.123	0.062	0.060	0.048	0.034	0.024	0.162
10	0.029	0.032	0.044	0.034	0.027	0.024	0.166
11	0.020	0.020	0.024	0.030	0.026	0.019	0.046
12	0.018	0.020	0.022	0.024	0.019	0.020	0.064
13	0.019	0.019	0.029	0.027	0.042	0.109	0.153
14	0.045	0.045	0.270	0.205	0.203	0.065	0.207
15	0.050	0.070	0.038	0.064	0.063	0.040	0.232
16	0.218	0.150	0.164	0.168	0.108	0.104	0.223
17	0.071	0.075	0.220	0.273	P.O.	P.O.	0.308
18	P.O.	P.O.	P.O.	PO	PO	0.282	0.341
19	0.135	0.168	0.059	0.043	0.175	0.217	0.280
20	0.224	0.224	0.079	0.070	0.037	0.070	0.241
21	0.041	0.040	0.059	0.048	0.067	0.043	0.164
22	0.042	0.029	0.029	0.062	0.036	0.125	0.268
23	0.084	0.073	0.099	0.065	0.027	0.058	0.111
24	0.040	0.038	0.051	0.024	0.101	0.107	0.238
25	0.023	0.093	0.058	0.064	0.036	0.255	0.265
26	P.O.	P.O.	P.O.	PO	P.O.	0.290	0.265
27	0.245	0.223	0.281	0.261	0.082	0.102	0.328
28	0.247	0.241	0.232	0.185	0.118	0.101	0.290
29	0.162	0.139	0.127	0.188	0.152	0.115	0.256
30	0.129	0.135	0.140	0.042	0.089	0.048	0.250
31	0.169	0.034	0.066	0.070	0.041	0.093	0.233

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings  $\leq$  0.3 NTU? Yes / No  
 All daily turbidity readings  $\leq$  1 NTU? Yes / No  
 All turbidity readings  $<$  IFE<sup>2</sup> triggers Yes / No

CT's met everyday? (see back) Yes / No  
 All Cl<sub>2</sub> residual at entry point Yes / No

Notes:

PRINTED NAME:

SIGNATURE:

DATE: 01/02/25

PHONE #: ( )

CERT #:

including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns

12 AM through 8 PM may not

correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C)) (503) 842-9405

DAVID B Hancock  
 David Hancock 01/2/25  
 T. 09183  
 D-09449



OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A  
 Disinfection  
 Giardia Log  
 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Dec-24	Required CT	0.5	Peak Hourly Demand Flow
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>		
		[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]	
1	01:30	1.09	108	117.7	9.4	7.85	27.4	Yes	149	
2	20:26	1.15	108	124.2	8.7	7.83	28.7	Yes	108	
3	18:10	1.13	108	122.0	8.6	7.84	28.9	Yes	178	
4	02:56	1.16	108	125.3	8.3	7.84	29.6	Yes	93	
5	20:58	1.29	108	139.3	8.6	7.88	29.9	Yes	104	
6	02:58	1.04	108	112.5	9.1	7.86	27.8	Yes	111	
7	01:50	0.93	108	100.7	9.1	7.88	27.7	Yes	122	
8	07:58	0.81	108	87.4	9.1	7.86	27.1	Yes	122	
9	08:00	0.93	108	100.7	9.1	7.84	27.4	Yes	198	
10	06:00	0.91	108	98.6	9.1	7.84	27.3	Yes	152	
11	10:08	0.88	108	95.0	9.4	7.83	26.5	Yes	89	
12	10:28	0.92	108	99.4	9.3	7.84	26.9	Yes	96	
13	20:50	0.73	108	78.8	9.3	7.88	26.7	Yes	119	
14	10:06	0.68	108	73.4	9.1	7.88	26.9	Yes	128	
15	20:14	0.83	108	90.1	9.1	7.89	27.5	Yes	122	
16	07:00	0.79	108	84.8	9.3	7.89	27.1	Yes	98	
17	19:48	1.15	108	124.2	9.3	7.89	28.2	Yes	98	
18	20:00	0.83	108	90.1	9.6	7.89	26.6	Yes	93	
19	19:50	0.98	108	105.8	10.1	7.89	26.1	Yes	96	
20	01:00	0.84	108	90.7	10.3	7.89	25.4	Yes	96	
21	12:58	0.77	108	83.5	10.1	7.89	25.5	Yes	131	
22	06:00	0.75	108	81.0	10.2	7.91	25.5	Yes	117	
23	01:30	0.75	108	81.0	10.4	7.91	25.2	Yes	117	
24	20:50	1.13	108	122.0	10.3	7.74	24.9	Yes	116	
25	19:30	1.12	108	121.0	9.9	7.74	25.5	Yes	104	
26	13:50	0.90	108	97.2	10.4	7.62	23.1	Yes	125	
27	21:00	0.87	108	94.0	9.9	7.26	21.0	Yes	132	
28	10:15	0.74	108	79.9	10.1	7.41	21.5	Yes	141	
29	19:50	1.23	108	132.8	9.9	7.85	26.9	Yes	147	
30	20:00	1.15	108	124.2	9.7	7.91	27.6	Yes	140	
31	20:00	1.15	108	124.2	9.3	7.91	28.4	Yes	151	

† met, DWP to be notified by end of next business day.

Revised February 2012