

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Jan-25

System Name:	Netarts Water District			ID#: 41	00556		WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.070	0.030	0.080	0.098	0.024	0.056	0.129
2	0.030	0.030	0.076	0.040	0.208	0.210	0.236
3	0.060	0.059	0.255	0.246	PO	0.070	0.356
4	0.038	0.036	0.035	0.035	0.244	0.213	0.589
5	0.194	0.188	0.185	0.054	0.096	0.297	0.445
6	0.151	0.057	0.122	0.075	0.068	0.097	0.246
7	0.029	0.027	0.072	0.031	0.074	0.037	0.289
8	0.035	0.027	0.051	0.051	0.062	0.103	0.122
9	0.070	0.035	0.032	0.051	0.027	0.027	0.217
10	0.194	0.041	0.168	0.053	0.049	0.043	0.205
11	0.040	0.101	0.036	0.065	0.026	0.052	0.288
12	0.025	0.024	0.054	0.034	0.051	0.027	0.245
13	0.024	0.053	0.070	0.063	0.056	0.089	0.262
14	0.090	0.045	0.025	0.025	0.024	0.056	0.262
15	0.026	0.025	0.027	0.079	0.130	0.030	0.210
16	0.027	0.026	0.025	0.064	0.026	0.060	0.172
17	0.031	0.049	0.026	0.064	0.095	0.025	0.139
18	0.024	0.024	0.029	0.051	0.024	0.065	0.142
19	0.025	0.021	0.023	0.063	0.024	0.062	0.162
20	0.026	0.024	0.048	0.023	0.052	0.057	0.195
21	0.087	0.024	0.049	0.043	0.025	0.045	0.123
22	0.023	0.023	0.046	0.043	0.042	0.025	0.137
23	0.043	0.029	0.042	0.041	0.021	0.068	0.111
24	0.026	0.024	0.028	0.025	0.048	0.024	0.167
25	0.040	0.025	0.026	0.023	0.045	0.026	0.102
26	0.047	0.023	0.044	0.031	0.025	0.043	0.119
27	0.023	0.026	0.026	0.026	0.027	0.029	0.090
28	0.026	0.049	0.026	0.103	0.026	0.051	0.122
29	0.079	0.054	0.028	0.025	0.051	0.032	0.122
30	0.035	0.029	0.032	0.057	0.023	0.054	0.108
31	0.025	0.024	0.037	0.131	0.245	PO	0.934

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU? Yes/No
 All daily turbidity readings ≤ 1 NTU? Yes/No
 All turbidity readings < IFE² triggers Yes/No

CT's met everyday? (see back) Yes/No
 All Cl₂ residual at entry point Yes/No

Notes:

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

Including continuous NTU data, if applicable, for optimization/recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

DAVID HANCOCK
 T-09183
 D-09449
 David Hancock 2/3/25
 971-241-7203
 503-842-9405

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

Disinfection
Giardia Log
Reduction

0.5

System
Name:

Netarts Water District

ID#: 41

00556

Month/Year:

Jan-25

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	08:00	1.15	108	124.2	9.7	7.91	27.6	Yes	164
2	08:00	1.15	108	124.2	9.7	7.91	27.6	Yes	124
3	23:58	1.15	108	124.2	9.7	7.91	27.6	Yes	128
4	22:58	1.11	108	119.9	9.7	7.91	27.5	Yes	128
5	19:01	0.90	108	97.3	9.9	7.41	22.1	Yes	133
6	08:00	0.80	108	86.4	10.6	7.74	23.5	Yes	107
7	08:30	0.93	108	100.4	9.7	7.98	27.6	Yes	140
8	08:00	0.96	108	103.7	9.8	7.92	27.0	Yes	162
9	06:00	0.92	108	99.3	9.7	7.86	26.3	Yes	126
10	23:58	0.74	108	79.9	9.7	7.86	25.8	Yes	135
11	23:00	1.16	108	125.3	9.6	7.96	28.3	Yes	135
12	12:19	1.13	108	122.0	9.6	7.96	28.3	Yes	129
13	19:00	1.27	108	137.2	9.6	7.91	28.2	Yes	142
14	10:34	1.13	108	122.0	9.1	7.91	28.7	Yes	96
15	19:58	0.79	108	85.3	9.3	8.42	32.7	Yes	99
16	09:30	1.05	108	113.4	9.1	8.95	41.5	Yes	111
17	08:50	0.75	108	81.0	8.8	7.71	26.1	Yes	139
18	01:30	0.77	108	83.2	8.8	7.83	27.3	Yes	134
19	20:30	0.90	108	97.2	8.6	8.54	36.3	Yes	152
20	10:20	1.08	108	116.6	8.6	8.97	43.5	Yes	144
21	19:14	1.06	108	114.5	8.6	8.46	35.9	Yes	96
22	18:58	1.34	108	144.7	8.8	8.46	36.6	Yes	74
23	19:00	1.02	108	109.8	8.5	9.27	48.7	Yes	106
24	18:10	0.51	108	55.1	8.5	8.97	40.9	Yes	144
25	22:00	0.74	108	79.9	8.6	9.66	54.0	Yes	124
26	18:00	0.72	108	77.5	8.2	9.88	60.0	Yes	135
27	06:00	0.94	108	102.0	8.2	8.42	36.0	Yes	114
28	18:00	1.27	108	137.2	8.2	8.42	37.2	Yes	100
29	02:49	1.02	108	110.2	25.0	11.57	37.8	Yes	97
30	05:00	0.99	108	106.9	8.3	11.16	100.1	Yes	115
31	03:45	0.93	108	100.7	8.2	10.03	65.2	Yes	116

† met, DWP to be notified by end of next business day.

Revised February 2012