

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Feb-25

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	PO	PO	PO	0.131	0.245	PO	0.934
2	PO	PO	PO	0.064	0.063	0.046	0.181
3	0.081	1.090	0.053	0.024	0.024	0.072	0.122
4	0.024	0.052	0.023	0.046	0.035	0.063	0.169
5	0.057	0.059	0.029	0.074	0.036	0.133	0.208
6	0.201	0.195	0.073	0.027	0.060	0.023	0.205
7	0.027	0.062	0.056	0.025	0.023	0.058	0.108
8	0.025	0.076	0.032	0.046	0.032	0.058	0.162
9	0.058	0.062	0.053	0.103	0.024	0.029	0.081
10	0.023	0.024	0.085	0.027	0.042	0.023	0.126
11	0.049	0.031	0.040	0.051	0.021	0.042	0.126
12	0.019	0.052	0.032	0.032	0.023	0.043	0.115
13	0.021	0.046	0.054	0.024	0.060	0.024	0.126
14	0.042	0.021	0.046	0.084	0.071	0.026	0.092
15	0.021	0.047	0.042	0.122	0.048	0.049	0.128
16	0.021	0.053	0.079	0.090	0.035	0.125	0.218
17	0.168	0.177	P.O.	PO	PO	PO	0.859
18	PO	PO	PO	0.112	0.095	0.111	0.205
19	0.045	0.041	0.214	0.219	0.230	0.129	0.321
20	0.117	0.035	0.031	0.078	0.038	0.076	0.211
21	0.029	0.027	0.066	0.067	0.021	0.047	0.164
22	0.047	0.046	0.215	0.145	0.058	0.053	0.238
23	0.049	0.049	0.064	0.049	0.049	0.048	0.069
24	0.048	0.052	0.164	0.038	0.021	PO	0.670
25	PO	PO	PO	0.115	0.159	0.146	0.229
26	0.153	0.109	0.082	0.075	0.062	0.049	0.572
27	0.051	0.029	0.055	0.054	0.046	0.052	0.172
28	0.043	0.049	0.039	0.038	0.041	0.042	0.157
29							
30							
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 0.3 NTU?  Yes /  No  
 All daily turbidity readings ≤ 1 NTU?  Yes /  No  
 All turbidity readings < IFE<sup>2</sup> triggers  Yes /  No

CT's met everyday? (see back) Yes / No  
 All Cl<sub>2</sub> residual at entry point Yes / No

Notes:

PRINTED NAME: David Hancock

SIGNATURE:

DATE:

PHONE #: (971) 241-7203

CERT #:

<sup>1</sup>Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup>IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

T-09183  
D-09449

David Hancock  
971.241.7203  
3/4/2025



OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Feb-25	Disinfection Giardia Log Inactivation	0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]	
1	16:20	0.92	108	99.3	8.5	10.20	68.2	Yes	128	
2	23:50	0.99	108	106.9	8.1	10.29	73.0	Yes	141	
3	15:20	0.94	108	101.5	7.9	10.63	83.7	Yes	102	
4	16:00	0.93	108	100.4	7.7	10.96	96.1	Yes	95	
5	01:00	0.93	108	100.4	7.2	10.19	74.2	Yes	100	
6	09:00	0.87	108	94.0	7.2	10.37	79.0	Yes	141	
7	14:50	0.92	108	99.4	7.5	7.60	27.9	Yes	107	
8	10:36	0.90	108	97.2	7.5	7.59	27.7	Yes	129	
9	03:00	1.04	108	112.3	7.8	7.06	22.9	Yes	137	
10	19:10	1.09	108	117.7	7.2	7.77	30.9	Yes	94	
11	21:36	1.10	108	119.1	6.9	7.77	31.5	Yes	104	
12	01:18	1.07	108	115.6	6.8	7.77	31.7	Yes	102	
13	15:20	1.02	108	110.2	6.8	7.76	31.4	Yes	114	
14	02:30	1.04	108	112.3	6.8	7.76	31.4	Yes	103	
15	01:00	1.07	108	115.6	6.8	7.77	31.7	Yes	126	
16	23:00	0.87	108	94.0	7.7	7.76	29.0	Yes	143	
17	08:00	0.86	108	92.9	7.8	7.85	29.8	Yes	129	
18	07:00	0.73	108	78.8	8.3	7.62	26.0	Yes	180	
19	05:20	0.64	108	69.1	8.5	7.62	25.5	Yes	107	
20	05:45	0.61	108	66.3	8.6	7.62	25.1	Yes	103	
21	09:08	0.61	108	65.9	8.8	7.62	24.8	Yes	145	
22	07:00	0.63	108	68.0	9.1	7.62	24.4	Yes	123	
23	06:36	0.72	108	77.8	9.1	7.64	24.8	Yes	145	
24	10:06	0.77	108	83.2	9.2	7.64	24.8	Yes	123	
25	04:52	0.96	108	103.7	9.3	7.33	22.6	Yes	100	
26	11:44	0.88	108	95.0	10.2	8.58	33.0	Yes	114	
27	03:30	0.90	108	97.2	10.2	8.44	31.4	Yes	132	
28	01:00	0.98	108	105.8	10.4	8.30	29.7	Yes	117	
29			108	0.0			4.2			
30			108	0.0			4.2			
31			108	0.0			4.2			

† met, DWP to be notified by end of next business day.