

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:

Tillamook

Conventional or Direct Filtration

Month/Year:

Mar-25

System Name:	Netarts Water District			ID#: 41	00556	WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.053	0.051	0.058	0.047	0.035	0.041	1.000
2	0.038	0.051	0.033	0.060	0.032	0.045	0.157
3	0.038	0.024	0.048	0.030	0.047	0.027	0.178
4	0.053	0.027	0.053	0.054	0.026	0.049	0.178
5	0.025	0.038	0.027	0.047	0.024	0.047	0.180
6	0.021	0.047	0.024	0.046	0.026	0.027	0.125
7	0.026	0.026	0.026	0.025	0.026	0.029	0.147
8	0.030	0.049	0.054	0.058	0.025	0.030	0.164
9	0.025	0.024	0.048	0.027	0.052	0.025	0.164
10	0.063	0.084	0.067	0.027	0.056	0.031	0.207
11	0.023	0.026	0.052	0.052	0.026	0.034	0.161
12	0.026	0.025	0.168	0.180	0.034	0.034	0.294
13	0.034	0.037	0.072	0.029	0.025	0.058	0.236
14	0.029	0.062	0.159	0.051	0.059	0.045	0.274
15	0.034	0.025	0.036	0.075	0.157	0.030	0.238
16	0.058	0.036	0.111	0.079	0.051	0.034	0.208
17	0.041	0.037	0.033	0.025	0.056	0.026	0.208
18	0.056	0.027	0.033	0.059	0.067	0.024	0.151
19	0.038	0.079	0.097	0.070	0.027	0.058	0.188
20	0.030	0.062	0.044	0.087	0.057	0.045	0.188
21	0.041	0.040	PO	0.249	0.114	0.051	0.852
22	0.036	0.029	0.054	0.027	0.084	0.060	0.316
23	0.074	0.038	0.037	0.079	0.037	0.078	0.293
24	0.043	0.056	0.071	0.051	0.090	0.056	0.293
25	0.032	0.054	0.045	0.087	0.045	0.026	0.219
26	0.082	0.049	0.061	0.045	0.034	0.032	0.196
27	0.038	0.036	0.052	0.025	0.036	0.034	0.196
28	0.030	0.091	0.032	P.O.	0.297	0.228	0.313
29	0.191	0.201	0.198	0.178	0.143	0.173	0.233
30	0.148	0.130	0.139	0.122	0.146	0.144	0.245
31	0.147	0.128	0.122	0.134	0.169	0.161	0.201

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU?

Yes / No

All daily turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry
point

Yes / No

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

Notes:

TREATMENT WAS OFF DURING HIGH NTA 21st - 25thincluding continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns
12 AM through 8 PM may notcorrespond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))David B Hancock
David Hancock

971-241-7203

T-09183 D-09449

4/3/2025

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Netarts Water District ID#: 41 00556 Month/Year: Mar-25							Disinfection Giardia Log Location: 0.5		
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	06:30	1.02	108	110.2	10.1	8.15	28.9	Yes	151
2	10:16	1.09	108	117.7	9.9	7.95	27.4	Yes	157
3	10:00	1.16	108	125.3	9.7	7.88	27.3	Yes	104
4	05:26	1.00	108	107.9	9.6	7.78	26.1	Yes	144
5	17:26	1.03	108	111.1	10.1	7.74	25.0	Yes	104
6	01:30	1.04	108	112.5	9.9	7.72	25.1	Yes	114
7	04:32	1.04	108	112.5	9.9	7.67	24.6	Yes	134
8	07:01	1.04	108	112.5	9.7	7.64	24.7	Yes	136
9	23:00	1.02	108	110.2	9.9	7.64	24.4	Yes	139
10	09:16	0.99	108	106.9	9.4	7.71	25.7	Yes	118
11	10:54	1.24	108	133.9	9.6	7.71	26.1	Yes	103
12	00:40	1.18	108	127.4	9.4	7.71	26.3	Yes	113
13	08:30	1.16	108	125.3	10.5	7.71	24.4	Yes	108
14	23:30	1.16	108	125.3	9.7	7.71	25.7	Yes	111
15	23:00	1.13	108	122.0	9.3	7.71	26.3	Yes	132
16	06:20	1.10	108	119.1	9.1	7.67	26.3	Yes	0.205
17	12:20	1.10	108	119.1	9.1	7.67	26.3	Yes	118
18	20:00	1.10	108	118.8	9.1	7.67	26.2	Yes	108
19	04:44	1.15	108	124.3	9.3	7.67	26.1	Yes	110
20	17:00	1.10	108	119.1	9.3	7.67	26.0	Yes	121
21	23:59	1.32	108	142.9	9.3	7.21	22.5	Yes	120
22	14:00	1.20	108	129.6	9.5	7.81	27.2	Yes	151
23	04:00	1.12	108	121.0	9.7	7.91	27.5	Yes	164
24	06:00	1.01	108	109.1	9.9	7.67	24.6	Yes	141
25	09:20	0.79	108	85.3	10.2	7.65	23.4	Yes	164
26	08:40	0.79	108	85.3	10.8	7.60	22.1	Yes	158
27	23:00	0.91	108	98.3	10.8	7.59	22.3	Yes	196
28	15:00	0.88	108	95.0	10.8	7.62	22.4	Yes	143
29	11:50	0.80	108	86.4	11.2	7.62	21.7	Yes	160
30	23:48	0.73	108	78.8	10.3	7.85	24.7	Yes	162
31	06:32	0.71	108	76.2	10.1	7.55	22.6	yES	120

if met, DWP to be notified by end of next business day.

Revised February 2012