

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:

Tillamook

Conventional or Direct Filtration

Month/Year:

Apr-25

System Name:	Netarts Water District			ID#: 41	00556	WTP: TP - A	Highest Reading of the Day ¹ [NTU]
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	
1	0.136	0.128	0.125	0.134	0.169	0.161	0.241
2	0.136	0.128	0.125	0.145	0.125	0.118	0.241
3	0.120	0.135	0.124	0.114	0.109	0.112	0.186
4	0.107	0.108	0.133	0.113	0.114	0.112	0.172
5	0.120	0.098	0.104	0.084	0.082	0.118	0.175
6	0.086	0.082	0.098	0.115	0.107	0.213	0.260
7	0.207	0.185	0.198	0.228	0.202	0.170	0.286
8	0.177	0.146	0.176	P.O.	0.257	0.195	P.O. 0.497
9	0.180	0.151	0.145	0.131	0.159	0.140	0.161
10	0.131	0.129	0.148	0.135	0.146	0.128	0.207
11	0.140	0.131	0.127	0.115	0.109	0.078	0.188
12	0.078	0.063	0.060	0.070	0.133	0.070	0.157
13	0.041	0.059	0.036	0.086	0.038	0.069	0.145
14	0.037	0.036	0.102	0.048	0.036	0.128	0.145
15	0.047	0.045	0.094	0.034	0.059	0.097	0.125
16	0.069	0.034	0.036	0.034	0.056	0.038	0.124
17	0.056	0.032	0.053	0.029	0.038	0.054	0.117
18	0.064	0.034	0.032	0.049	0.037	0.035	0.106
19	0.032	0.034	0.032	0.073	0.038	0.052	0.118
20	0.058	0.073	0.073	0.037	0.080	0.090	0.177
21	0.092	0.052	0.049	0.074	0.056	0.032	0.247
22	0.036	0.092	0.089	0.034	0.038	0.035	0.201
23	0.032	0.031	0.032	0.053	0.054	0.034	0.139
24	0.032	0.032	0.032	0.056	0.032	0.056	0.115
25	0.031	0.031	0.032	0.047	0.037	0.031	0.108
26	0.030	0.032	0.121	0.034	0.030	0.056	0.120
27	0.034	0.031	0.052	0.058	0.068	0.034	0.133
28	0.031	0.031	0.058	0.177	0.058	0.034	0.240
29	0.059	0.087	0.085	0.076	0.071	0.038	0.134
30	0.036	0.031	0.053	0.062	0.034	0.034	0.135
31							

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU?

Yes / No

All daily turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings $<$ IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point

Yes / No

Notes:

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

D-09449
T-09183DAVID Hancogek
503.842.9405
971.241.7203

5/5/25

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Apr-25	Disinfection Giardia Log Reduction		0.5
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	12:48	0.79	108	85.4	10.2	7.89	25.4	Yes	124
2	04:30	0.79	108	85.4	10.1	7.89	25.6	Yes	124
3	02:30	0.90	108	97.3	10.2	7.88	25.6	Yes	118
4	22:56	1.07	108	115.1	10.5	7.86	25.4	Yes	155
5	21:08	1.14	108	123.0	10.7	7.84	25.1	Yes	161
6	03:16	1.07	108	115.6	10.8	7.83	24.7	Yes	161
7	03:52	0.72	108	77.8	10.6	7.77	23.5	Yes	125
8	05:24	0.71	108	76.7	10.5	7.77	23.7	Yes	127
9	07:30	0.69	108	74.5	10.5	7.77	23.6	Yes	196
10	11:00	0.69	108	74.5	11.0	7.78	23.0	Yes	134
11	01:00	0.72	108	77.8	11.0	7.74	22.7	Yes	135
12	01:00	0.94	108	101.5	11.5	7.77	22.7	Yes	143
13	22:00	1.15	108	124.3	10.5	7.77	24.8	Yes	164
14	22:00	1.31	108	141.5	10.9	7.62	23.4	Yes	164
15	22:00	1.30	108	140.8	11.0	7.64	23.4	Yes	121
16	07:09	1.29	108	138.9	10.7	7.64	23.9	Yes	111
17	06:00	1.24	108	134.2	10.5	7.64	24.0	Yes	209
18	01:06	1.23	108	132.3	10.8	7.64	23.4	Yes	121
19	04:34	1.18	108	127.7	10.8	7.65	23.4	Yes	145
20	03:48	1.13	108	122.4	10.7	7.65	23.5	Yes	156
21	02:00	1.15	108	123.7	10.5	7.67	23.9	Yes	168
22	21:52	1.16	108	125.7	10.7	7.67	23.7	Yes	110
23	03:00	1.18	108	127.4	10.6	7.67	23.9	Yes	
24	01:50	1.18	108	127.4	11.3	7.71	23.2	Yes	115
25	06:00	1.23	108	132.8	11.5	7.76	23.4	Yes	121
26	03:00	1.27	108	137.2	11.5	7.81	23.9	Yes	150
27	05:42	1.29	108	138.9	11.0	7.84	25.1	Yes	177
28	10:19	1.27	108	137.6	11.2	7.86	24.9	Yes	130
29	02:54	1.23	108	132.3	11.2	7.86	24.7	Yes	150
30	06:40	1.16	108	125.7	11.0	7.88	25.1	Yes	176
31			108	0.0					

† met, DWP to be notified by end of next business day.

Revised February 2012