

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:

Tillamook

Conventional or Direct Filtration

Month/Year:

May-25

System Name:	Netarts Water District			ID#: 41	00556	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.023	0.032	0.048	0.040	0.051	0.053	0.129
2	0.032	0.032	0.059	0.048	0.058	0.040	0.122
3	0.074	0.037	0.035	0.058	0.034	0.035	0.091
4	0.051	0.030	0.030	0.128	0.024	0.056	0.128
5	0.032	0.067	0.031	0.078	0.031	0.073	0.125
6	0.030	0.041	0.030	0.051	0.026	0.024	0.137
7	0.032	0.024	0.105	0.049	0.039	0.053	0.139
8	0.037	0.037	0.064	0.048	0.027	0.041	0.129
9	0.052	0.031	0.047	0.030	0.036	0.045	0.115
10	0.047	0.031	0.049	0.051	0.031	0.048	0.126
11	0.090	0.081	0.034	0.034	0.076	0.081	0.185
12	0.041	0.063	0.034	0.135	0.091	0.097	0.139
13	0.086	0.106	0.089	0.079	0.059	0.059	0.178
14	0.114	0.103	0.096	0.119	0.082	0.073	0.181
15	0.054	0.097	0.036	0.054	0.097	0.036	0.133
16	0.071	0.090	0.103	0.082	0.131	0.103	0.234
17	0.112	0.120	0.124	0.170	0.140	0.147	0.238
18	0.128	0.134	0.130	0.117	0.112	0.157	0.203
19	0.123	0.090	0.100	0.245	0.169	0.164	0.245
20	0.156	0.153	0.112	0.060	0.058	0.045	0.199
21	0.070	0.035	0.057	0.032	0.048	0.056	0.164
22	0.034	0.046	0.083	0.063	0.067	0.032	0.163
23	0.073	0.036	0.059	0.063	0.032	0.060	0.115
24	0.031	0.030	0.068	0.051	0.045	0.063	0.177
25	0.032	0.051	0.031	0.074	0.053	0.024	0.193
26	0.064	0.031	0.118	0.036	0.036	0.034	0.134
27	0.047	0.065	0.056	0.051	0.034	0.069	0.159
28	0.034	0.031	0.024	0.025	0.026	0.027	0.043
29	0.025	0.024	0.025	0.124	0.213	0.156	0.261
30	0.160	0.035	0.035	0.026	0.038	0.029	0.192
31	0.026	0.025	0.035	0.025	0.025	0.030	0.062

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings $\leq$ 0.3 NTU?

Yes/No

All daily turbidity readings $\leq$ 1 NTU?

Yes/No

All turbidity readings < IFE² triggers

Yes/No

CT's met everyday?
(see back)

Yes/No

All Cl₂ residual at entry
point

Yes/No

Notes:

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns

12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

DAVID B HANCOCK

David B Hancock

971.241.7203

6/1/2025

D=09449

T=09183

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: May-25	Disinfection Giardia Log negative	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	04:30	1.10	108	119.1	11.2	7.84	24.2	Yes	296
2	16:16	1.07	108	115.1	11.2	7.88	24.5	Yes	201
3	06:44	1.04	108	111.8	10.8	7.91	25.2	Yes	177
4	13:08	1.04	108	112.3	11.6	7.91	24.0	Yes	177
5	10:00	1.04	108	112.3	11.8	7.96	24.1	Yes	136
6	07:00	1.23	108	132.8	12.5	7.93	23.3	Yes	213
7	16:00	1.26	108	136.1	11.5	7.77	23.6	Yes	187
8	23:00	1.29	108	139.3	11.3	7.77	24.0	Yes	116
9	06:00	1.15	108	124.2	12.0	7.82	22.9	Yes	131
10	11:00	1.14	108	123.1	11.9	7.88	23.5	Yes	152
11	03:28	1.19	108	129.0	11.5	7.69	22.8	Yes	167
12	03:00	1.19	108	128.5	11.5	7.69	22.8	Yes	132
13	22:04	1.26	108	136.1	11.6	7.67	22.5	Yes	160
14	14:48	1.23	108	132.9	11.5	7.64	22.5	Yes	138
15	16:00	1.23	108	132.8	11.5	7.64	22.4	Yes	144
16	05:38	1.19	108	129.0	11.8	7.57	21.4	Yes	146
17	06:30	0.99	108	107.2	11.5	7.57	21.4	Yes	150
18	03:16	0.96	108	103.7	11.5	7.55	21.1	Yes	157
19	06:00	1.02	108	109.8	11.3	7.53	21.3	Yes	142
20	13:00	0.87	108	94.0	11.5	7.48	20.4	Yes	130
21	06:00	0.87	108	94.0	11.9	7.50	20.0	Yes	131
22	09:00	0.89	108	96.1	12.1	7.48	19.6	Yes	138
23	09:00	0.89	108	96.1	12.2	7.47	19.4	Yes	137
24	08:00	1.15	108	124.2	12.4	7.60	20.7	Yes	182
25	09:00	1.30	108	140.4	12.5	7.47	19.8	Yes	157
26	06:00	1.23	108	132.3	11.7	7.71	22.7	Yes	192
27	03:30	1.21	108	131.0	11.9	7.91	23.9	Yes	171
28	06:00	1.21	108	131.0	12.4	7.69	21.4	Yes	140
29	06:00	1.15	108	123.7	12.1	7.67	21.5	Yes	127
30	06:00	1.09	108	117.7	12.6	7.71	21.0	Yes	167
31	05:00	1.05	108	113.8	13.1	7.81	21.0	Yes	259

† met, DWP to be notified by end of next business day.

Revised February 2012